



# Applied Advanced Pattern Recognition Technology

By: James Kosak – Consultant  
Gerald Weber – EME  
James Herzau – Scientech  
Wally Walejeski – Scientech

January 14, 2009



# Presentation Topics

---

- **Overview of Midwest Generation's Monitoring Plan – “Work in Progress”**
- **Technology Evaluation**
- **Monitoring Focus**
- **Advanced Pattern Recognition Technology Deployment**
- **Project Status – January 2009**
- **Q&A**



# Our Mix of Generation: Thermal

- **8 coal-fired plants**
  - 6 in Illinois (MWGen)
  - 1 in Pennsylvania
  - 1 in West Virginia



- **9 gas-fired plants in California and Washington**



# About Edison Mission Group

---

- **A major Independent Power Producer (IPP), headquartered in Irvine, CA**
- **30 Power Plants, 10,634 megawatts**
- **Energy marketing and trading center in Boston, MA**
- **Sister company to Southern California Edison**



# Wind: A New Generation in Generation!

---

- 18 Wind farms in Iowa, Minnesota, New Mexico, Oklahoma, Pennsylvania, Texas and Wyoming.
- Projects are pending in Illinois, Maine, Maryland, Nebraska, New York, Pennsylvania, Utah, West Virginia, Wisconsin and Wyoming.
- We are one of the fastest growing developers of renewable energy.







# Midwest Generation WT Monitoring Objectives

---

- 1. Obtain an earlier warning on impending problems before a failure occurs**
  - **Prioritize tower inspections and analysis trouble shooting**
  - **Schedule Maintenance – Reduce unplanned events**
  - **Optimize crane usage**
  - **Reduce costs**
  - **Improve Availability**
- 2. Remote monitoring**
- 3. Apply technology WT fleet-wide**





# Pilot Effort - Technology Evaluations

---

## Purpose

- Determine if advanced pattern recognition technology could be effectively applied to wind-turbine monitoring
- Find the optimal vendor

## Approach

- Evaluate various vendors' offerings through simultaneous 3 month pilot efforts
- Evaluate: ease of use, application features, reliability, accuracy, deployment costs, and vendor support


## Project Results

- Sciencetech's PdP was chosen for Wind fleet-wide deployment
- Also decided to deploy at all Coal sites



# PdP – Predictive Pattern Recognition


- Utilizes a statistical state algorithm for analysis
- Compares current state to learned or referenced states based upon related historical information
- Used as a collective signal (component) monitoring tool for anomaly detection
- Can determine very subtle condition changes
- Model & signal status indications





# PdP - “Ins and Outs”

---



- Primary inputs:
  - Process data from PI
  - Other real-time data sources
- Outputs:
  - Normal / Abnormal status indicators
  - Data plots and drill down
  - Sensor integrity information
  - Various reports

# PdP - Displays

**Sciencetech Unit 3** Gross MW **417** #Notifications **6**

Component	Status	Count
3 TURBINE MECH	ABNORMAL	10
3 TURBINE PERF	NORMAL	4
3 GENERATOR	NORMAL	4
3A BFP	ABNORMAL	3
3A BFP TURB	NORMAL	1
3B BFP	ABNORMAL	3
3B BFP TURB	NORMAL	2
3A COND PUMP	NORMAL	1
3B COND PUMP	NORMAL	1
3 CONDENSER	NORMAL	2
3A SBAC	ABNORMAL	3
3B SBAC	NORMAL	1
3C SBAC	NORMAL	1
3A PULV & FEEDER	NORMAL	2
3B PULV & FEEDER	NORMAL	2
3C PULV & FEEDER	NORMAL	2
3D PULV & FEEDER	NORMAL	1
3E PULV & FEEDER	NORMAL	3
3F PULV & FEEDER	NORMAL	1
3G PULV & FEEDER	NORMAL	1
3A AIR HEATER	NORMAL	0
3B AIR HEATER	NORMAL	1
3A FD FAN	NORMAL	1
3B FD FAN	NORMAL	1
3A ID FAN	NORMAL	0
3B ID FAN	NORMAL	2
3 BOILER	NORMAL	2
3 WATER CHEM	NORMAL	2
31 HP FWH	NORMAL	0
32 HP FWH	NORMAL	1
33 LP FWH	NORMAL	2
34 LP FWH	NORMAL	0
35 LP FWH	NORMAL	1
36 LP FWH	ABNORMAL	1
37 LP FWH	ABNORMAL	1

NOTE: Click on Status indication for additional component information.

**PdP POINT SUMMARY**

UNIT: wil1  
MODEL: WTG40  
WTG40 WIND TURBINE  
CATEGORY: OK  
MODEL HEALTH: 0.987  
MODEL STATUS: ABNORMAL  
ABNORMAL POINTS: 1


PROCESSING RATE: 300 seconds  
VALIDATION PARAMETER: 0.95  
TOTAL POINTS: 29  
CUTOFF POINT: WTG40-ACTIVEPOWER  
ACTIVE POWER  
CUTOFF VALUE: 2180.00  
HIGH Cutoff: 10000.0, LOW Cutoff: 50.0  
ALARMS: X out of Y: X = 9, Y = 12  
ALARM ON: Residual

GROUP PLOTS: 4 Point

Status Legend: NORMAL ABNORMAL INACTIVE

INPUT POINT	DESCRIPTION	UNITS	ACTUAL	PREDICTD	VARIANCE	RESIDUAL	RESID HI	RESID LO	SIG ACT	TREND
WTG40-ACTIVEPOWER	ACTIVE POWER	KW	2180.000	2270.22	0.614	54.776	125.00	-125.00	Yes	
WTG40-C.BLADEANGLE	AVERAGE BLADE ANGLE	DEG	5.000	1.8488	1.743	1.118	3.00	-3.00	Yes	
WTG40-AMBTMP	AMBIENT TEMPERATURE	DEF C	19.000	19.070	0.043	-0.070	0.00	0.00	Yes	
WTG40-BLADEANGLEA	PITCH POSITION A	DEG	-0.900	1.2969	0.646	0.403	1.00	-1.00	Yes	
WTG40-BLADEANGLEB	PITCH POSITION B	DEG	-0.900	1.5473	0.084	0.053	1.00	-1.00	Yes	
WTG40-BLADEANGLEC	PITCH POSITION C	DEG	-0.900	1.3926	0.492	0.307	1.00	-1.00	Yes	
WTG40-BLADEANGLE	BLADE REFERENCE	DEG	0.000	1.1090	0.169	-0.109	1.00	-1.00	Yes	
WTG40-BLADEPRESSUF	BLADE HYDRAULIC PRESSURE	PSIG	236.000	232.997	1.992	-0.997	5.00	-5.00	Yes	
WTG40-CURRENTA	PHASE AMPS A	AMPS	1678.000	1839.47	0.210	15.528	100.00	-100.00	Yes	
WTG40-CURRENTB	PHASE AMPS B	AMPS	1734.000	1907.98	0.040	3.024	100.00	-100.00	Yes	
WTG40-CURRENTC	PHASE AMPS C	AMPS	1752.000	1923.10	0.038	2.903	100.00	-100.00	Yes	
WTG40-FREQUENCY	GENERATOR FREQUENCY	HZ	60.020	60.011	0.148	-0.001	0.03	-0.03	Yes	
WTG40-GENBEARDETEN	GENERATOR BEARING DRIVE END TEMP	DEG C	42.000	44.795	1.505	-3.795	4.00	-5.00	Yes	
WTG40-GENBEARNDETE	GENERATOR BEARING NON DRIVE END TEM	DEG C	63.000	62.997	0.312	-0.997	4.00	-5.00	Yes	
WTG40-HSGEARBRG1TA	HIGH SPEED GEAR BEARING TEMP 1	DEG C	68.000	67.591	0.409	-0.591	4.00	-5.00	Yes	
WTG40-IMSGEARBRG1T	IMS GEAR BEARING TEMP 1	DEG C	63.000	60.361	2.018	2.639	4.00	-5.00	Yes	
WTG40-IMSGEARBRG2T	IMS GEAR BEARING TEMP 2	DEG C	55.000	49.606	5.080	4.394	4.00	-5.00	Yes	
WTG40-REACTIVEPOWER	REACTIVE POWER	KVAR	399.000	411.148	0.381	-20.148	100.00	-100.00	Yes	
WTG40-ROTORRPM	ROTOR RPM	RPM	16.300	16.103	0.479	0.197	1.00	-1.00	Yes	
WTG40-VOLTAGEA	PHASE VOLTAGE A	VOLTS	412.600	411.845	1.292	-1.345	4.00	-4.00	Yes	


# PdP - Web Displays




Fleet	Unit	Point Summary	Assessment	Reports	Architect	Mon Sep 15 2008 5:19:21 PM				
Unit:	sc3 (Sciotech 3)					Model ID	Description	Status	Signals in Alarm	Health
Gross MW	122.49					31HPFWHp	31 HP FWH	NORMAL	0	0.992
#Notifications	19					32HPFWHp	32 HP FWH	NORMAL	0	0.996
						33LPFWHp	33 LP FWH	ABNORMAL	1	0.997
						34LPFWHp	34 LP FWH	ABNORMAL	1	0.996
						35LPFWHp	35 LP FWH	ABNORMAL	2	0.988
						36LPFWHp	36 LP FWH	ABNORMAL	1	0.996
						37LPFWHp	37 LP FWH	NORMAL	0	0.999
						3aAHTRp	3A AIR HEATER	NORMAL	0	0.997
						3aBFPp	3A BOILER FEED PUMP	ABNORMAL	3	0.839
						3aBFTp	3A BOILER FEED PUMP TURB	ABNORMAL	2	0.994
						3aCONDp	3A COND PUMP	INACTIVE	0	0.000
						3aFDFANp	3A FD FAN	ABNORMAL	1	0.997
						3aIDFANp	3A ID FAN	ABNORMAL	1	0.995
						3aPULFDp	3A PULV & FEEDER	INACTIVE	0	0.000
						3aSBACp	3A SBAC	ABNORMAL	1	0.998
						3bAHTRp	3B AIR HEATER	NORMAL	0	0.993
						3bBFPp	3B BOILER FEED PUMP	INACTIVE	0	0.000
						3bBFTp	3B BOILER FEED PUMP TURB	INACTIVE	0	0.000
						3bCONDp	3B COND PUMP	INACTIVE	0	0.000
						3bFDFANp	3B FD FAN	ABNORMAL	1	0.998
						3bIDFANp	3B ID FAN	ABNORMAL	1	0.995
						3BOILERp	3 BOILER	ABNORMAL	1	0.941
						3bPULFDp	3B PULV & FEEDER	NORMAL	0	0.967
						3bSBACp	3B SBAC	NORMAL	0	1.000
						3CONDSPp	3 CONDENSER	ABNORMAL	1	0.987



# PdP - Result Views



# The Nacelle – What's inside the box



*Ref: Siemens SWT36107 Wind Turbine*

- 1 – Spinner
- 2 – Spinner Bracket
- 3 – Blade
- 4 – Pitch Bearing
- 5 – Rotor Hub
- 6 – Main Bearing
- 7 – Main Shaft
- 8 – Gear Box
- 9 – Service Crane
- 10 – Brake Disc
- 11 – Coupling
- 12 – Generator
- 13 – Yaw Gear
- 14 – Tower
- 15 – Yaw Ring
- 16 – Oil Filter
- 17 – Generator Fan
- 18 – Canopy / Nacelle





# Typical Monitored Parameters

## Critical Components

Rotor

Blades

Pitch Mechanism

Nacelle

Gear Box

Main Gear

Generator

Hydraulic System

Yaw System

### PITCH SYSTEM

- Pitch angle
- Current to blade pitch servomotor
- Pitch angle velocity
- Pitch angle set point
- Servo speed set point
- Servo motor temperature
- Status signal servo brake

### GENERATOR

- Stator Temperatures
- Stator Currents
- Bearing Temperatures
- Bearing Vibrations

### TURBINE SYSTEM

- Rotor speed
- Electrical power
- Wind speed at met tower
- Wind speed wind turbine
- Wind direction at met tower
- Yaw alignment
- Air temperature

### MAIN BEARING & GEAR

- Bearing Temperature
- Bearing Vibration
- Gear Vibration



# Wind-Turbine (WT) Modeling Approach

---

## Model Configurations


- Presently configured one model type (generic) for all WTs
- Models are each comprised of 12-26 real-time sensor signals
- Models calculate bogey wind speed for comparison to actual
- PI utilizes this value to calculate a WTG efficiency

## Monitoring


- PdP application server interfaced with common WT PI server
- Models processed every five minutes
- Results reported to responsible engineer and wind management persons
- Using web features for reporting findings
- PdP results exported to PI



# Application Deployment



# Case Study - Generator NDE Bearing Temps Higher than predicted






# Another example of previous slide (this time WTG05)






# WTG16 Generator Bearing Drive End Temp

(Actual in Blue, Predicted in Green)




# Gearbox High Speed Shaft Bearing Temp High









# Gearbox High Speed Shaft – Actual vs Predicted



# Another Gearbox Bearing Temp Spike



# Reactive Power Measurement - Issue







# Project Status

---

- ✓ **3 Wind-Farms are utilizing PdP Monitoring System, 6 more in deployment stages (to expand to 13 total wind-farm sites)**
- ✓ **235 Wind-Turbines being monitored by PdP (to expand to >500 wind-turbines)**
- ✓ **Expect to complete this summer**
- ✓ **Preliminary Findings; Some problems, Most sensor related.**



# Coal Fleet Monitoring


---

- **Modeling all Coal Units over 200 MW's**
- **15 Units**
- **254 Models**
- **Began in 11/08**
- **Lessons learned already**
- **Issues Identified**
- **Plan to complete modeling by March**

# Coal Unit – ID Fan Thermocouple Failure




# ID Fan Thermocouple – Actual vs Predicted






# Coal Unit Boiler feed Pump Bearing Temp






# Coal Unit Boiler Feed Pump Inboard Bearing Temperature - High



# Coal Unit Feedwater Heater Shell Pressure

## “Lesson learned” : Include entire load range in Model





# Questions ?

---

