

# **Benefits of SaskPower's Monitoring & Diagnostics (M&D) Center**

Presented by:  
**Alyssa Beisel**  
Sciencetech Symposium  
Managing Plant Assets and Performance  
January 19 2012

## AVAILABLE GENERATION (net capacity)

### HYDROELECTRIC

1. Athabasca Hydroelectric System - 23 MW
  - Wellington (5 MW)
  - Waterloo (8 MW)
  - Charlot River (10 MW)
2. Island Falls Hydroelectric Station - 101 MW
4. Nipawin Hydroelectric Station - 255 MW
5. E.B. Campbell Hydroelectric Station - 288 MW
12. Coteau Creek Hydroelectric Station - 186 MW

### NATURAL GAS

3. Meadow Lake Power Station - 44 MW
9. Landis Power Station - 79 MW
8. Ermine Power Station - 92 MW
11. Queen Elizabeth Power Station - 430 MW
14. Success Power Station - 30 MW

### WIND

15. Cypress Wind Power Facility - 11 MW
17. Centennial Wind Power Facility - 150 MW

### COAL


19. Poplar River Power Station - 582 MW
20. Boundary Dam Power Station - 824 MW
22. Shand Power Station - 276 MW

### INDEPENDENT POWER PRODUCERS

6. Meridian Cogeneration Station - 210 MW
7. NRGreen Kerrobert Heat Recovery Project - 5 MW
10. Cory Cogeneration Station - 228 MW
13. NRGreen Loreburn Heat Recovery Project - 5 MW
16. SunBridge Wind Power Project - 11 MW
18. NRGreen Estlin Heat Recovery Project - 5 MW
21. NRGreen Alameda Heat Recovery Project - 5 MW

## TRANSMISSION

- 230 kV
- 138 kV
- - - 138 kV line operating at 72 kV
- Switching station
- ↔ Interconnection



# SaskPower

## Generation

- **3,513 MW Total Generating Capacity**
- **3 Coal-fired power stations**
- **7 Hydroelectric power stations**
- **7 Natural Gas power stations**
- **2 Wind Facilities**

## Transmission and Distribution


- **We maintain approximately 12,212 kilometres (km) of transmission lines and 142,843 km of distribution lines.**

## Coal Plants


# Outline of Presentation

- **M&D Process**
  - Relationship with Sciencetech
  - Roles and Responsibilities
- **Anomaly example**
- **Reporting and Managing M&D Process**
  - Cost-Benefit Spreadsheet

# M&D Process



# Prioritization




- **Monitoring efforts are prioritized:**
  - Units back from forced/planned outages
  - 300 MW units
  - 150 MW units
  - Units < 150 MW



# SaskPower M&D Center Roles & Responsibilities

Sciencetech

Monitor/Maintain/tune **PdP** models



**PEPSE** Modeling,  
Upgrades & Tuning




Anomaly  
Documentation

1. Team Room
2. Cost Benefit Spreadsheet




**PMAx**

Monitoring,  
IVM's &  
Tuning



**RULES**

Rules  
Monitoring &  
Continuous  
Improvement





# SaskPower M&D Center Roles & Responsibilities

## Performance Group:



Review items  
logged by Scientech


Review Unit  
Logs

Review GCC  
reports

Search existing /  
enter SAP Work  
notifications



Notify operations of  
critical issues (liason  
w Shift lead)



Manage /  
prioritize issues








Site Inspections  
& Testing



Site meetings

# SaskPower M&D Center Roles & Responsibilities

	<b>W. Perry Hill</b> Supervisor 566-3339 <a href="mailto:phill@saskpower.com">phill@saskpower.com</a> Plant Contact: None		<b>Scott McLeod</b> Senior Performance Engineer 566-2243 <a href="mailto:smcleod@saskpower.com">smcleod@saskpower.com</a> Plant Contact: BDPS C Plant, Western Plants (& assigned to FAMOS project)
	<b>Alyssa Beisel</b> Performance Engineer 566-3171 <a href="mailto:amclaughlin@saskpower.com">amclaughlin@saskpower.com</a> Plant Contact: BDPS B Plant		<b>Scott Prokopetz</b> Performance Engineer 566-4054 <a href="mailto:sprokopetz@saskpower.com">sprokopetz@saskpower.com</a> Plant Contact: SHPS, PRPS
	<b>Luke Montague</b> Grad Works Engineer 566-3431 <a href="mailto:lmontague@saskpower.com">lmontague@saskpower.com</a> Plant Contact: BDPS A Plant		

## Plant Services

Digital Systems Technologist  
Senior Electrical Controls Engineers  
Electrical Controls Engineers and EITs  
Mechanical Engineer

## Chemical Services

Senior Chemists  
Chemists  
Senior Metallurgist

## Environmental Initiatives

Environmental Engineer  
Environmental Chemist

## Equipment Integrity

QC Assurance Project Leaders  
Senior Maintenance Support Engineer  
Maintenance Support Specialist  
Maintenance Support Engineer  
Mechanical Engineer




**Plant Operations:** Monitor & Optimize variables that change frequently.


## Controllable losses



# BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example



# M&D Process



# BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example

- Step 1: Add anomaly to cost benefits spreadsheet

Microsoft Excel - BDPS-B benefits.xls

File Edit View Insert Format Tools Data Bluebeam PI Window Help GPCALCS R\*TIME Adobe PDF Type a question for help

75% 14 B

Reply with Changes... End Review...

C171 PMAX

BDPS B Plant Anomaly Log & Cost Benefit Analysis:										
This is the sheet where the M&D staff enter the information from ALL findings. Enter all findings regardless of consequence, probability of failure, or if the issue is an expected character										
Anomaly Identification										Anomaly Diag
TOTALS										
Date Identified	Identified By:	Tool	Unit	Anomaly Description	Location or Pi Tag Name:	Component	Issue Type	IVM Activity	Diagnosis By:	
20-Oct-11	SCIENTECH	PMAX	BD4	BD4 Condenser pressure is reading high.	BDPS-4SG01	Turbine (Steam)				MCLEOD
		PdP PMAX Rules PEPSE Pi Plant Found Field Test/Inspection								

Overview Probabilities Data Entry Statistics

Ready

# BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example

- Step 1 (continued): Add to Lotus Notes Team Room & Notify Performance contact


BDPS B Plant Performanc... X BDPS C Plant Performanc... X

New Document New Response New Response to Response Chat Database Help

Date ^	Topic	Due ^	Auth
▼ BDPSB-04	▼ S Steam Cycle Systems		
★ ▶ A Primary	▶ SB Main&Reheat Steam System		
★ ▶ D Fuel M	▶ SD Condensate System		
★ ▶ E Electric	▶ SE Steam Extraction System		
★ ▶ G Comb	▼ SG Condenser System		
★ ▶ I Instrum	▼ 20/10/2011 20 BD4 Condenser pressure is higher than expected		
★ ▶ J Protect	Preview		
★ ▶ K Water C	Scott,		
★ ▶ S Steam	I noticed that the LP Turbine exhaust pressure tag is responding very slowly on this unit as it comes down in power.		
★ ▶ SB Main&Reheat Steam System			
★ ▶ SD Condensate System			
★ ▶ SE Steam Extraction System			
★ ▶ SG Condenser System			
★ ▼ 20/10/2011 20	BD4 Condenser pressure is higher than expected		Scot
	Preview		wer
	Scott,		ture
	I noticed that the LP Turbine exhaust pressure tag is responding very slowly on this unit as it comes down in power.		



# M&D Process



## ***BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example***

- **Step 2: Investigate anomaly**
  - Dig into background
  - Compare historical trends
  - Compare with other units
  - Compare with similar equipment
  - Shift log
  - Search work orders

# BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example

- Step 2 (continued): Investigate anomaly
  - Discuss with Sciencetech

The screenshot shows a web application with two tabs: "BDPS B Plant Performance..." and "BDPS C Plant Performance...". The interface includes a toolbar with buttons for "New Document", "New Response", "New Response to Response", "Chat", and "Database Help". Below the toolbar is a table with columns for "Date", "Topic", "Due", and "Author". The table contains several entries, including "SE Steam Extraction System" and "SG Condenser System". One entry is expanded, showing a discussion thread. The thread starts with a post from Scott McLeod on 20/10/2011, stating "BD4 Condenser pressure is higher than expected". This is followed by three responses: "Not related to compression in PI (Scott McLeod/SaskPower 10/20/2011)", "Entered notification (Scott McLeod/SaskPower 10/20/2011)", and "Further note from Sciencetech (Scott McLeod/SaskPower 10/23/2011)". Below the table is a "Preview" section showing a message from Scott: "Looking at this more, we think there is a bigger issue with BD4s backpressure. It looks quite high compared to all the other sensors. This is giving us a very poor cleanliness factor on the condenser. We are then passing that cleanliness factor to PEPSE, to help calculate the target backpressure. The current backpressure is reading 3.05 INHG, when the Psat at the hotwell temp is 1.91 INHG. The LP exhaust hood temp (BDPS-4TA36) agrees with the hotwell temp. What is the difference between the exhaust hood temp (BDPS-4TA36) and the Turb Exhaust temp (BDPS-4TA35)? These two temperatures do not agree at all, with the Exhaust temp (4TA35) being much lower than either the hood temp or the hotwell. Also on the circ water outlet temps, there seems to be quite a large variation in the measured temps (79-84.5 degrees currently.) Are some of these tags better than others? We're just looking for some direction on this, so that we can provide better values to the PEPSE model to get an accurate target backpressure. Thanks, Scott Nedrow".

Date	Topic	Due	Author
	SE Steam Extraction System		
	SG Condenser System		
20/10/2011 20	BD4 Condenser pressure is higher than expected		Scott McLeod/
	Not related to compression in PI (Scott McLeod/SaskPower 10/20/2011)		
	Entered notification (Scott McLeod/SaskPower 10/20/2011)		
	Further note from Sciencetech (Scott McLeod/SaskPower 10/23/2011)		

Preview ▼

Scott,  
Looking at this more, we think there is a bigger issue with BD4s backpressure.

It looks quite high compared to all the other sensors. This is giving us a very poor cleanliness factor on the condenser. We are then passing that cleanliness factor to PEPSE, to help calculate the target backpressure. The current backpressure is reading 3.05 INHG, when the Psat at the hotwell temp is 1.91 INHG. The LP exhaust hood temp (BDPS-4TA36) agrees with the hotwell temp. What is the difference between the exhaust hood temp (BDPS-4TA36) and the Turb Exhaust temp (BDPS-4TA35)? These two temperatures do not agree at all, with the Exhaust temp (4TA35) being much lower than either the hood temp or the hotwell. Also on the circ water outlet temps, there seems to be quite a large variation in the measured temps (79-84.5 degrees currently.) Are some of these tags better than others?

We're just looking for some direction on this, so that we can provide better values to the PEPSE model to get an accurate target backpressure.

Thanks,  
Scott Nedrow

## ***BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example***

- **Step 2 (continued): Investigate anomaly**
  - Weekly group anomaly discussion


### **Summary Anomaly Log & Cost Benefit Analysis:**

This is the sheet is used only for summarizing the SaskPower wide M & D effort. Do not enter new findings on this

Anomaly Identification							Anomaly Diagnosis	
Date Identified	ntified	To	Un	Anomaly Description	Function Location or Pi Tag Name	Componer	Diagnosis By:	Date Diagnosed
30-Aug-11	SCIE	PdP	BD6	BD6 6A SAH Gas outlet temp dropped 20 lower than B SAH and avg cold end temp dropped about 10 deg since 7/17/2011	BDPS-6GG-TT-119A BDPS-6GG-TT-119B BDPS-6AF-XTT-073A BDPS-6AF-XTT-073B	Air Heater	Sort Ascending Sort Descending  (All) (Top 10...) (Custom...) AZIZ BEISEL Hodgson MONTAGUE PLANT PREIKCHAT (Blanks) (NonBlanks) PREIKCHAT	
26-May-11	SCIE	PdP	SH1	SH1 Cooling towers - higher amps on multiple revisted -- possible scaling/fouling?	SHPS-1KE-IT-069A SHPS-1KE-IT-069B SHPS-1KE-IT-069C SHPS-1KE-IT-069D SHPS-1KE-IT-069E SHPS-1KE-IT-069F	Cooling Tower		

# ***BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example***

- **Step 2 (continued): Investigate anomaly**
  - **Discuss with local experts & plant**





- **Step 2 (continued): Investigate anomaly**

- 



## ***BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example***

- **Step 2 (continued): Investigate anomaly**
  - **Work order**

Transmitter will be moved to operating floor in 2012 (Scott McLeod/SaskPower 10/27/2011)

Leq correction added to transmitter (Scott McLeod/SaskPower 10/27/2011)

Preview ▼

Scott

I have entered a notification for the Overhaul on BD4-2012 to have this transmitter moved.

Notification	10735783	M1	BD4 OH 4-GS-PT-210 Change Location	
Notific. Status	NOPR ORAS			CRTD
Order	16918393			
Maintenance Request  Documents				
Subject				
Description				
BD4 OH 4-GS-PT-210 Change Location				
Move transmitter to operating floor. Like BD1 and BD2.				

# BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example

- Step 2 (continued): Investigate anomaly
  - Document in the cost benefit spreadsheet

Microsoft Excel - BDPS-B benefits.xls

File Edit View Insert Format Tools Data Bluebeam VBA Macros PI Window Help GPCALCS R\*TIME Adobe PDF


75% Arial 14

Reply with Changes... End Review...

H171 Instrument

	F	G	H	I	J	K	L	M
1								
2	ence, probability of failure, or if the issue is an expected characteristic change (ie. resulting from equipment run in, operator biasing, etc). The "							
3	Anomaly Diagnosis							
4								
5	Function Location or Pi Tag Name:	Component	Issue Type	IVM Activit	Diagnosis E	Date Diagnose	Notification Number	Diagnosis Description
171	BDPS-4SG01	Turbine (Steam)	Instrument	VM Added	MCLEOD	20-Oct-11	10734568	Entered notification 10734568 for IT's to reduce the compression on 4SG01 in AOL block.

# M&D Process



## ***BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example***

- **Step 3: Resolve anomaly**
  - **Work order or operational changes**

Order	PM02	16918393	BDB 04 OH 4-GS-PT-210 Change Location		
Sys.Status	REL	ESTC	NMAT	PRC	SETC
					PLC
<b>HeaderData</b>   Operations   Components   Costs   Partner   Objects   Additional Data					
Person responsible			Notifctn 10735783		
PlannerGrp	104 / 0004	BD Prod Sup E/I/ET	Est. Costs	500.16	CAD
Mn.wk.ctr	BD05IT51 / 0004	BD BCI IT CONTR...	PMActType	005	Overhaul
			SystCond.		
			Address		
<b>Dates</b>					
Bsc start	02/17/2012	23:00	Priority	High (7 Days)	
Basic fin.	03/06/2012	11:00	Revision	BD4-2012 Unit 4 2012 Unit Overhaul	
<b>Reference object</b>					
Func. Loc.	BDPSB-04-SG-COHD		CONDENSER,4		
Equipment	8400027027		TRANSMITTER,PRESS,PT210,CONDENSER BACK,4		



## ***BDPS Unit #4 Condenser Exhaust Pressure Anomaly Example***

- **Step 3: Resolve anomaly**
  - **Document in cost benefit spreadsheet**

Anomaly Resolution		
Date Resolved ▼	Resolved By ▼	Resolution Description ▼
27-Oct-11	PLANT	IT added leg compensatrion, so TX won't be blown down anymore. Plant will move the TX to above the pressure tap during the 2012 overhaul on notification 10735783.

# Reporting and Managing M&D

- **Unit Cost Benefit Sheet**
  - Work management
  - Documentation
  - Prioritization
- **Summary Benefits Sheet**
  - Weekly M&D Discussion Meetings
  - Weekly and monthly reporting
  - Distribution of resources

# Reporting and Managing M&D

<u>Unit</u>	BDPSB					
<u>Start Date</u>	1-Dec-2011					
<u>End Date</u>	1-Jan-2012	<b>Anomaly Identification</b>				
	<b>Unit</b>	<b>Anomaly Description</b>	<b>Issue Type</b>	<b>Identified By:</b>	<b>Date Identified</b>	<b>Function Location or Pi Tag Name:</b>
	BD4	BD4 PA Fan 4A OB MTR temp intermittently spiking high (to 400F or 2300F) since 3 Nov 2011 (BDPS-4AL04)	Instrument	BEISEL	6-Dec-11	BDPS-4AL04
	BD4	BD4 BFP motor power signals reading about double what they should.	Equipment	MCLEOD	7-Dec-11	BDPS-4SJ-JT-030A
	BD4	BD4 PA Fan 4B Outboard Bearing temp made a step change on 11/5/11 of 5-10 DegF. Deviation between inboard/outboard bearings is increasing.	Model Tuning	SCIENTECH	8-Dec-11	BDPS-4AL08
	BD3	BD3 3B ID Fan IB BRG vibration always lower than other bearings (BDPS-3GG15)	Instrument	BEISEL	20-Dec-11	BDPS-3GG15
	BD4	BD4 FD Fan 4B Motor temperatures reading low. The winding temp signal is tracking the process but averages about 35 DegF (BDPS-4AF12).	Instrument	SCIENTECH	22-Dec-11	BDPS-4AF12
	BD3	BD3 FD Fan 3A OB Bearing Temp is suspect of erroneous reading	Instrument	SCIENTECH	15-Dec-11	BDPS-3AF02

# Reporting and Managing M&D


							Unit	BDPSB
							Start Date	1-Dec-2011
							End Date	1-Jan-2012
Anomaly Diagnosis								
Unit	Anomaly Description	Issue Type	Diagnosis By:	Date Diagnosed	Notification Number	Diagnosis Description	Total \$	
BD4	BD4 PA Fan 4A OB MTR temp intermittently spiking high (to 400F or 2300F) since 3 Nov 2011 (BDPS-4AL04)	Instrument	BEISEL	6-Dec-11	10745233	This was previously repaired under notification 10738590 on Nov 16, failed again Nov 22. The plant has added this to WO 18910896 to replace the thermocouple at the next fan motor PM (Feb 2012).		
BD4	BD4 BFP motor power signals reading about double what they should.	Equipment	MCLEOD	7-Dec-11	10712015	Asked Jim A. to have EL's investigate the MPU configuration.		
BD4	BD4 PA Fan 4B Outboard Bearing temp made a step change on 11/5/11 of 5-10 DegF. Deviation between inboard/outboard bearings is increasing.	Model Tuning	BEISEL	21-Dec-11		4B OB BRG is hotter than the other BD4 fan BRGs, but is actually cooler than both BD3 OB PA fan BRGs. Suspect door closed or other ambient cooling effect was removed. Retraining please.		
BD3	BD3 3B ID Fan IB BRG vibration always lower than other bearings (BDPS-3GG15)	Instrument	BEISEL	21-Dec-11	10748794	Last BRG vib test showed 1.7 mils compared with 0.3 mils from instrument. Having instrument checked.		
BD4	BD4 FD Fan 4B Motor temperatures reading low. The winding temp signal is tracking the process but averages about 35 DegF (BDPS-4AF12).	Instrument	BEISEL	28-Dec-11	10749620	seems to be reading ambient.		
BD3	BD3 FD Fan 3A OB Bearing Temp is suspect of erroneous reading	Instrument	BEISEL	19-Dec-11	10748028	suspect tc not seated.		
BD4	BD4 4B ID FAN IB and OB Bearing Vibration on slight rise since early Aug 2011 outage (periodically 1 mil high)	Monitor Chang	BEISEL	21-Dec-11		Returned to normal after unit outage. Started increasing Nov 5th 2011, still was not in alarm, alarmed Nov 9th (>4mil) but then unit came offline to clean precip, came back online and is running as predicted.		
BD3	BD3 3A PA Fan OB Mtr Bearing running consistently about 10 deg higher than predicted since end of Oct 2011	Model Tuning	BEISEL	21-Dec-11		This increase happened same time as 4AL08 went into alarm, ambient effect suspected. Retrain. Note: We already retrained in August 2011 to accept higher temps.		

# Reporting and Managing M&D

<i>Last updated:</i>		<i>January 18, 2012</i>	
<b>Plant</b>	<b>This Month</b>	<b>This Year</b>	<b>Cumulative</b>
<b>Start Date</b>	2011-Dec-01	2011-Jan-01	2006-Jan-01
<b>End Date</b>	2012-Jan-01	2012-Jan-01	2020-Jan-01
<b>Total (By M&amp;D Center &amp; Plant Staff)</b>			
Anomalies Identified (qty)	6	146	185
Anomalies Diagnosed (qty)	8	139	164
Anomalies Resolved (qty)	3	91	108
Anomalies Identified (\$)			
Anomalies Diagnosed (\$)			
Anomalies Resolved (\$)			
<b>By M&amp;D Center</b>			
Anomalies Identified (qty)	6	141	179
Anomalies Diagnosed (qty)	8	123	146
Anomalies Resolved (qty)	0	33	33
Anomalies Identified (\$)			
Anomalies Diagnosed (\$)			
Anomalies Resolved (\$)			
<b>By Plant Staff</b>			
Anomalies Identified (qty)	0	5	6
Anomalies Diagnosed (qty)	0	16	18
Anomalies Resolved (qty)	3	58	75
Anomalies Identified (\$)			
Anomalies Diagnosed (\$)			
Anomalies Resolved (\$)			




# Reporting and Managing M&D



# SaskPower Monitoring & Diagnostics

## Cumulative Potential Cost Savings (OM&A, Replacement Energy)



# Probability, OM&A Impact and Duration Estimated Costs

	Probabilities			Identified by		OM&A Impacts			Plant Finds		M&D Center finds		Derate Duration			Plant Finds		M&D Center finds		Derate Magnitude			Plant Finds		M&D Center finds	
	Risk					Value							Derate Duration							Derate Magnitude						
	Minor %	Major %	Catastrophic %	Plant %	M&D Center %	Minor \$	Major \$	Catastrophic \$	Value \$	Prob. Value \$	Value \$	Prob. Value \$	Minor hr	Major hr	Catastrophic hr	Duration hr	Prob. Dur. hr	Duration hr	Prob. Dur. hr	Minor %	Major %	Catastroph %	Derate %	Prob. Derat %	Derate %	Prob. Derat %
Air Heater	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
BFP	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	50.00%	50.00%	6%	3%	6%	3%
Boiler Air/Gas	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	50.00%	100.00%	7%	3%	7%	3%
Boiler Chem	89.00%	10.90%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	8%	12%	8%
Boiler Leak	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Boiler Temp	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Boiler Water/Steam	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
CEP	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Condenser	89.00%	10.90%	0.10%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Cooling Tower	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
CW Pumps	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	20.00%	20.00%	3%	2%	3%	2%
Fans	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	50.00%	100.00%	7%	3%	7%	3%
FWH	80.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	0.00%	0.00%	0.00%	0%	0%	0%	0%
Generator Mech	90.00%	9.50%	0.50%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	11%	5%	11%	5%
Generator Temp	90.00%	9.50%	0.50%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	11%	5%	11%	5%
Large Valves	99.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Mills	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	16.67%	16.67%	3%	1%	3%	1%
Large Motors	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Other	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
PI / FAMOS failure																									0%	
Precipitator																									6%	
SRAC																									6%	
Start up assist																									6%	
Turbine (Gas)																									4%	
Turbine (Steam)																									4%	

Probabilities

Risk

Identified by

Minor %

Major %

Catastrophic %

Plant %

M&D Center %

Air Heater	89.00%	10.00%	1.00%	50%	50%
BFP	89.00%	10.00%	1.00%	50%	50%
Boiler Air/Gas	89.00%	10.00%	1.00%	50%	50%
Boiler Chem	89.00%	10.90%	0.10%	50%	50%
Boiler Leak	89.00%	10.00%	1.00%	50%	50%
Boiler Temp	89.00%	10.00%	1.00%	50%	50%
Boiler Water/Steam	89.00%	10.00%	1.00%	50%	50%

## Probability, OM&A Impact and Duration Estimated Costs

	Probabilities					OM&A Impacts										Derate Duration										Derate Magnitude									
	Risk					Identified by		Value			Plant Finds			M&D Center finds			Derate Duration			Plant Finds			M&D Center finds			Derate Magnitude			Plant Finds			M&D Center finds			
	Minor %	Major %	Catastrophic %	Plant %	M&D Center %	Minor \$	Major \$	Catastrophic \$	Value \$	Prob. Value \$	Value \$	Prob. Value \$	Value \$	Prob. Value \$	Minor hr	Major hr	Catastrophic hr	Duration	Prob. Dur hr	Duration hr	Prob. Dur hr	Minor %	Major %	Catastrophic %	Derate %	Prob. Derate %	Derate %	Prob. Derate %							
Air Heater	88.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
BFP	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	50.00%	50.00%	8%	3%	6%	3%							
Boiler Air/Gas	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	50.00%	100.00%	7%	3%	7%	3%							
Boiler Chem	89.00%	10.00%	0.10%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Boiler Leak	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Boiler Temp	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Boiler Water/Steam	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
CEP	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Condenser	89.00%	10.00%	0.10%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Cooling Tower	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
C/W Pumps	88.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	20.00%	20.00%	3%	2%	3%	2%							
Fans	99.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	50.00%	100.00%	7%	3%	7%	3%							
FWH	80.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	0.00%	0.00%	0.00%	0%	0%	0%	0%							
Generator Mech	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Generator Temp	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Large Valves	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Mills	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Other	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
P / FAMOS failure	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Precipitator	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
SRAC	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Start up assist	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Turbine (Gas)	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							
Turbine (Steam)	10.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%							

	Probabilities					OM&A Impacts		
	Risk			Identified by		Value		
	Minor %	Major %	Catastrophic %	Plant %	M&D Center %	Minor \$	Major \$	Catastrophic \$
Air Heater	89.00%	10.00%	1.00%	50%	50%	\$	\$	\$
BFP	<b>Air heater (Minor):</b> Instrument failure Baskets partially plugged. Increased bypass leakage. Blown seal not resulting in PA Fan or FD Fan capacity limitations.					\$	\$	\$
Boiler Air/Gas						\$	\$	\$
Boiler Chem						\$	\$	\$
Boiler Leak						\$	\$	\$
Boiler Temp						\$	\$	\$
Boiler Water/Steam						\$	\$	\$
CEP	<b>Air heater (Major):</b> Baskets fully plugged, must be power washed off-line. Blown seal resulting in PA Fan or FD Fan capacity limitations.					\$	\$	\$
Condenser						\$	\$	\$
Cooling Tower						\$	\$	\$
CW Pumps						\$	\$	\$
Fans						\$	\$	\$
FWH						\$	\$	\$
Generator Mech	<b>Air Heater (Catastrophic):</b> Air Heater fire Baskets plugged and cannot be powerwashed. Bearing wiped					\$	\$	\$
Generator Temp						\$	\$	\$
Large Valves						\$	\$	\$

# Probability, OM&A Impact and Duration Estimated Costs

	Probabilities			OM&A Impacts												Derate Duration												Derate Magnitude											
	Risk			Identified by		Value			Plant Finds			M&D Center finds			Derate Duration			Plant Finds			M&D Center finds			Derate Magnitude			Plant Finds			M&D Center finds									
	Minor %	Major %	Catastrophic %	Plant %	M&D Center %	Minor \$	Major \$	Catastrophic \$	Value \$	Prob. Value \$	Value \$	Prob. Value \$	Value \$	Prob. Value \$	Minor hr	Major hr	Catastrophic hr	Duration hr	Prob. Dur. hr	Duration hr	Prob. Dur. hr	Duration hr	Prob. Dur. hr	Duration hr	Prob. Dur. hr	Duration hr	Prob. Dur. hr	Duration hr	Prob. Dur. hr	Duration hr	Prob. Dur. hr								
Air Heater	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
BFP	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Boiler Air/Gas	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Boiler Chem	89.00%	10.00%	0.10%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Boiler Leak	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Boiler Temp	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Boiler Water/Steam	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
CEP	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Condenser	89.00%	10.00%	0.10%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Cooling Tower	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
C/W Pumps	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Fans	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
FWH	80.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Generator Mech	90.00%	9.50%	0.50%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Generator Temp	90.00%	9.50%	0.50%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Large Valves	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Mills	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Large Motors	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Other	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Pi / FAMOS failure	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
Precipitator	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours	z hours							
SBAC																																							
Start up ass																																							
Turbine (Ga																																							
Turbine (Ste																																							

	Derate Duration						
	Derate Duration			Plant Finds		M&D Center finds	
	Minor hr	Major hr	Catastrophic hr	Duration hr	Prob. Dur. hr	Duration hr	Prob. Dur. hr
Air Heater							
BFP							
Boiler Air/Gas							
Boiler Chem							
Boiler Leak							
Boiler Temp							



# Probability, OM&A Impact and Duration Estimated Costs

	Probabilities			Identified by		OM&A Impacts			Derate Duration				Derate Magnitude																
	Risk			Plant %	M&D Center %	Value			Plant Finds		M&D Center finds		Derate Magnitude				Plant Finds		M&D Center finds										
	Minor %	Major %	Catastrophic %			Minor \$	Major \$	Catastrophic \$	Value \$	Prob. Value \$	Value \$	Prob. Value \$	Minor hr	Major hr	Catastrophic hr	Duration hr	Prob. Dur hr	Duration hr	Prob. Dur hr	Minor %	Major %	Catastrophic %	Derate %	Prob. Derate %	Derate %	Prob. Derate %			
Air Heater	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
BFP	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	50.00%	50.00%	6%	3%	6%	3%
Boiler Air/Gas	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	50.00%	100.00%	7%	3%	7%	3%
Boiler Chem	89.00%	10.90%	0.10%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	8%	12%	6%
Boiler Leak	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Boiler Temp	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Boiler Water/Steam	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
CEP	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Condenser	89.00%	10.90%	0.10%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	8%	12%	6%
Cooling Tower	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
C/W Pumps	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	20.00%	20.00%	3%	2%	3%	2%
Fans	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	50.00%	100.00%	7%	3%	7%	3%
FWH	80.00%	10.00%	10.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	0.00%	0.00%	0.00%	0%	0%	0%	0%
Generator Mech	90.00%	9.50%	0.50%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	11%	5%	11%	5%
Generator Temp	90.00%	9.50%	0.50%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	11%	5%	11%	5%
Large Valves	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Mills	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	16.67%	16.67%	3%	1%	3%	1%
Large Motors	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
Other	89.00%	10.00%	1.00%	50%	50%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	1.00%	100.00%	100.00%	12%	6%	12%	6%
PI / FAMOS failure	0.00%	0.00%	0.00%	0%	0%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	0.00%	0.00%	0.00%	0%	0%	0%	0%
Precipitator	0.00%	0.00%	0.00%	0%	0%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	0.00%	0.00%	0.00%	0%	0%	0%	0%
SBAC	0.00%	0.00%	0.00%	0%	0%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	0.00%	0.00%	0.00%	0%	0%	0%	0%
Start up assist	0.00%	0.00%	0.00%	0%	0%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	0.00%	0.00%	0.00%	0%	0%	0%	0%
Turbine (Gas)	0.00%	0.00%	0.00%	0%	0%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	0.00%	0.00%	0.00%	0%	0%	0%	0%
Turbine (Steam)	0.00%	0.00%	0.00%	0%	0%	\$ xxx	\$ xxx	\$ xxx	\$ yy	\$ yy	\$ zzz	\$ zzz	x hours	y hours	z hours	y hours	y hours	z hours	z hours	z hours	z hours	z hours	0.00%	0.00%	0.00%	0%	0%	0%	0%

Derate Magnitude

Derate Magnitude

Plant Finds

M&D Center finds

Minor %

Major %

Catastrophic %

Derate %

Prob. Derate %

Derate %

Prob. Derate %

Air Heater

1.00%

100.00%

100.00%

12%

6%

12%

6%

BFP

1.00%

50.00%

50.00%

6%

3%

6%

3%

Boiler Air/Gas

1.00%

50.00%

100.00%

7%

3%

7%

3%

Boiler Chem

1.00%

100.00%

100.00%

12%

6%

12%

6%

Boiler Leak

1.00%

100.00%

100.00%

12%

6%

12%

6%

Boiler Temp

1.00%

100.00%

100.00%

12%

6%

12%

6%

Boiler Water/Steam

1.00%

100.00%

100.00%

12%

6%

12%

6%

CEP

1.00%

100.00%

100.00%

12%

6%

12%

6%

Condenser

1.00%

100.00%

100.00%

12%

6%

12%

6%

Cooling Tower

1.00%

100.00%

100.00%

12%

6%

12%

6%

C/W Pumps

1.00%

20.00%

20.00%

3%

2%

3%

2%

Fans

1.00%

50.00%

100.00%

7%

3%

7%

3%

FWH

0.00%

0.00%

0.00%

0%

0%

0%

0%

SaskPower  
powering the future



# Probability, OM&A Impact and Duration

## Estimated Costs

- **Probabilistic Costing Calculations**
  - Minor
  - Major
  - Catastrophic
  - Risk
  - Dollar values
  - Derate Duration
  - Derate Magnitude

# Questions or Comments

- How are your monitoring and diagnostics findings being *quantified*?
- How are your monitoring and diagnostics findings being *communicated*?

# Thank you!