

***Combined Cycle Performance Analysis***

*Presented by:*

***George Slanina***

***Houston Lighting & Power Company***

*Model by:*

***G. L. Slanina***

***A. Lau***

***Houston Lighting & Power Company***

# COMBINED CYCLE PERFORMANCE ANALYSIS

## ABSTRACT

Previous Gas Turbine (GT) analysis was basically limited to unit output and heat rate for the following reasons:

- o GT component analysis requires accurate temperature and pressure measurements
- o Additional temperature, pressure and flow measurements are required
- o HRSG flows, pressures and temperatures must be accurately determined
- o Flue gas bypassing must be determined

As a result of the above a performance model was built in PEPSE. This performance model includes four GTs, four bypass stacks, four HRSGs, one steam turbine generator, one condenser, one condensate pump, one boiler feed pump and one gland steam condenser. Each GT exhausts into an HRSG which is modeled in the performance mode as a convective boiler section. The amount of flue gas escaping thru the stack by-pass is modeled by controlling the bypass flow of flue gas to obtain the stack temperature. The steam turbine is modeled as a general turbine with one extraction. Since HL&P's Maximum Capability Testing is performed at Valves Wide Open (VWO) on the steam turbine, the bleeds and leakoffs are modeled as fixed flows. There are assumptions and controls built into the model to simulate interstage cooling air by-passing the compressor section. Estimates are made since these are internal flow paths and are not easily measured. A fixed percentage is used for this cooling flow, the reason for this is because in actuality multiple air extractions exist and the amount from each is not measured or readily measurable. This cooling air is then mixed with the expander first stage aft section. This requires modeling the expander as two sections with a cooling air mixer. This has to be done to compensate somewhat for PEPSEs' lack of interstage modeling capabilities. In reality the admission of cooling air is complicated somewhat since the air is injected in the first stage buckets, first stage forward and aft wheelspaces, second stage wheelspaces and third stage wheelspaces.

The HL&P Maximum Capability Test is designed to establish the maximum generation of the unit, document any equipment limitations, and define current equipment performance or efficiency. General plant process instruments are used for pressures, temperatures and flows in general. Where more accurate instrumentation is required the Central Results Performance Analysis Group will supply and install necessary test grade instrumentation. For these Combined Cycle tests, ambient temperature is monitored, GT by-pass temperature, HRSG flue gas temperature and fuel gas components, fuel flow (P,T,Diff.) and fuel analysis, along with standard PEPSE inputs for the HRSG, Steam

## INTRODUCTION

The purpose of this paper is to demonstrate some of the capabilities of PEPSE in performing Combined Cycle Unit Performance Analysis. Thru the use of Controls, Schedules, Operations, and Operational Variables a method of evaluation for the Combined Cycle and adjustment to standard conditions is possible.

The T. H. Wharton Units 3 and 4 are each a Combined Cycle (CC) unit comprised of four (4) General Electric(GE) Frame 7, Model MS7000 Gas Turbines (GTs), four (4) Heat Recovery Steam Generators (HRSGs) and one Steam Turbine Generator also furnished by GE. The units were originally placed in service on August 16, 1974. Each gas turbine has a base rating of 50.25 MW without inlet air filter and a design heat rate of 12,900 BTu(HHV)/KWHr. The combined cycle unit has a base rating of 279.9 MW Net for the unit output without inlet air filters and a heat rate of 8710 BTu(HHV)/KWHr. The turbine generator is rated at 133,000 KVA, three phase, 60 cycle, 0.85 PF, 13,800 VOLTS, 0.58 SCR at 30 psig H<sub>2</sub>, and designed for 95°F cooling water. The combined cycle performance is based on 3.5 inHg absolute back pressure at the steam turbine exhaust, ambient temperature of 100°F, atmospheric pressure of 14.64 psia and an elevation of 122 feet above sea level with gas turbine exhaust silencers installed.

Each GT exhaust is directed to a dedicated HRSG. The steam generated from the HRSG then feeds the GE 100MW steam turbine with the rated inlet conditions of 800psig and 850°F. The steam turbine is an outdoor rated, tandem-compound, double flow, non-reheat, non-regenerative cycle machine with 23" last stage blades. There is a gland steam condenser with no other provisions for feedwater heating. For the above conditions, the maximum expected steam flow to the turbine is 990,000 lb/hr.

Over the years the GE Frame 7 GTs have undergone several modifications such as installation of inlet guide vanes, inlet air bag house filters. Most of the modifications have increased pressure drops and cost the unit in heat rates. However, being completed in 1995 are GT prime upgrades designed to upgrade output by some 4.4% and 9.9% and reduce the GT heatrate by some 2% and 3.2% at 40°F and 100°F respectively. The test data analysis this paper covers was performed in June of 1992 on the T. H. Wharton Unit 4.

## BODY OF PAPER

A Maximum Capability test was performed on T. H. Wharton Combine Cycle Unit 4 on

June 25, 1992. This test was designed to evaluate the maximum generation achievable with four (4) gas turbines, four (4) heat recovery steam generators and the steam turbine in service. The test is to also identify actual and potential equipment limitations and problems related to capacity or heat rate.

Previous Combined Cycle Analyses methods required component analysis with accurate temperatures, pressures and flows that required considerable instrumentation and was done during design verification and initial testing or under research projects with EPRI. The HRSG feed water flow, pressure and temperature had to be accurately measured and with some flue gas by-passing thru the bypass dampers it was difficult to analyze the system.

As for methods used in Combined Cycle Analysis, The American Society of Mechanical Engineers (ASME) performance test codes cover the unit output and heat rate issues but do not address individual GT section and other Combined Cycle component analysis. There are some GT and Combine Cycle analysis software applications offered by various software companies, GT experts, and the Electric Power Research Institute (EPRI). At this period the Performance Analysis Division had not evaluated these applications although HL&P's Maintenance Division had procured EPRI's Gas Turbine Evaluation (GATE) and Efficiency Map (EMAP) software applications. These applications, upon preliminary review, required detail GT and combined cycle design parameters. Some customizing and training would be required before one could expect to fully realize some of their value and capability. As an alternative a performance model built with PEPSE, the general purpose thermodynamic application, was investigated since several Performance Analysis personnel were familiar with the software.

To aid in this analysis a PEPSE model was made and verified. The test inputs were identified to be obtained on the unit. Plant instrumentation was used along with Performance Analysis instruments on low pressure and critical areas or where plant instruments are not installed. Performance Analysis also supplied a flue gas analysis trailer to collect flue gas component and temperatures in the HRSG stacks. Manual data was taken for all data except the fuel gas data that came from the Bailey terminal.

The PEPSE model uses several controls to perform function in the thermodynamic balance for each gas turbine in the model:

- o The gas turbine efficiency is controlled to obtain the test MW load.
- o The compressor efficiency is controlled to obtain the compressor outlet test temperature.
- o The stack bypass is controlled to obtain the test measured stack outlet temperature.

The steam turbine is modeled as a general turbine PEPSE Type 08 with an expansion line swing to match the test measured exhaust pressure and gross generation.

Gas Turbine thermal kit correction curves are incorporated as Schedules for correction to the ISO (59°F) conditions from the test measured conditions:

- o The gas turbine heat rate vs. inlet temperature.
- o The gas turbine MW output vs. inlet temperature.
- o The gas turbine air flow vs. inlet temperature.
- o The gas turbine exhaust temperature vs. inlet temperature.

The above corrections are made utilizing Operational Variables and Operations. Additionally a correction for altitude is implemented.

The Replacement Features and the Special Input /Output capabilities of PEPSE are utilized to enter data and obtain outputs for each GT, HRSG, and the Steam Turbine, Condenser, Pumps and other model equipment. The corrected outputs are then printed for easy identification with the proper labels to make the report writing easier and less time consuming.

The stack leakage is greatly influenced by the stack temperature, feedwater and steam temperature, and indicated steam flow in addition to the calculated flue gas flow.

The PEPSE model of the Combined Cycle T. H. Wharton Unit 4 is shown in Figure 1. The body of this paper incorporates the PEPSE model as developed for Combined Cycle Performance Analysis.

COMBINED CYCLE MODEL  
4 GT'S, 4 HRSG'S PLUS 1 STEAM TURBINE




Figure 1. PEPSE™ Configuration.

LISTII: F INPUT DATA FOR CASE 1

```

*****
** GE STAG          COMBINED CYCLE MODEL          **
**                8/27/92                        **
*****
** This is a base model of four gas turbines, four
** heat recovery boilers (HRSG), one steam
** non-reheat turbine and one condenser.
*****
* CYCLE FLAG
010200 2 0 5 1 0
* MAX ITERATIONS
012000 35
* SUPPRESSION TABLE
* GEOMETRY
020001 NOPR
020002 NOPR
020004 NOPR
020013 NOPR
020015 NOPR
020019 NOPR
020034 NOPR
* SECOND LAW
020021 NOPR
020022 NOPR
020023 NOPR
020024
020039
*****
* FIRST GT UNIT
500010 11 U 801
500050 801 I 601 I
500090 601 U 501 IA
500130 501 U 511 IA
500170 511 U 811 I
500210 811 U 521 IA
500250 521 U 821 I
500290 821 U 611 I
500330 611 U 211 S
500370 211 D 531 IA
500410 531 U 41 I
501010 21 U 501 IF
501110 31 U 511 IB
500510 601 B 521 IB
500610 611 B 531 IB
** SECOND GT UNIT
500020 12 U 802 I
500060 802 U 602 I
500100 602 U 502 IA
500140 502 U 512 IA
500180 512 U 812 I
500220 812 U 522 IA
500260 522 U 822 I
500300 822 U 612 I
500340 612 U 212 S
500380 212 D 532 IA
500420 532 U 42 I
501020 22 U 502 IF
501120 32 U 512 IB
500520 602 B 522 IB
500620 612 B 532 IB
** THIRD GT UNIT
500030 13 U 803 I
500070 803 U 603 I
*****

```

500110	607	U	503	IA
500150	505	U	513	IA
500190	513	U	813	I
500230	813	U	523	IA
500270	523	U	823	I
500310	823	U	613	I
500350	613	U	213	S
500390	213	D	533	IA
500430	533	U	43	I
501030	23	U	503	IF
501130	33	U	513	IB
500530	603	B	523	IB
500630	613	B	533	IB
**	FOURTH GT UNIT			FOUR
500040	14	U	804	I
500080	804	U	604	I
500120	604	U	504	IA
500160	504	U	514	IA
500200	514	U	814	I
500240	814	U	524	IA
500280	524	U	824	I
500320	824	U	614	I
500360	614	U	214	S
500400	214	D	534	IA
500440	534	U	44	I
501040	24	U	504	IF
501140	34	U	514	IB
500540	604	B	524	IB
500640	614	B	534	IB
*	FEEDWATER			
502010	200	D	401	I
502020	401	U	201	T
502030	201	T	402	I
502040	402	U	631	I
502050	631	B	632	I
502060	631	U	633	I
502110	632	U	211	T
502120	632	B	212	T
502130	633	B	213	T
502140	633	U	214	T
*	STEAM FROM HRSG			
502150	211	T	541	IA
502520	212	T	541	IB
502550	541	U	543	IA
502530	213	T	542	IA
502540	214	T	542	IB
502560	542	U	543	IB
502570	543	U	641	I
*				
502580	641	U	100	I
502590	100	U	649	I
502600	649	U	101	I
502620	101	U	200	S
*	EXTRACTION			
502630	641	B	549	IA
502640	549	U	644	I
502650	649	B	549	IB
502660	644	U	201	S
502670	644	B	551	IB
502680	201	D	551	IA
502690	551	U	200	D
*	CW			
502410	50	U	200	T
502420	200	T	51	I
*				

\*\*\*\*\*





```

* CONTROL : T AIR FLOW TO COMPRESSOR TO ACHIEVE GOAL TURBINE OUTLET MP
*
840100 WTVSC 11 981.57 0.0 1.0 TT -29
* TURB EXH. T.
* CONTROL TURBINE EFF. TO PRODUCE DESIRED LOAD - MW
840200 EFFTRE 821 50.699 0.0 1.0 BKGRO 1
* CONTROL COMP. EFF. TO OBTAIN COMP. OUT TEMP.
840300 EFFPMP 801 593.33 0.0001 1.0 TT -5
* CONTROL BYPASS LEAK TO OBTAIN STACK TEMP
840400 FRSPPL 611 360. 0.0 1.0 TT -37
***** FINISHED DATA ENTRY FOR GT ONE *****
*
* COMPONENTS:
* SECOND GT UNIT ----- TWO -----
* T amb P amb (at inlet plenum) AIR FLOW GUESS
700120 31 82.9 14.718 1900000.
700122 0 1
* REL HUM
700123 AIR 0.63
* COMPRESSOR OUTLET P. EFF. GUESS
708020 44 2 129.72 1.0 .89
* COMPRESSOR AIR TO GT INTERSTAGE COOLING @ 2%
706020 63 0.0 0.019999
* COMBUSTOR EXCESS AIR?
705020 70 0 2 0 0.0
* NOX SPRAY MIXER
705120 50
* FIRST SECTION EXPANDER WITH ASSUMED EFFICIENCY & EXH. P.
708120 09 2 0 1 1
* ASSUMED EFF. ASSUMED EXH. P.
708121 0.850001 87.0001
* INTERSTATE COOLING MIXER
705220 50
* MAIN SECTION EXPANDER WITH EFF. GUESS & MEAS. EXH. P.
708220 09 2 3 1 1
* EFF. GUESS MEASURED EXH. P.
708221 0.85 15.31116
* EXHAUST BYPASS DAMPER LEAKAGE GUESS
706120 63 0.0 0.10
* CONVECTIVE STAGE -- HRSG
* STM FLOW FW P. FW IN T. STM OUT T.
702120 28 2 230000. 814.7 108. 840. 0.0 0.0 0.0 0.0
* STM OUT P. STACK P.
702123 0.0 774.7 0.0 14.7
* MIXER TO ATMO.
705320 50
* FUEL SOURCE T-FUEL P-FUEL MASS FLOW
700220 31 65.0 14.7 32630.20
700222 0 1
* FUEL SPEC. HHV
700223 FUEL 22621. SSVL 0.0 C .7268 H2 .2375 O2 .0305 N2 .00513
* NOX SPRAY SOURCE T P MASS FLOW
700320 31 79. 250. 11008.8
700322 0 1
* ATMOSPHERE
700420 30
*
*** ADD CONTROLS ---- SECOND GT + + + + +
* CONTROL INLET AIR FLOW TO COMPRESSOR TO ACHIEVE GOAL TURBINE OUTLET TEMP
* TURB EXH. T.
840500 WTVSC 12 978.417 0.0 1.0 TT -30
* CONTROL TURBINE EFF. TO PRODUCE DESIRED LOAD - MW
840600 EFFTRE 822 52.2469 0.0 1.0 BKGRO 2
* CONTROL COMP. EFF. TO OBTAIN COMP. OUT TEMP.
840700 EFFPMP 802 602.5 0.0001 1.0 TT -6
* CONTROL BYPASS LEAK TO OBTAIN STACK TEMP
840800 FRSPPL 612 360. 0.0 1.0 TT -38

```

```

***** FINISHED DATA ENTRY FOR GT TWO *****
* COP. ENT
* THIRD GT UNIT ----- THREE -----
* T amb P amb (at inlet plenum) AIR FLOW GUESS
700130 31 82.9 14.666 1900000.
700132 0 1
* REL HUM
700133 AIR 0.63
* COMPRESSOR OUTLET P. EFF. GUESS
708030 44 3 127.804 1.0 .89
* COMPRESSOR AIR TO GT INTERSTAGE COOLING @ 2%
706030 63 0.0 0.019999
* COMBUSTOR EXCESS AIR?
705030 70 0 2 0 0.0
* NOX SPRAY MIXER
705130 50
* FIRST SECTION EXPANDER WITH ASSUMED EFFICIENCY & EXH. P.
708130 09 3 0 1 1
* ASSUMED EFF. ASSUMED EXH. P.
708131 0.850001 87.0001
* INTERSTATE COOLING MIXER
705230 50
* MAIN SECTION EXPANDER WITH EFF. GUESS & MEAS. EXH. P.
708230 09 3 3 1 1
* EFF. GUESS MEASURED EXH. P.
708231 0.85 15.345
* EXHAUST BYPASS DAMPER LEAKAGE GUESS
706130 63 0.0 0.10
* CONVECTIVE STAGE -- HRSG
702130 28 2 230000. 814.7 120. 890. 0.0 0.0 0.0 0.0 0.0
* STM FLOW FW P. FW IN T. STM OUT T.
* STM OUT P. STACK P.
702133 0.0 774.7 0.0 14.7
* MIXER TO ATMOS.
705330 50
* FUEL SOURCE T-FUEL P-FUEL MASS FLOW
700230 31 65.0 14.7 31593.2
700232 0 1
* FUEL SPEC. HHV
700233 FUEL 22621. SSVL 0.0 C .7268 H2 .2375 O2 .0305 N2 .00513
* NOX SPRAY SOURCE T P MASS FLOW
700330 31 79. 250. 12009.6
700332 0 1
* ATMOSPHERE
700430 30
*
*** ADD CONTROLS -- THIRD GT + + + + +
* CONTROL INLET AIR FLOW TO COMPRESSOR TO ACHIEVE GOAL TURBINE OUTLET TEMP
* TURB EXH.
840900 MWVSC 13 977.5 0.0 1.0 TT -31
* CONTROL TURBINE EFF. TO PRODUCE DESIRED LOAD - MW
841000 EFFTRE 823
* CONTROL COMP. EFF. TO OBTAIN COMP. OUT TEMP.
841100 EFFPMP 803 602. 0.0001 1.0 TT -7
* CONTROL BYPASS LEAK TO OBTAIN STACK TEMP
841200 FRSPPL 613 370. 0.0 1.0 TT -39
***** FINISHED DATA ENTRY FOR GT THREE *****
* COMPONENT
* FOURTH GT UNIT ----- FOUR -----
* T amb P amb (at inlet plenum) AIR FLOW GUESS
700140 31 82.9 14.666 1900000.
700142 0 1
* REL HUM
700143 AIR 0.63
* COMPRESSOR OUTLET P. EFF. GUESS

```

```

708040 44 129.954 1.0 .89
* COMPRESS AIR TO GT INTERSTAGE COOLING @ 2%
706040 63 0.0 0.019999
* COMBUSTOR EXCESS AIR?
705040 70 0 2 0 0.0
* NOX SPRAY MIXER
705140 50
* FIRST SECTION EXPANDER WITH ASSUMED EFFICIENCY & EXH. P.
708140 09 4 0 1 1
* ASSUMED EFF. ASSUMED EXH. P.
708141 0.850001 87.0001
* INTERSTATE COOLING MIXER
705240 50
* MAIN SECTION EXPANDER WITH EFF. GUESS & MEAS. EXH. P.
708240 09 4 3 1 1
* EFF. GUESS MEASURED EXH. P.
708241 0.85 15.331
* EXHAUST BYPASS DAMPER LEAKAGE GUESS
706140 63 0.0 0.10
* CONVECTIVE STAGE -- HRSG
702140 28 2 230000. 794.7 122. 890. 0.0 0.0 0.0 0.0
* STM FLOW FW P. FW IN T. STM OUT T.
702143 0.0 754.7 0.0 14.7
* STM OUT P. STACK P.
* MIXER TO ATM
705340 50
* FUEL SOURCE T-FUEL P-FUEL MASS FLOW
700240 31 65.0 14.7 31964.5
700242 0 1
* FUEL SPEC. MHV
700243 FUEL 22621. SSVL 0.0 C .7268 H2 .2375 O2 .0305 N2 .00513
* NOX SPRAY SOURCE T P MASS FLOW
700340 31 79. 250. 10008.0
700342 0 1
* ATMOSPHERE
700440 30
*** ADD CONTROLS --- FOURTH GT + + + +
* CONTROL INLET AIR FLOW TO COMPRESSOR TO ACHIEVE GOAL TURBINE OUTLET TEMP
* TURB EXH.
841300 WVVSC 14 971.62 0.0 1.0 TT -32
* CONTROL TURBINE EFF. TO PRODUCE DESIRED LOAD - MW
841400 EFFTRE 824 52.2317 0.0 1.0 BKGRO 4
* CONTROL COMP. EFF. TO OBTAIN COMP. OUT TEMP.
841500 EFFPMP 804 600.5 0.0001 1.0 TT -8
* CONTROL BYPASS LEAK TO OBTAIN STACK TEMP
841600 FRSPPL 614 360. 0.0 1.0 TT -40
***** FINISHED DATA ENTRY FOR GT FOUR *****
* COMPONENT *****
* STEAM CYCLE *
* STEAM TURBINE *
*****
* TRY ENVELOP - ENVEL 2 FOR STEAM TURBINE AND ENVEL 1 FOR GTs.
602570 6 1 2 860. 755. 840000.
602040 6 2 1 121. 1220. 840000.
* STEAM TURBINE
011050 5 2 1 0 3600 133000. 0.85 30. 102476.000
* HP SECTION MODEL (GENERAL TURBINE)
* EXP. LINE CURVE
*** CARD ABOVE IS A REPLACEMENT CARD. ***
701000 08 5 0 0 5 0 1 5 0.0
* ASSUME CROSS-OVER P & H
701005 103.00 & 1234.000

```

\* LP TION MODEL (GENERAL TURBINE)  
 701010 08 3 0 4 0 2 5 0.0 0.0 32.9  
 \* EXP. LINE CURVE  
 \* 701018 3  
 \* LAST STAGE -- P & ENTHALPY  
 701015 1.584 1010.000  
 \* CONDENSER  
 702000 10 1 2 0.0 1.5832  
 \*  
 700500 33 80.97 44.2 3.333E7  
 700502 0 2  
 700510 32  
 \* CONDENSER OUTLET TEMP CONTROL  
 842200 WTVSC 50 107.67 -- 1.0 TT -242  
 \* CONDENSER PUMP  
 704010 41 114.7 .95 1.0 0.8  
 \*  
 704020 41 1244.7 .95 1.0 0.85  
 \* FIRST FW SPLITTER TO UNIT TWO  
 706310 63 0.0 0.5  
 \* SECOND FW SPLITTER TO UNIT ONE AND UNIT TWO  
 706320 63 0.0 0.5  
 \* THIRD FW SPLITTER TO UNIT THREE AND UNIT FOUR  
 706330 63 0.0 0.5  
 \* STEAM MIXER FOR HRSG ONE AND TWO  
 705410 50  
 \* STEAM MIXER FOR HRSG THREE AND FOUR  
 705420 50  
 \* TOTAL MAIN STEAM MIXER TO TURBINE  
 705430 50  
 \* STEM LEAK OFF SET FLOW  
 706410 61 0.0 582.0  
 \* GLAND STEAM LEAK OFF SET FLOW  
 706490 61 0.0 3219.0  
 \* STEM SEAL REGULATOR  
 705490 50  
 \* SPLITTER TO G.S.C. SET FLOW  
 706440 61 0.0 2401.0  
 \* G.S.C.  
 702010 10 0 2 0.0 2.0  
 \* MIXER FOR DRAINS TO CONDENSER  
 705510 50  
 \* SWING WHOLE STEAM TURBINE  
 850000 2  
 850002 100  
 \*  
 ----- ADD SCHEDULES FOR ISO DESIGN PARAMETERS VS. INLET TEMP -----\*  
 801100 'GT HEAT RATE VS. INLET TEMP.'  
 811100 40. 45. 50. 55. 59. 65. 70. 75. 80. 85. 90.  
 811110 0.0 .982 .988 .992 .997 1.0 1.0055 1.01 1.015 1.02 1.026 1.032  
 830100 11 OPVB 11 TT 1  
 830200 11 OPVB 21 TT 2  
 830300 11 OPVB 31 TT 3  
 830400 11 OPVB 41 TT 4  
 \*  
 801200 'GT OUTPUT VS. INLET TEMP.'  
 811200 40. 50. 59. 70. 80. 90. 100.  
 811210 0. 1.075 1.036 1.0 0.96 0.922 0.885 0.848  
 831100 12 OPVB 12 TT 1  
 831200 12 OPVB 22 TT 2  
 831300 12 OPVB 32 TT 3  
 831400 12 OPVB 42 TT 4  
 \*  
 801300 'GT AIR FLOW VS. INLET TEMP.'  
 811300 40. 50. 59. 70. 80. 90. 100.  
 811310 0. 1.04 1.02 1.0 0.979 0.958 0.937 0.917



880240	BK	2	DIV	OPVB	22	OPVB	28
881240	OP	28	DIV	OPVB	90	OPVB	28
890251		OPVB	28				
890260	'SECOND GT CORR. ISO AIR FLOW, LB/HR'						
880250	WV	2	DIV	OPVB	23	OPVB	29
890261		OPVB	29				
890270	'SECOND GT CORR. ISO EXHAUST TEMP., DEGF'						
890271		OPVB	24				
890280	'2ND GT COMPRESSOR EFFICIENCY'						
890281	EFFPMP	802					
890290	'2ND GT OVERALL EXPANDER EFFICIENCY'						
890291	EFFSEC	822					
890200	'2ND GT COMPRESSOR CALC. AIR FLOW, ACFM'						
880270	WV	-2	DIV	OPVB	5	OPVB	20
890201		OPVB	20				
*							
	-----	THIRD GT	-----	THIRD GT			
890310	'THIRD GT TEST HEAT INPUT, BTU/HR'						
890311	QFLHV	503					
890320	'THIRD GT TEST GROSS GENERATION, MW'						
890321	BKGRO	3					
890330	'THIRD GT TEST GROSS HEAT RATE, BTU/KWH'						
890331	OPVB	36					
880320	QFLHV	503	DIV	BKGRO	3	OPVB	36
881320	OPVB	36	DIV	OPVB	99	OPVB	36
*	-----	THIRD GT CORRECTIONS	-----				
890340	'THIRD GT CORR. ISO GROSS HEAT RATE'						
881330	OPVB	36	DIV	OPVB	31	OPVB	37
890341		OPVB	37				
890350	'THIRD GT CORR. ISO GROSS GENERATION'						
880340	BKGRO	3	DIV	OPVB	32	OPVB	38
881340	OPVB	38	DIV	OPVB	90	OPVB	38
890351		OPVB	38				
890360	'THIRD GT CORR. ISO AIR FLOW, LB/HR'						
880350	WV	3	DIV	OPVB	33	OPVB	39
890361		OPVB	39				
890370	'THIRD GT CORR. ISO EXHAUST TEMP., DEGF'						
890371		OPVB	34				
890380	'3RD GT COMPRESSOR EFFICIENCY'						
890381	EFFPMP	803					
890390	'3RD GT OVERALL EXPANDER EFFICIENCY'						
890391	EFFSEC	823					
890300	'3RD GT COMPRESSOR CALC. AIR FLOW, ACFM'						
880370	WV	-3	DIV	OPVB	5	OPVB	30
890301		OPVB	30				
*							
	-----	FOURTH GT	-----	FOURTH GT			
890410	'FOURTH GT TEST HEAT INPUT, BTU/HR'						
890411	QFLHV	504					
890420	'FOURTH GT TEST GROSS GENERATION, MW'						
890421	BKGRO	4					
890430	'FOURTH GT TEST GROSS HEAT RATE, BTU/KWH'						
890431	OPVB	46					
880420	QFLHV	504	DIV	BKGRO	4	OPVB	46
881420	OPVB	46	DIV	OPVB	99	OPVB	46
*	-----	FOURTH GT CORRECTIONS	-----				
890440	'FOURTH GT CORR. ISO GROSS HEAT RATE'						
881430	OPVB	46	DIV	OPVB	41	OPVB	47
890441		OPVB	47				
890450	'FOURTH GT CORR. ISO GROSS GENERATION'						
880440	BKGRO	4	DIV	OPVB	42	OPVB	48
881440	OPVB	48	DIV	OPVB	90	OPVB	48
890451		OPVB	48				
890460	'FOURTH GT CORR. ISO AIR FLOW, LB/HR'						
880450	WV	4	DIV	OPVB	43	OPVB	49

890461		OPVB	49						
890470	'FL	.H GT CORR. ISO EXHAUST TEMP., DEGF'							
890471		OPVB	44						
890480	'4TH GT COMPRESSOR EFFICIENCY'								
890481	EFFPMP	804							
890490	'4TH GT OVERALL EXPANDER EFFICIENCY'								
890491	EFSECC	824							
890400	'4TH GT COMPRESSOR CALC. AIR FLOW, ACFM'								
880470	WV	-4	DIV	OPVB	5	OPVB	40		
890401	OPVB	40							
*	---	UNIT PARAMETERS	---	---	---	---	---	---	---
890700	'SIMPLE CYCLE GROSS GENERATION, MW'								
880700	BKGRO	1	ADD	BKGRO	2	OPVB	70		
880710	BKGRO	3	ADD	OPVB	70	OPVB	70		
880720	BKGRO	4	ADD	OPVB	70	OPVB	70		
890701	OPVB	70							
*									
890710	'STEAM TURBINE GROSS GENERATION, KW'								
890711	POWER	5							
*									
890720	'UNIT AUXILIARY LOAD, MW'								
870710	3.993								
890721	OPVB	71							
*									
890730	'COMBINED CYCLE GROSS GENERATION, MW'								
880730	POWER	5	DIV	OPVB	99	OPVB	95		
881730	OPVB	95	ADD	OPVB	70	OPVB	72		
890731	OPVB	72							
*									
890740	'COMBINED CYCLE NET GENERATION, MW'								
880740	OPVB	72	SUB	OPVB	71	OPVB	73		
890741	OPVB	73							
*									
890750	'TOTAL UNIT HEAT INPUT, BTU/HR'								
880750	QFLHHV	501	ADD	QFLHHV	502	OPVB	74		
880760	QFLHHV	503	ADD	OPVB	74	OPVB	74		
880770	QFLHHV	504	ADD	OPVB	74	OPVB	74		
890751	OPVB	74							
*									
890760	'GROSS UNIT HEAT RATE, BTU/KWH'								
880780	OPVB	74	DIV	OPVB	72	OPVB	75		
881780	OPVB	75	DIV	OPVB	99	OPVB	75		
890761	OPVB	75							
*									
890770	'NET UNIT HEAT RATE, BTU/KWH'								
880790	OPVB	74	DIV	OPVB	73	OPVB	76		
881790	OPVB	76	DIV	OPVB	99	OPVB	76		
890771	OPVB	76							
*									
890780	'GROSS STEAM TURBINE HEAT RATE, BTU/KWH'								
880800	HH	-257	SUB	HH	-204	OPVB	77		
880810	WV	204	MUL	OPVB	77	OPVB	77		
880820	OPVB	77	DIV	POWER	5	OPVB	77		
890781	OPVB	77							
*									
890790	'STEAM TURBINE EFFICIENCY'								
890791	EFFSEC	101							
*									
891410	HRSG EFFECTIVENESS								
891411	'1ST HRSG EFFECTIVENESS'								
891420	EFFHX	211							
891421	'2ND HRSG EFFECTIVENESS'								
891422	EFFHX	212							
891430	'3RD HRSG EFFECTIVENESS'								
891431	EFFHX	213							
891440	'4TH HRSG EFFECTIVENESS'								





```

708110 09 0 1 1
* ASSUMED EFF. ASSUMED P.
708111 0.850001 87.0001
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* INTERSTAGE COOLING MIXER
705210 50
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* MAIN SECTION EXPANDER WITH EFF. GUESS & MEAS. EXH. P.
708210 09 1 3 1 1
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* EFF. GUESS MEASURED EXH. P.
708211 0.85 15.242
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* EXHAUST BYPASS DAMPER LEAKAGE GUESS
706110 63 0.0 0.10
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* CONNECTIVE STAGE -- HRSG
* STM FLOW FW P. FW IN T. STM OUT T.
702110 28 2 210000. 783.68 124.5 867. 0.0 0.0 0.0 0.0
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* STM OUT P. STACK P.
702113 0.0 754.68 0.0 14.7
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* MIXER TO ATHO.
705310 50
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* FUEL SOURCE T-FUEL P-FUEL MASS FLOW
700210 31 65.0 14.7 31828.9
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* FUEL SPEC. HHV
700213 FUEL 22470. SSVL 0.0 C .72558 H2 .23503 O2 .0362 N2 .0032
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* NOX SPRAY SOURCE T P MASS FLOW
700310 31 86.6 250. 8707.
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* ATMOSPHERE
700410 30
*** CARD ABOVE IS A REPLACEMENT CARD. ***

*** ADD CONTROLS ---- FIRST GT + + + + +
* CONTROL INLET AIR FLOW TO COMPRESSOR TO ACHIEVE GOAL TURBINE OUTLET TEMP
* TURB EXH. T.
840100 WNVSC 11 982.4 0.0 1.0 TT -29
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* CONTROL TURBINE EFF. TO PRODUCE DESIRED LOAD - MW
840200 EFFTRE 821 51.5564 0.0001 1.0 BKGR0 1
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* CONTROL COMP. EFF. TO OBTAIN
* COMP. OUT TEMP.
840300 EFFPMP 801 616.2 0.0001 1.0 TT -5
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* CONTROL BYPASS LEAK TO OBTAIN
* STACK TEMP
840400 FRSPPL 611 341.5 0.0 1.0 TT -37
*** CARD ABOVE IS A REPLACEMENT CARD. ***

** ADD CONTROL LIMITS MIN. MAX.
840409 0.00 0.33333
***** FINISHED DATA ENTRY FOR GT ONE *****

* COMPONENTS:
* SECOND GT UNIT ----- TWO -----
* T amb P amb (at inlet plenum) AIR FLOW GUESS
700120 31 90.2 14.58 1900000.
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* REL HUM
700123 AIR 0.54
*** CARD ABOVE IS A REPLACEMENT CARD. ***

```

```

* COMPRES:      OUTLET P.      EFF. GUESS      *
708020 44      128.88      1.0      .89      *
* COMPRESSOR AIR TO GT INTERSTAGE COOLING @ 2%      *
706020 63 0.0 0.019999      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* COMBUSTOR      EXCESS AIR?      *
705020 70 0 2 0 0.0      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* NOX SPRAY MIXER      *
705120 50      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* FIRST SECTION EXPANDER WITH ASSUMED EFFICIENCY & EXH. P.      *
708120 09 2 0 1 1      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* ASSUMED EFF.      ASSUMED EXH. P.      *
708121 0.850001      87.0001      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* INTERSTATE COOLING MIXER      *
705220 50      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* MAIN SECTION EXPANDER WITH EFF. GUESS & MEAS. EXH. P.      *
708220 09 2 3 1 1      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* EFF. GUESS      MEASURED EXH. P.      *
708221 0.85      15.189      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* EXHAUST BYPASS DAMPER      LEAKAGE GUESS      *
706120 63 0.0      0.10      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONVECTIVE STAGE -- HRSG      *
* STM FLOW      FW P.      FW IN T.      STM OUT T.      *
702120 28 2 21000.      794.68      124.5      867.      0.0      0.0      0.0      0.0
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* STM OUT P.      STACK P.      *
702123 0.0      734.68      0.0      14.7      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* MIXER TO ATMO.      *
705320 50      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* FUEL SOURCE      T-FUEL      P-FUEL      MASS FLOW      *
700220 31      65.0      14.7      31370.8      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* FUEL SPEC.      HHV      *
700223 FUEL      22470.      SSVL      0.0      C      .72558      H2      .23502      O2      .0362      N2      .0032
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* NOX SPRAY SOURCE      T      P      MASS FLOW      *
700320 31      86.6      250.      9908.      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* ATMOSPHERE      *
700420 30      *
*** CARD ABOVE IS A REPLACEMENT CARD. ***
*
*** ADD CONTROLS ----- SECOND GT      +      +      +      +
* CONTROL INLET AIR FLOW TO COMPRESSOR TO ACHIEVE GOAL TURBINE OUTLET TEMP
840500 MWVSC 12      974.1      0.0      1.0      TT      -30
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONTROL TURBINE EFF. TO PRODUCE DESIRED LOAD - MW      *
840600 EFFPRE 822      51.1495      0.00001      1.0      BKGR0      2
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONTROL COMP. EFF. TO OBTAIN      *
840700 EFFPMP 802      615.5      0.0001      1.0      TT      -6
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONTROL BYPASS LEAK TO OBTAIN      *
STACK TEMP

```

840800 FRF 612 344.5 0.0 1.0 TT -38  
 \*\*\* CARD ABOVE IS A REPLACEMENT RD. \*\*\*  
 \*\* ADD CONTROL LIMITS MIN. MAX.  
 840809 0.00 0.33333  
 \*\*\*\*\* FINISHED DATA ENTRY FOR GT TWO \*\*\*\*\*  
 \* COMPONENT \*  
 \* THIRD GT UNIT ----- THREE ----- \*  
 \* T amb P amb (at inlet plenum) AIR FLOW GUESS \*  
 700130 31 90.2 14.586 190000.  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* REL HUM \*  
 700133 AIR 0.54  
 \* COMPRESSOR OUTLET P. EFF. GUESS \*  
 708030 44 3 132.68 1.0 .89  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* COMPRESSOR AIR TO GT INTERSTAGE COOLING @ 2 \*  
 706030 63 0.0 0.019999  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* COMBUSTOR EXCESS AIR? \*  
 705030 70 0 2 0 0.0  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* NOX SPRAY MIXER \*  
 705130 50  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* FIRST SECTION EXPANDER WITH ASSUMED EFFICIENCY & EXH. P. \*  
 708130 09 3 0 1 1  
 \* ASSUMED EFF. ASSUMED EXH. P. \*  
 708131 0.850001 87.0001  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* INTERSTATE COOLING MIXER \*  
 705230 50  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* MAIN SECTION EXPANDER WITH EFF. GUESS & MEAS. EXH. P. \*  
 708230 09 3 3 1 1  
 \* EFF. GUESS MEASURED EXH. P. \*  
 708231 0.85 15.171  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* EXHAUST BYPASS DAMPER LEAKAGE GUESS \*  
 706130 63 0.0 0.10  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* CONVECTIVE STAGE -- HRSG \*  
 \* STM FLOW FW P. FW IN T. STM OUT T. \*  
 702130 28 2 210000. 814.68 124.5 867. 0.0 0.0 0.0 0.0  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* STM OUT P. STACK P. \*  
 702133 0.0 754.68 0.0 14.7  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* MIXER TO ATRO. \*  
 705330 50  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* FUEL SOURCE T-FUEL P-FUEL MASS FLOW \*  
 700230 31 65.0 14.7 31560.4  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* FUEL SPEC. HHV \*  
 700233 FUEL. 22470. SSVL 0.0 C .72558 H2 .23503 O2 .0362 N2 .0032  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* NOX SPRAY SOURCE T P MASS FLOW \*  
 700330 31 86.6 250. 10508.  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*  
 \* ATMOSPHERE \*  
 700430 30  
 \*\*\* CARD ABOVE IS A REPLACEMENT CARD. \*\*\*

```

* FUEL SOL      T-FUEL P-FUEL MASS FLOW      RD. ***
700240 31      65.0 14.7      32065.8
* FUEL SPEC.    HHV
700243 FUEL 22470. SSVL 0.0 C .72558 H2 .23503 O2 .0362 N2 .0032
* NOX SPRAY SOURCE T P MASS FLOW
700340 31      86.6 250. 9458.0
* ATMOSPHERE
700440 30

*** CARD ABOVE IS A REPLACEMENT CARD. ***

*** ADD CONTROLS ----- FOURTH GT + + + + +
* CONTROL INLET AIR FLOW TO COMPRESSOR TO ACHIEVE GOAL TURBINE OUTLET TEMP
* TURB EXH. T.
841300 MWVSC 14 975.9 0.0 1.0 TT -32
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONTROL TURBINE EFF. TO PRODUCE DESIRED LOAD - MW
841400 EFFTRE 824 52.3901 0.00001 1.0 BKGRO 4
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONTROL COMP. EFF. TO OBTAIN
841500 EFFPMP 804 617.7 0.0001 1.0 TT -8
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONTROL BYPASS LEAK TO OBTAIN
841600 FRSPPL 614 343.5 0.0 1.0 TT -40
*** CARD ABOVE IS A REPLACEMENT CARD. ***

** ADD CONTROL LIMITS MIN. MAX. **
841609 0.00 0.33333
***** FINISHED DATA ENTRY FOR GT FOUR *****
* COMPONENT
* STEAM CYCLE STEAM CYCLE * * *
* STEAM TURBINE TEST DATA ENTRY * * *
*****
* STEAM TURBINE GROSS GEN. KW *
011050 5 2 1 0 3600 133000. 0.85 30. 30. 102463.000
*** CARD ABOVE IS A REPLACEMENT CARD. ***
* UNIT AUX LOAD MW*
870710 3.901

*** CARD ABOVE IS A REPLACEMENT CARD. ***

* HP SECTION MODEL (GENERAL TURBINE)
701000 08 5 0 0 5 0 1 5 0.0
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* EXP. LINE CURVE
*701008 3
* ASSUME CROSS-OVER P & H 1234.000
701005 103.00

* LP SECTION MODEL (GENERAL TURBINE)
701010 08 5 3 0 4 0 2 5 0.0 0.0 32.9
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* EXP. LINE CURVE NUMBER
*701018 3
* LAST STAGE -- P & ENTHALPY
701015 1.9 1010.000
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* CONDENSER
702000 10 1 2 0.0 1.8901
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* CW IN T. CW IN P. CW FLOW GUESS
700500 33 87.35 49.58 3.333E7
*** CARD ABOVE IS A REPLACEMENT CARD. ***

700510 32

```

```

* ** ADD CON .LS ----- THIRD GT + + + + +
* CONTROL INLET AIR FLOW TO COMPRESSOR TO ACHIEVE GOAL TURBINE OUTLET TEMP
* TURB EXH. T.
840900 WWSVC 13 974.0 0.0 1.0 TT -31
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONTROL TURBINE EFF. TO PRODUCE DESIRED LOAD - MW
841000 EFFTRE 823 50.8359 0.00001 1.0 BKGR0 3
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONTROL COMP. EFF. TO OBTAIN
841100 EFFPMP 803 620. 0.00001 1.0 TT -7
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONTROL BYPASS LEAK TO OBTAIN
841200 FRSPPL 613 340. 0.0 1.0 TT -39
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
** ADD CONTROL LIMITS MIN. MAX.
841209 0.00 0.33333
* ** **
* ** FINISHED DATA ENTRY FOR GT THREE *
* COMPONENT *
* FOURTH GT UNIT ----- FOUR ----- *
* T amb P amb (at inlet plenum) AIR FLOW GUESS *
700140 31 90.2 14.58 190000.
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* REL HUM
700143 AIR 0.54
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* COMPRESSOR OUTLET P. EFF. GUESS
708040 44 4 127.48 1.0 .89
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* COMPRESSOR AIR TO GT INTERSTAGE COOLING @ 2%
706040 63 0.0 0.019999
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* COMBUSTOR EXCESS AIR?
705040 70 0 2 0 0.0
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* NOX SPRAY MIXER
705140 50
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* FIRST SECTION EXPANDER WITH ASSUMED EFFICIENCY & EXH. P.
708140 09 4 0 1 1
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* ASSUMED EFF. ASSUMED EXH. P.
708141 0.850001 87.0001
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* INTERSTATE COOLING MIXER
705240 50
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* MAIN SECTION EXPANDER WITH EFF. GUESS & MEAS. EXH. P.
708240 09 4 3 1 1
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* EFF. GUESS MEASURED EXH. P.
708241 0.85 15.1745
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* EXHAUST BYPASS DAMPER LEAKAGE GUESS
706140 63 0.0 0.10
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* CONVECTIVE STAGE -- HRSG
* STM FLOW FW P. FW IN T. STM OUT T.
702140 28 2 210000. 794.68 124.5 867. 0.0 0.0 0.0 0.0
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* STM OUT P. STACK P.
702143 0.0 754.68 0.0 14.7
* ** CARD ABOVE IS A REPLACEMENT CARD. ***
* MIXER TO ATM0
705340 50

```

OT ADD TO A VALUE OF 1.0 FOR COMPONENT WITH  
.SER ID = 23. THE SUM IS 1.00001E+00. THE  
MATERIAL MASS FRACTIONS HAVE BEEN NORMALIZED TO  
YIELD A SUM OF 1.0.

\*\*\* WARNING FROM READ03 ROUTINE \*\*\*  
THE INPUT VALUES OF MATERIAL MASS FRACTIONS DO  
NOT ADD TO A VALUE OF 1.0 FOR COMPONENT WITH  
USER ID = 24. THE SUM IS 1.00001E+00. THE  
MATERIAL MASS FRACTIONS HAVE BEEN NORMALIZED TO  
YIELD A SUM OF 1.0.

```

* CONDENSEI          OUTLET TEMP CONTROL          RD. ***
842200 WVVSC 50      114.12 -- 1.0 TT -242
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* CONDENSER PUMP P. 704010 41 117.68 .95 1.0 0.8
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* BOILER FEED PUMP P. 704020 41 1274.68 .95 1.0 0.85
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* FIRST FW SPLITTER TO UNIT TWO 706310 63 0.0 0.5
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* SECOND FW SPLITTER TO UNIT ONE AND UNIT TWO 706320 63 0.0 0.5
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* THIRD FW SPLITTER TO UNIT THREE AND UNIT FOUR 706330 63 0.0 0.5
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* STEAM MIXER FOR HRSG ONE AND TWO 705410 50
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* STEAM MIXER FOR HRSG THREE AND FOUR 705420 50
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* TOTAL MAIN STEAM MIXER TO TURBINE 705430 50
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* STEM LEAK OFF 706410 61 0.0
SET FLOW 582.0
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* GLAND STEAM LEAK OFF 706490 61 0.0
SET FLOW 3219.0
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* STEM SEAL REGULATOR 705490 50
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* SPLITTER TO G.S.C. 706440 61 0.0
SET FLOW 2401.0
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* G.S.C. 702010 10 0 2 0.0 2.0
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* MIXER FOR DRAINS TO CONDENSER 705510 50
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* SWING WHOLE STEAM TURBINE 850002 100
*** CARD ABOVE IS A REPLACEMENT CARD. ***

*--*--*--*--*--* END OF TEST DATA REPLACEMENT DECK --*--*--*--*

```

```

*** WARNING FROM READ03 ROUTINE ***
THE INPUT VALUES OF MATERIAL MASS FRACTIONS DO
NOT ADD TO A VALUE OF 1.0 FOR COMPONENT WITH
USER ID = 21. THE SUM IS 1.00001E+00. THE
MATERIAL MASS FRACTIONS HAVE BEEN NORMALIZED TO
YIELD A SUM OF 1.0.

```

```

*** WARNING FROM READ03 ROUTINE ***
THE INPUT VALUES OF MATERIAL MASS FRACTIONS DO

```



PEPSE C/ BY NUS CORPORATION, IDAHO FALLS, ID.  
VERSION 1. CREATED 22 JAN 91 DATE 01-07-93. AGE 2  
THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (4CC\_6\_25\_92)

INPUT SCHEDULE NUMBER 13 TABLE OF VALUES

GT AIR FLOW VS. INLET TEMP.

UNIVARIATE TABLE OF Y VERSUS X

VALUES OF X

4.000E+01 5.000E+01 5.900E+01 7.000E+01 8.000E+01 9.000E+01 1.000E+02

VALUES OF Y

1.040E+00 1.020E+00 1.000E+00 9.790E-01 9.580E-01 9.370E-01 9.170E-01

INPUT SCHEDULE NUMBER 14 TABLE OF VALUES

GT EXHAUST TEMPERATURE VS. INLET TEMP.

UNIVARIATE TABLE OF Y VERSUS X

VALUES OF X

4.000E+01 5.000E+01 5.900E+01 7.000E+01 8.000E+01 9.000E+01 1.000E+02

VALUES OF Y

9.360E+02 9.440E+02 9.500E+02 9.560E+02 9.620E+02 9.690E+02 9.755E+02

PEPSE C/ BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 1  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stw flow, MEA stack T. (ACC\_6\_25\_92)

INPUT SCHEDULE NUMBER 11 TABLE OF VALUES

GT HEAT RATE VS. INLET TEMP.

UNIVARIATE TABLE OF Y VERSUS X

VALUES OF X

4.000E+01 4.500E+01 5.000E+01 5.500E+01 5.900E+01 6.500E+01 7.000E+01  
 7.500E+01 8.000E+01 8.500E+01 9.000E+01

VALUES OF Y

9.820E-01 9.880E-01 9.920E-01 9.970E-01 1.000E+00 1.005E+00 1.010E+00  
 1.015E+00 1.020E+00 1.026E+00 1.032E+00

INPUT SCHEDULE NUMBER 12 TABLE OF VALUES

GT OUTPUT VS. INLET TEMP.

UNIVARIATE TABLE OF Y VERSUS X

VALUES OF X

4.000E+01 5.000E+01 5.900E+01 7.000E+01 8.000E+01 9.000E+01 1.000E+02

VALUES OF Y

1.075E+00 1.036E+00 1.000E+00 9.600E-01 9.220E-01 8.850E-01 8.480E-01

14	1.0E+00	* BKGR0 ( 4)	4.2E-08	5.23901E+01	EFFTR ( 824)	YES
		5.23901E+01			8.67320E-01	
15	1.0E+00	* TT ( -8)	1.5E-05	6.17700E+02	EFFMP ( 804)	YES
		6.17691E+02			8.72017E-01	
16	1.0E+00	* TT ( -40)	4.3E-06	3.43500E+02	FRSPL ( 614)	YES
		3.43499E+02			1.51773E-01	
22	1.0E+00	* TT (-242)	-8.0E-04	1.14120E+02	MMVSC ( 50)	YES
		1.14211E+02			2.88429E+07	

PEPSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 13  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (4CC\_6\_25\_92)

CONTROLLED VARIABLE VALUES CALCULATED

CONTROL SET	Y VARIABLE/ VALUE FROM ITERATE 18	FRAC(ABS) DEVIATION FROM GOAL	Y VARIABLE GOAL VALUE	X VARIABLE/ VALUE USED AT ITERATE 18	CONVG LAST ITN X LIMITD
1	1.0E+00 * TT (-29) 9.82519E+02	-1.2E-04	9.82400E+02	WVSC ( 11) 1.88601E+06	YES
2	1.0E+00 * BKGR0 ( 1) 5.15564E+01	2.7E-10	5.15564E+01	EFFTRE ( 821) 8.52850E-01	YES
3	1.0E+00 * TT (-5) 6.16211E+02	-1.7E-05	6.16200E+02	EFFPMP ( 801) 8.86349E-01	YES
4	1.0E+00 * TT (-37) 3.41811E+02	-9.1E-04	3.41500E+02	FRSPL ( 611) 1.54108E-01	YES
5	1.0E+00 * TT (-30) 9.74234E+02	-1.4E-04	9.74100E+02	WVSC ( 12) 1.86468E+06	YES
6	1.0E+00 * BKGR0 ( 2) 5.11495E+01	1.2E-09	5.11495E+01	EFFTRE ( 822) 8.61255E-01	YES
7	1.0E+00 * TT (-6) 6.15498E+02	2.7E-06	6.15500E+02	EFFPMP ( 802) 8.81682E-01	YES
8	1.0E+00 * TT (-38) 3.44500E+02	8.7E-07	3.44500E+02	FRSPL ( 612) 1.29605E-01	YES
9	1.0E+00 * TT (-31) 9.74207E+02	-2.1E-04	9.74000E+02	WVSC ( 13) 1.88207E+06	YES
10	1.0E+00 * BKGR0 ( 3) 5.08359E+01	-7.7E-10	5.08359E+01	EFFTRE ( 823) 8.47701E-01	YES
11	1.0E+00 * TT (-7) 6.20004E+02	-6.7E-06	6.20000E+02	EFFPMP ( 803) 8.89294E-01	YES
12	1.0E+00 * TT (-39) 3.40031E+02	-9.0E-05	3.40000E+02	FRSPL ( 613) 1.44148E-01	YES
13	1.0E+00 * TT (-32) 9.76396E+02	-5.1E-04	9.75900E+02	WVSC ( 14) 1.90363E+06	YES

PEPSE C BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 5 CREATED 22 JAN 91 DATE 01-07-93. AGE 16  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED steam flow, MEA stack T. (ACC\_6\_25\_92)

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY ( - )	ENTH (B/LB)	ENTRYP (B/LB-F)	SPEC. VOLUME (FT3/LBM)
200 COND	262/S	0	836199.	124.0	1.89	0.899	1012.8	1.74919	1.65E+02
	241/T	0	28842924.	87.3	49.58	-0.210	55.5	0.10672	1.61E-02
	269/D	0	3801.	344.1	124.65	0.606	846.8	1.15645	2.19E+00
	201/D	0	840000.	124.0	1.89	0.000	92.0	0.17146	1.62E-02
242/T	0	28842924.	114.2	49.58	-0.181	82.3	0.15454	1.62E-02	
201 COND	266/S	0	1400.	517.0	124.90	1.108	1285.7	1.69145	4.54E+00
	202/T	0	840000.	124.1	117.68	-0.248	92.4	0.17162	1.62E-02
	268/D	0	1400.	126.1	2.00	0.000	94.0	0.17500	1.62E-02
	203/T	0	840000.	126.1	117.68	-0.246	94.4	0.17502	1.62E-02
211 HCNV	211/T	0	210000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
	33/S	15	1629645.	982.5	15.24	N.A.	422.5	1.90676	3.61E+01
	215/T	0	210000.	867.0	754.68	1.341	1439.1	1.63491	9.94E-01
	37/D	15	1629645.	344.8	14.70	N.A.	249.7	1.75167	2.08E+01
212 HCNV	212/T	0	210000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
	34/S	17	1658937.	974.2	15.19	N.A.	420.8	1.90570	3.60E+01
	252/T	0	210000.	867.0	734.68	1.339	1439.8	1.63831	1.02E+00
	38/D	17	1658937.	344.5	14.70	N.A.	251.0	1.75278	2.09E+01
213 HCNV	213/T	0	210000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
	35/S	19	1646779.	974.2	15.17	N.A.	420.9	1.90589	3.61E+01
	253/T	0	210000.	867.0	754.68	1.341	1439.1	1.63491	9.94E-01
	39/D	19	1646779.	340.0	14.70	N.A.	250.0	1.75145	2.08E+01
214 HCNV	214/T	0	210000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
	36/S	21	1649932.	976.4	15.17	N.A.	421.1	1.90603	3.61E+01
	254/T	0	210000.	867.0	754.68	1.341	1439.1	1.63491	9.94E-01
	40/D	21	1649932.	343.5	14.70	N.A.	250.4	1.75234	2.08E+01
401 PHEL	201/I	0	840000.	124.0	1.89	0.000	92.0	0.17146	1.62E-02
	202/U	0	840000.	124.1	117.68	-0.248	92.4	0.17162	1.62E-02
402 PHEL	203/I	0	840000.	126.1	117.68	-0.246	94.4	0.17502	1.62E-02
	204/U	0	840000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
501 COMB	9/IA	2	1848287.	616.2	130.78	N.A.	280.3	1.66932	3.09E+00
	101/IF	6	31829.	65.0	14.70	N.A.	426.9	4.05335	N.A.
	13/U	10	1880116.	1787.6	130.78	N.A.	653.9	1.88294	6.54E+00

PEPSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 5 CREATED 22 JAN 91 DATE 01-07-93. AGE 15  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED STM FLOW, MEA stack T. (4CC\_6\_25\_92)

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBH/HR)	TEMP (F)	PRESS (PSIA)	QUALITY ( - )	ENTH (B/LB)	ENTRYP (B/LB-F)	SPEC. VOLUME (FT3/LBM)
11	SRCE	1/U	2	1886006.	90.2	14.58	N.A.	149.4	1.65537 1.42E+01
12	SRCE	2/U	3	1864681.	90.2	14.58	N.A.	149.4	1.65537 1.42E+01
13	SRCE	3/U	4	1882072.	90.2	14.59	N.A.	149.4	1.65534 1.42E+01
14	SRCE	4/U	5	1903631.	90.2	14.58	N.A.	149.4	1.65537 1.42E+01
21	SRCE	101/U	6	31829.	65.0	14.70	N.A.	426.9	4.05335 N.A.
22	SRCE	102/U	7	31371.	65.0	14.70	N.A.	426.8	4.05322 N.A.
23	SRCE	103/U	8	31560.	65.0	14.70	N.A.	426.9	4.05335 N.A.
24	SRCE	104/U	9	32066.	65.0	14.70	N.A.	426.9	4.05335 N.A.
31	SRCE	111/U	0	8707.	86.6	250.00	-0.388	55.3	0.10526 1.61E-02
32	SRCE	112/U	0	9908.	86.6	250.00	-0.388	55.3	0.10526 1.61E-02
33	SRCE	113/U	0	10508.	86.6	250.00	-0.388	55.3	0.10526 1.61E-02
34	SRCE	114/U	0	9458.	86.6	250.00	-0.388	55.3	0.10526 1.61E-02
41	SINK	41/I	15	1926541.	444.9	14.83	N.A.	276.4	1.78229 2.33E+01
42	SINK	42/I	17	1905960.	429.8	14.80	N.A.	273.0	1.77831 2.29E+01
43	SINK	43/I	19	1924140.	435.5	14.81	N.A.	274.6	1.78005 2.31E+01
44	SINK	44/I	21	1945155.	443.8	14.81	N.A.	276.3	1.78218 2.33E+01
50	IPUT	241/U	0	28842924.	87.3	49.58	-0.210	55.5	0.10672 1.61E-02
51	OPUT	242/I	0	28842924.	114.2	49.58	-0.181	82.3	0.15454 1.62E-02
100	TGEN	258/I	0	839418.	867.0	749.57	1.340	1439.3	1.63576 1.00E+00
		259/U	0	839418.	458.8	103.00	1.079	1257.9	1.68281 5.16E+00
101	TGEN	260/I	0	836199.	458.8	103.00	1.079	1257.9	1.68281 5.16E+00
		262/U	0	836199.	124.0	1.89	0.899	1012.8	1.74919 1.65E+02

PEPSE C/ BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1. CREATED 22 JAN 91 DATE 01-07-93. AGE 18  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (4CC\_6\_25\_92)

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY ( - )	ENTH (B/LB)	ENTRPY (B/LB-F)	SPEC. VOLUME (FT3/LBM)
524 MIXR	24/IA	20	1907084.	1608.2	87.00	N.A.	606.5	1.88926	9.07E+00
	54/IB	5	38071.	617.7	127.48	N.A.	280.7	1.67145	3.18E+00
	28/U	21	1945155.	1590.4	87.28	N.A.	600.1	1.88628	8.96E+00
531 MIXR	37/IA	15	1629645.	341.8	14.70	N.A.	249.7	1.75167	2.08E+01
	61/IB	15	296896.	982.5	15.24	N.A.	422.5	1.90676	3.61E+01
	41/U	15	1926541.	444.9	14.83	N.A.	276.4	1.78229	2.33E+01
532 MIXR	38/IA	17	1658937.	344.5	14.70	N.A.	251.0	1.75278	2.09E+01
	62/IB	17	247023.	974.2	15.19	N.A.	420.8	1.90570	3.60E+01
	42/U	17	1905960.	429.8	14.80	N.A.	273.0	1.77831	2.29E+01
533 MIXR	39/IA	19	1646779.	340.0	14.70	N.A.	250.0	1.75145	2.08E+01
	63/IB	19	277362.	974.2	15.17	N.A.	420.9	1.90589	3.61E+01
	43/U	19	1924140.	435.5	14.81	N.A.	274.6	1.78005	2.31E+01
534 MIXR	40/IA	21	1649932.	343.5	14.70	N.A.	250.4	1.75234	2.08E+01
	64/IB	21	295223.	976.4	15.17	N.A.	421.1	1.90603	3.61E+01
	44/U	21	1945155.	443.8	14.81	N.A.	276.3	1.78218	2.33E+01
541 MIXR	215/IA	0	210000.	867.0	754.68	1.341	1439.1	1.63491	9.94E-01
	252/IB	0	210000.	867.0	734.68	1.339	1439.8	1.61831	1.02E+00
	255/U	0	420000.	867.0	744.54	1.340	1439.5	1.63662	1.01E+00
542 MIXR	253/IA	0	210000.	867.0	754.68	1.341	1439.1	1.63491	9.94E-01
	254/IB	0	210000.	867.0	754.68	1.341	1439.1	1.63491	9.94E-01
	256/U	0	420000.	867.0	754.68	1.341	1439.1	1.63491	9.94E-01
543 MIXR	255/IA	0	420000.	867.0	744.54	1.340	1439.5	1.63662	1.01E+00
	256/IB	0	420000.	867.0	754.68	1.341	1439.1	1.63491	9.94E-01
	257/U	0	840000.	867.0	749.57	1.340	1439.3	1.63576	1.00E+00
549 MIXR	263/IA	0	582.	867.0	749.57	1.340	1439.3	1.63576	1.00E+00
	265/IB	0	3219.	458.8	103.00	1.079	1257.9	1.68281	5.16E+00
	264/U	0	3801.	517.0	124.90	1.108	1285.7	1.69145	4.54E+00
551 MIXR	268/IA	0	1400.	126.1	2.00	0.000	94.0	0.17500	1.62E-02
	267/IB	0	2401.	517.0	124.90	1.108	1285.7	1.69145	4.54E+00
	269/U	0	3801.	344.1	124.65	0.606	846.8	1.15645	2.19E+00

PEPSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 17  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED STEAM FLOW, MEA STACK T. (4CC\_6\_25\_92)

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY (-)	ENTH (B/LB)	ENTRPY (B/LB-F)	SPEC. VOLUME (FT3/LBM)
502 COMB	10/IA 3		1827389.	615.5	128.88	N.A.	280.1	1.67017	3.14E+00
	102/IF 7		31371.	65.0	14.70	N.A.	426.8	4.05322	N.A.
	14/U 11		1858760.	1783.7	128.88	N.A.	652.6	1.88343	6.62E+00
503 COMB	11/IA 4		1844432.	620.0	132.68	N.A.	281.3	1.66922	3.06E+00
	103/IF 8		31560.	65.0	14.70	N.A.	426.9	4.05335	N.A.
	15/U 12		1875993.	1784.0	132.68	N.A.	652.6	1.88141	6.43E+00
504 COMB	12/IA 5		1865560.	617.7	127.48	N.A.	280.7	1.67145	3.18E+00
	104/IF 9		32066.	65.0	14.70	N.A.	426.9	4.05335	N.A.
	16/U 13		1897626.	1786.8	127.48	N.A.	653.6	1.88463	6.71E+00
511 MIXR	13/IA 10		1880116.	1787.6	130.78	N.A.	653.9	1.88294	6.54E+00
	111/IB 0		8707.	86.6	250.00	-0.388	55.3	0.10526	1.61E-02
	17/U 14		1888823.	1758.5	130.78	N.A.	651.2	1.88138	6.47E+00
512 MIXR	14/IA 11		1858760.	1783.7	128.88	N.A.	652.6	1.88343	6.62E+00
	112/IB 0		9908.	86.6	250.00	-0.388	55.3	0.10526	1.61E-02
	18/U 16		1868668.	1750.2	128.88	N.A.	649.5	1.88163	6.54E+00
513 MIXR	15/IA 12		1875993.	1784.0	132.68	N.A.	652.6	1.88141	6.43E+00
	113/IB 0		10508.	86.6	250.00	-0.388	55.3	0.10526	1.61E-02
	19/U 18		1886501.	1748.9	132.68	N.A.	649.2	1.87951	6.35E+00
514 MIXR	16/IA 13		1897626.	1786.8	127.48	N.A.	653.6	1.88463	6.71E+00
	114/IB 0		9458.	86.6	250.00	-0.388	55.3	0.10526	1.61E-02
	20/U 20		1907084.	1755.5	127.48	N.A.	650.7	1.88295	6.63E+00
521 MIXR	21/IA 14		1888823.	1600.5	87.00	N.A.	603.8	1.88798	9.04E+00
	51/IB 2		37718.	616.2	130.78	N.A.	280.3	1.66932	3.09E+00
	25/U 15		1926541.	1582.8	87.30	N.A.	597.5	1.88500	8.92E+00
522 MIXR	22/IA 16		1868668.	1598.8	87.00	N.A.	604.0	1.88806	9.03E+00
	52/IB 3		37292.	615.5	128.88	N.A.	280.1	1.67017	3.14E+00
	26/U 17		1905960.	1581.1	87.29	N.A.	597.7	1.88508	8.92E+00
523 MIXR	23/IA 18		1886501.	1585.7	87.00	N.A.	600.3	1.88627	8.97E+00
	53/IB 4		37640.	620.0	132.68	N.A.	281.3	1.66922	3.06E+00
	27/U 19		1924140.	1568.3	87.31	N.A.	594.1	1.88331	8.86E+00



PERSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 5 CREATED 22 JAN 91 DATE 01-07-93. AGE 20  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (4CC\_6\_25\_92)

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY ( - )	ENTH (B/LB)	ENTRYP (B/LB-F)	SPEC. VOLUME (FT3/LBM)
633 SPCT	206/I	0	420000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
	214/U	0	210000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
	213/B	0	210000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
641 SPIX	257/I	0	840000.	867.0	749.57	1.340	1439.3	1.63576	1.00E+00
	258/U	0	839418.	867.0	749.57	1.340	1439.3	1.63576	1.00E+00
	263/B	0	582.	867.0	749.57	1.340	1439.3	1.63576	1.00E+00
644 SPIX	264/I	0	3801.	517.0	124.90	1.108	1285.7	1.69145	4.54E+00
	266/U	0	1400.	517.0	124.90	1.108	1285.7	1.69145	4.54E+00
	267/B	0	2401.	517.0	124.90	1.108	1285.7	1.69145	4.54E+00
649 SPIX	259/I	0	839418.	458.8	103.00	1.079	1257.9	1.68281	5.16E+00
	260/U	0	836199.	458.8	103.00	1.079	1257.9	1.68281	5.16E+00
	265/B	0	3219.	458.8	103.00	1.079	1257.9	1.68281	5.16E+00
801 PMAC	1/I	2	1886006.	90.2	14.58	N.A.	149.4	1.65537	1.42E+01
	5/U	2	1886006.	616.2	130.78	N.A.	280.3	1.66932	3.09E+00
802 PMAC	2/I	3	1864681.	90.2	14.58	N.A.	149.4	1.65537	1.42E+01
	6/U	3	1864681.	615.5	128.88	N.A.	280.1	1.67017	3.14E+00
803 PMAC	3/I	4	1882072.	90.2	14.59	N.A.	149.4	1.65534	1.42E+01
	7/U	4	1882072.	620.0	132.68	N.A.	281.3	1.66922	3.06E+00
804 PMAC	4/I	5	1903631.	90.2	14.58	N.A.	149.4	1.65537	1.42E+01
	8/U	5	1903631.	617.7	127.48	N.A.	280.7	1.67145	3.18E+00
811 TGAS	17/I	14	188823.	1758.5	126.20	N.A.	651.2	1.88390	6.71E+00
	21/U	14	188823.	1600.5	87.00	N.A.	603.8	1.88798	9.04E+00
812 TGAS	18/I	16	1868668.	1750.2	124.37	N.A.	649.5	1.88414	6.78E+00
	22/U	16	1868668.	1598.8	87.00	N.A.	604.0	1.88806	9.03E+00
813 TGAS	19/I	18	1886501.	1748.9	128.04	N.A.	649.2	1.88202	6.58E+00
	23/U	18	1886501.	1565.7	87.00	N.A.	600.3	1.88627	8.97E+00
814 TGAS	20/I	20	1907084.	1755.5	123.02	N.A.	650.7	1.88546	6.87E+00
	24/U	20	1907084.	1608.2	87.00	N.A.	606.5	1.88926	9.07E+00

PEPSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 19  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED STEAM FLOW, MEA stack T. (ACC 6\_25\_92)

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY (-)	ENTH (B/LB)	ENTRPY (B/LB-F)	SPEC. VOLUME (FT3/LBM)
601	SPCT	5/I	2 1886006.	616.2	130.78	N.A.	280.3	1.66932	3.09E+00
		9/U	2 1848287.	616.2	130.78	N.A.	280.3	1.66932	3.09E+00
		51/B	2 37718.	616.2	130.78	N.A.	280.3	1.66932	3.09E+00
602	SPCT	6/I	3 1864681.	615.5	128.88	N.A.	280.1	1.67017	3.14E+00
		10/U	3 1827389.	615.5	128.88	N.A.	280.1	1.67017	3.14E+00
		52/B	3 37292.	615.5	128.88	N.A.	280.1	1.67017	3.14E+00
603	SPCT	7/I	4 1882072.	620.0	132.68	N.A.	281.3	1.66922	3.06E+00
		11/U	4 1844432.	620.0	132.68	N.A.	281.3	1.66922	3.06E+00
		53/B	4 37640.	620.0	132.68	N.A.	281.3	1.66922	3.06E+00
604	SPCT	8/I	5 1903631.	617.7	127.48	N.A.	280.7	1.67145	3.18E+00
		12/U	5 1865560.	617.7	127.48	N.A.	280.7	1.67145	3.18E+00
		54/B	5 38071.	617.7	127.48	N.A.	280.7	1.67145	3.18E+00
611	SPCT	29/I	15 1926541.	982.5	15.24	N.A.	422.5	1.90676	3.61E+01
		33/U	15 1629645.	982.5	15.24	N.A.	422.5	1.90676	3.61E+01
		61/B	15 296896.	982.5	15.24	N.A.	422.5	1.90676	3.61E+01
612	SPCT	30/I	17 1905960.	974.2	15.19	N.A.	420.8	1.90570	3.60E+01
		34/U	17 1658937.	974.2	15.19	N.A.	420.8	1.90570	3.60E+01
		62/B	17 247023.	974.2	15.19	N.A.	420.8	1.90570	3.60E+01
613	SPCT	31/I	19 1924140.	974.2	15.17	N.A.	420.9	1.90589	3.61E+01
		35/U	19 1646779.	974.2	15.17	N.A.	420.9	1.90589	3.61E+01
		63/B	19 277362.	974.2	15.17	N.A.	420.9	1.90589	3.61E+01
614	SPCT	32/I	21 1945155.	976.4	15.17	N.A.	421.1	1.90603	3.61E+01
		36/U	21 1649932.	976.4	15.17	N.A.	421.1	1.90603	3.61E+01
		64/B	21 295223.	976.4	15.17	N.A.	421.1	1.90603	3.61E+01
631	SPCT	204/I	0 840000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
		206/U	0 420000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
		203/B	0 420000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
632	SPCT	205/I	0 420000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
		211/U	0 210000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02
		212/B	0 210000.	127.3	1274.68	-0.807	98.5	0.17610	1.62E-02

PERSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 22  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED STM FLOW, MEA STACK T. (4CC\_6\_25\_92)

PROPERTIES FOR ACTIVE STREAMS

STRM TYPE	STRM TYPE	FROM /TO	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY ( - )	ENTHALPY (B/LB)	PDRP/P ( - )
17	2	511-U 811-I	14	1888823.	1758.5 1758.5	130.8 126.2	N.A. N.A.	651.2 651.2	0.035
18	2	512-U 812-I	16	1868668.	1750.2 1750.2	128.9 124.4	N.A. N.A.	649.5 649.5	0.035
19	2	513-U 813-I	18	1886501.	1748.9 1748.9	132.7 128.0	N.A. N.A.	649.2 649.2	0.035
20	2	514-U 814-I	20	1907084.	1755.5 1755.5	127.5 123.0	N.A. N.A.	650.7 650.7	0.035
204	6	402-U 631-I	0	840000.	127.3 127.3	1274.7 1274.7	-0.8071 -0.8071	98.5 98.5	0.000
257	6	543-U 641-I	0	840000.	867.0 867.0	749.6 749.6	1.3408 1.3408	1439.3 1439.3	0.000

PEPSE C' BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1. CREATED 22 JAN 91 DATE 01-07-93. AGE 21  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED STM FLOW, MEA stack T. (4CC\_6\_25\_92)

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY ( - )	ENTH (B/LB)	ENTRPY (B/LB-F)	SPEC. VOLUME (FT3/LBM)
821 TGAS	25/I	15	1926541.	1582.8	87.30	N.A.	597.5	1.88500	8.92E+00
	29/U	15	1926541.	982.5	15.24	N.A.	422.5	1.90676	3.61E+01
822 TGAS	26/I	17	1905960.	1581.1	87.29	N.A.	597.7	1.88508	8.92E+00
	30/U	17	1905960.	974.2	15.19	N.A.	420.8	1.90570	3.60E+01
823 TGAS	27/I	19	1924140.	1568.3	87.31	N.A.	594.1	1.88331	8.86E+00
	31/U	19	1924140.	974.2	15.17	N.A.	420.9	1.90589	3.61E+01
824 TGAS	28/I	21	1945155.	1590.4	87.28	N.A.	600.1	1.88628	8.96E+00
	32/U	21	1945155.	976.4	15.17	N.A.	421.1	1.90603	3.61E+01

PEPSE C' BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 24  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED steam flow, MEA stack T. (4CC\_6\_25\_92)

MATERIAL DESCRIPTIONS USED IN THE MODEL

FLUID ID	CO2	H2O	SO2	O2	N2	CO	H2	C	S	ASH	FUEL HIGH HEAT VALUE (BTU/LBM)
19	0.044	0.056		0.161	0.739						N.A.
20	0.045	0.056		0.159	0.739						N.A.
21	0.044	0.056		0.161	0.740						N.A.

FLUID ID	CO2	H2O	SO2	O2	N2	CO	H2	C	S
0		1.000							
1				0.209	0.791				
2		0.026		0.203	0.771				
3		0.026		0.203	0.771				
4		0.026		0.203	0.771				
5		0.026		0.203	0.771				
6				0.006	0.001		0.654	0.339	
7				0.006	0.001		0.654	0.339	
8				0.006	0.001		0.654	0.339	
9				0.006	0.001		0.654	0.339	
10	0.029	0.081		0.141	0.749				
11	0.029	0.081		0.141	0.749				
12	0.029	0.081		0.142	0.749				
13	0.029	0.081		0.141	0.749				
14	0.029	0.088		0.140	0.743				
15	0.028	0.086		0.142	0.744				
16	0.029	0.088		0.140	0.743				
17	0.028	0.087		0.142	0.743				
18	0.028	0.089		0.140	0.742				
19	0.028	0.087		0.142	0.743				
20	0.029	0.088		0.140	0.743				
21	0.028	0.087		0.142	0.744				

PEPSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 5 CREATED 22 JAN 91 DATE 01-07-93. AGE 23  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED STM FLOW, MEA STACK T. (4CC\_6\_25\_92)

MATERIAL DESCRIPTIONS USED IN THE MODEL

FLUID ID	CONSTITUENT MASS FRACTIONS										FUEL HIGH HEAT VALUE (BTU/LBM)	
	CO2	H2O	SO2	O2	N2	CO	H2	C	S	ASH		
0		1.000										
1			0.232	0.769								N.A.
2		0.016	0.228	0.756								N.A.
3		0.016	0.228	0.756								N.A.
4		0.016	0.228	0.756								N.A.
5		0.016	0.228	0.756								N.A.
6			0.036	0.003			0.235	0.726				2.2470E+04
7			0.036	0.003			0.235	0.726				2.2470E+04
8			0.036	0.003			0.235	0.726				2.2470E+04
9			0.036	0.003			0.235	0.726				2.2470E+04
10	0.045	0.052	0.160	0.743								N.A.
11	0.045	0.052	0.160	0.743								N.A.
12	0.045	0.051	0.161	0.743								N.A.
13	0.045	0.052	0.160	0.743								N.A.
14	0.045	0.056	0.159	0.740								N.A.
15	0.044	0.055	0.161	0.740								N.A.
16	0.045	0.057	0.160	0.739								N.A.
17	0.044	0.056	0.161	0.740								N.A.
18	0.044	0.057	0.160	0.739								N.A.

PEPSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 26  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (4CC\_6\_25\_92)

COMPARISON OF COMPONENT PORT TEST DATA WITH PEPSE EMPLOYED STREAM PROPERTIES

STREAM NUMBER	STRM TYPE	PEPSE/TEST	STREAM START/END	TEMPERATURE (F)	THERMO PRESSURE (PSIA)	QUALITY (-)
5	0	PEPSE TEST	START START		130.78 130.78	
6	0	PEPSE TEST	START START		128.88 128.88	
7	0	PEPSE TEST	START START		132.68 132.68	
8	0	PEPSE TEST	START START		127.48 127.48	
37	0	PEPSE TEST	START START		14.70 14.70	
38	0	PEPSE TEST	START START		14.70 14.70	
39	0	PEPSE TEST	START START		14.70 14.70	
40	0	PEPSE TEST	START START		14.70 14.70	
202	0	PEPSE TEST	START START		117.68 117.68	
204	6	PEPSE TEST	START START		1274.68 1274.68	
215	0	PEPSE TEST	START START	867.0 867.0	754.68 754.68	
252	0	PEPSE TEST	START START	867.0 867.0	734.68 734.68	
253	0	PEPSE TEST	START START	867.0 867.0	754.68 754.68	
254	0	PEPSE TEST	START START	867.0 867.0	754.68 754.68	

PEPSE C/ BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 25  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED STM flow, MEA stack T. (4CC\_6\_25\_92)

STREAMS CARRYING THE TABULATED MATERIALS

PLU ID	ORIGIN +CMP/-STR	STREAMS:
0	N.A.	111, 112, 113, 114, 201, 202, 203, 204, 205, 206, 211, 212 213, 214, 215, 241, 242, 252, 253, 254, 255, 256, 257, 258 259, 260, 262, 263, 264, 265, 266, 267, 268, 269
1	0	
2	11	1, 5, 9, 51
3	12	2, 6, 10, 52
4	13	3, 7, 11, 53
5	14	4, 8, 12, 54
6	21	101
7	22	102
8	23	103
9	24	104
10	501	13
11	502	14
12	503	15
13	504	16
14	511	17, 21
15	521	25, 29, 33, 37, 41, 61
16	512	18, 22
17	522	26, 30, 34, 38, 42, 62
18	513	19, 23
19	523	27, 31, 35, 39, 43, 63
20	514	20, 24
21	524	28, 32, 36, 40, 44, 64



PERSE C/ BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 28  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (4CC\_6\_25\_92)

DETAILED TURBINE PERFORMANCE TABLE B

COMPONENT	STG GROUP	BOWL FLOW (LBM/HR)	PRESSURE AT LOAD (PSIA)	BOWL SHELL (BTU/LBM)	ENTHALPY AT LOAD (BTU/LBM)	ENTROPY AT LOAD (BTU/LB-F)	PRESS RATIO (-)	SHELL FLOW COEFF (*)	EXTR PRESS DROP (-)
811/GAS	1888823.	126.20	87.00	651.2	603.8	1.884	1.888	1.45	N.A.
821/	1926541.	87.30	15.24	597.5	422.5	1.885	1.907	5.73	N.A.
812/	1868668.	124.37	87.00	649.5	604.0	1.884	1.888	1.43	N.A.
822/	1905960.	87.29	15.19	597.7	420.8	1.885	1.906	5.75	N.A.
813/	1886501.	128.04	87.00	649.2	600.3	1.882	1.886	1.47	N.A.
823/	1924140.	87.31	15.17	594.1	420.9	1.883	1.906	5.75	N.A.
814/	1907084.	123.02	87.00	650.7	606.5	1.885	1.889	1.41	N.A.
824/	1945155.	87.28	15.17	600.1	421.1	1.886	1.906	5.75	N.A.
100/GENL	839418.	749.57	103.00	1439.3	1257.9	1.636	1.683	7.28	187221.00
101/	836199.	103.00	1.89	1257.9	1012.8	1.683	1.749	54.49	N.A.00

DETAILED TURBINE PERFORMANCE TABLE C

BASE END POINT PRESSURE IS 1.500 IN.HG

COMP NUMB	ACTUAL ANNULUS VELOCITY REF LOAD (FT/SEC)	SONIC ANNULUS VELOCITY REF LOAD (FT/SEC)	EFFICIENCY AT END PRESSURE (-)	EXHAUST LOSS (BTU/LBM)	ENERGY END POINTS (B T U / L B M)	CHOK PRESS (PSIA)			
101	N.A.	578.8	N.A.	1462.6	0.87488	5.28	966.12	1007.55	N.A.

PEPSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 27  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (4CC\_6\_25\_92)

DETAILED TURBINE PERFORMANCE TABLE A

COMPONENT	NUM	STAGE	GRP	EFFCYS	MECHANICAL POWER	EXTRACT FLOW AT LOAD
FLOW ENDS	REF.	LOAD	REF.	LOAD	STEAM EXTRACTION	LIQUID REMOVED
( - )	CASE	CASE	CASE	CASE	( L B M / H R )	
( - )	( - )	( - )	( MW )	( MW )		
811/GAS	1	N.A.	0.85000	N.A.	8.94551E+07	
821/	1	N.A.	0.85285	N.A.	3.37143E+08	
				SECTION EFFICIENCY AT LOAD = 0.87837		
812/	1	N.A.	0.85000	N.A.	8.48766E+07	
822/	1	N.A.	0.86125	N.A.	3.37185E+08	
				SECTION EFFICIENCY AT LOAD = 0.88486		
813/	1	N.A.	0.85000	N.A.	9.22965E+07	
823/	1	N.A.	0.84770	N.A.	3.33145E+08	
				SECTION EFFICIENCY AT LOAD = 0.87435		
814/	1	N.A.	0.85000	N.A.	8.42676E+07	
824/	1	N.A.	0.86732	N.A.	3.48239E+08	
				SECTION EFFICIENCY AT LOAD = 0.88964		
100/GENL	1	N.A.	0.81441	N.A.	4.46201E+01	0.
101/	2	N.A.	0.86349	N.A.	6.00564E+01	0.
				SECTION EFFICIENCY AT LOAD = 0.86562		


PERSE C/ BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 30  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED STM FLOW, MEA STACK T. (ACC\_6\_25\_92)

DETAILED FEEDWATER HEATER PERFORMANCE OUTPUT - TABLE A  
 (EXTRACTION FLOW UPDATING BEGINS AT ITERATION 2)

HTR COMP NO.	COMPONENT DESCRIPTION	HEAT TRANSFER/DEG* CONDENSING SUBCOOL/MX SECTION	HEAT# EX TEMP PERF DIFF PRESS INDEX (TTD) (DCA) DROP ( - ) (F) (PSIA)	HEAT# EX TEMP PERF DIFF PRESS INDEX (TTD) (DCA) DROP ( - ) (F) (PSIA)	TERM COOL TUBE DRAIN FW OR DRAIN FW OR DRAIN FW OR	UPD INT/ (RELAXN) DEMAND REFERENCE ( - )
A 200	STD. CONDENSER	3.79E+07	7.84E+04	9.62	N.A.	N.A.
B 201	STD. CONDENSER	2.28E+04	0.00E+00	9.98	N.A.	N.A.

\* HEAT TRANSFER/DEG IS SIMILAR TO UA. SEE VOL 1 OUTPUT DESCRIPTION.  
 † PERFORMANCE INDEX IS SIMILAR TO EFFECTIVENESS. SEE VOL 1 OUTPUT DESCRIPTION.

TURBINE EXPANSION CHARACTERISTICS



PEPSE C/ BY NUS CORPORATION, IDAHO FALLS, ID. AGE 32  
 VERSION 5 CREATED 22 JAN 91 DATE 01-07-93.  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (4CC\_6\_\_25\_92)

DETAILED HEAT EXCHANGER PERFORMANCE OUTPUT

COMPONENT NUMBER	COMPONENT DESCRIPTION	HEAT EXCH SHELL LOSSES (BTU/HR)	HEAT TO TUBE SIDE FLUID (BTU/HR)	HEAT EXCH PERF INDEX# (-)	PRESSURE DROP TUBE ( P S I )	PRESSURE DROP SHELL
211	CONVECTIVE STAGE	0.0000	2.8153E+08	0.9544	520.000	0.542
212	CONVECTIVE STAGE	0.0000	2.8169E+08	0.9576	540.000	0.489
213	CONVECTIVE STAGE	0.0000	2.8153E+08	0.9575	520.000	0.471
214	CONVECTIVE STAGE	0.0000	2.8153E+08	0.9567	520.000	0.475

# PERFORMANCE INDEX IS SIMILAR TO EFFECTIVENESS. SEE VOL 1 OUTPUT DESCRIPTION.

PEPSE C/ BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 31  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (ACC\_6\_25\_92)

DETAILED FEEDWATER HEATER PERFORMANCE OUTPUT - TABLE B

HTR COMP NO. NO.	COMPONENT DESCRIPTION	HEAT		ENTHALPY		TO		M A S S F L O W S	
		XFER TO FW OR CIRC.H2O (BTU/HR)	RISE FW OR CIRC. STEAM (BTU/LBM)	RISE EXT	DROP EXT	HEATER SHELL	HEATER DRAIN IN	RATE THRU TUBES	RATE
A 200 STD.	CONDENSER	7.73E+08	26.8	920.9		836199.		3801.	28842924.
B 201 STD.	CONDENSER	1.67E+06	2.0	1191.6		1400.		0.	840000.

PEPSE Cc BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 5 CREATED 22 JAN 91 DATE 01-07-93. AGE 34  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED steam flow, MEA stack T. (ACC\_6\_25\_92)

DETAILED SPLITTER PERFORMANCE OUTPUT

COMPONENT NUMBER	COMPONENT DESCRIPTION	B PORT FLOW (LBM/HR)	B PORT QUALITY ( - )	LEAKAGE CONSTANT ( * )	MOISTURE REMOVAL EFFECTIVENESS ( - )
601	FIXED P.C. SPLIT	37718.	N.A.	N.A.	N.A.
602	FIXED P.C. SPLIT	37292.	N.A.	N.A.	N.A.
603	FIXED P.C. SPLIT	37640.	N.A.	N.A.	N.A.
604	FIXED P.C. SPLIT	38071.	N.A.	N.A.	N.A.
611	FIXED P.C. SPLIT	296896.	N.A.	N.A.	N.A.
612	FIXED P.C. SPLIT	247023.	N.A.	N.A.	N.A.
613	FIXED P.C. SPLIT	277362.	N.A.	N.A.	N.A.
614	FIXED P.C. SPLIT	295223.	N.A.	N.A.	N.A.
631	FIXED P.C. SPLIT	420000.	-0.8071	N.A.	N.A.
632	FIXED P.C. SPLIT	210000.	-0.8071	N.A.	N.A.
633	FIXED P.C. SPLIT	210000.	-0.8071	N.A.	N.A.
641	FIXED FLOW SPLIT	582.	1.3409	N.A.	N.A.
644	FIXED FLOW SPLIT	2401.	1.1081	N.A.	N.A.
649	FIXED FLOW SPLIT	3219.	1.0791	N.A.	N.A.

PEPSE C BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION - CREATED 22 JAN 91 DATE 01-07-93. AGE 33  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stem flow, MEA stack T. (4CC\_6\_25\_92)

DETAILED PUMP/COMPRESSOR PERFORMANCE OUTPUT

COMP NO.	COMPONENT DESCRIPTION	PUMP/COMP EFFICIENCY (-)	LINKAGE/DRIVER EFFIC (-)	PRESSURE RISE (PSI)	ENTH RISE (BTU/LBM)	DRIVER POWER (KW)	GLAND/SEAL LOSSES (BTU/HR)	Input Power	WHP	Actual WHP/BHP	Pump EFF
401	STD. ELE. PUMP	0.8000	1.0000 0.9500	115.79 267.13 FT	0.43	1.1257E+02	0.0000	106.94 KW	85.55 KW	93.181 BHP	68.46
402	STD. ELE. PUMP	0.8500	1.0000 0.9500	1157.00 2669.19 FT	4.08	1.0573E+03	0.0000				
801	AUX. DR. FAN/CMP	0.8883	1.0000 N.A.	116.20	130.87	7.2337E+04	0.0000				
802	AUX. DR. FAN/CMP	0.8817	1.0000 N.A.	114.30	130.69	7.1419E+04	0.0000				
803	AUX. DR. FAN/CMP	0.8893	1.0000 N.A.	118.09	131.85	7.2726E+04	0.0000				
804	AUX. DR. FAN/CMP	0.8720	1.0000 N.A.	112.90	131.25	7.3226E+04	0.0000				



FIRST LAW OF THERMODYNAMICS PERFORMANCE - ENVELOPE 1

TERM	VALUE
HEAT SUPPLIED (ALL UNITS ARE BTU/HR) -	
MAKEUP HEATS BY FLOW INTO THE ENVELOPE	
1 AT SOURCE/SINK COMPONENT, USER ID 11	6.09671E+06
2 AT SOURCE/SINK COMPONENT, USER ID 12	6.02777E+06
3 AT SOURCE/SINK COMPONENT, USER ID 13	6.08396E+06
4 AT SOURCE/SINK COMPONENT, USER ID 14	6.15368E+06
5 AT SOURCE/SINK COMPONENT, USER ID 21	6.44628E+08
6 AT SOURCE/SINK COMPONENT, USER ID 22	6.35352E+08
7 AT SOURCE/SINK COMPONENT, USER ID 23	6.39190E+08
8 AT SOURCE/SINK COMPONENT, USER ID 24	6.49426E+08
9 AT SOURCE/SINK COMPONENT, USER ID 31	-9.05426E+06
10 AT SOURCE/SINK COMPONENT, USER ID 32	-1.03032E+07
11 AT SOURCE/SINK COMPONENT, USER ID 33	-1.09271E+07
12 AT SOURCE/SINK COMPONENT, USER ID 34	-9.83521E+06
13 AT BOUNDARY STREAM, USER ID 204	-8.37243E+08
LETDOWN HEATS BY FLOW FROM THE ENVELOPE	
14 AT SOURCE/SINK COMPONENT, USER ID 41	1.80368E+08
15 AT SOURCE/SINK COMPONENT, USER ID 42	1.71014E+08
16 AT SOURCE/SINK COMPONENT, USER ID 43	1.75528E+08
17 AT SOURCE/SINK COMPONENT, USER ID 44	1.81568E+08
18 AT BOUNDARY STREAM, USER ID 257	2.89032E+08
19 NET HEAT TO ENVELOPE BY FLOW	7.18085E+08
20 CIRC WATER LOAD CREDIT (HEAT IN)	0.00000E+00
21 FURNACE UNACCOUNTED HEAT LOSSES	0.00000E+00
22 BOILER REHEAT (TYPE 25 COMPONENTS)	0.00000E+00
23 UNSPECIFIED HEAT EXCHANGERS (HEAT IN)	0.00000E+00
24 COMPONENT VESSEL LOSSES	0.00000E+00
25 PIPE HEAT AND ELEVATION LOSSES	-6.97500E-07
26 PUMP/COMP/PAN INEFFICIENCY LOSSES	0.00000E+00
27 PUMP GLANDS AND SEALS LOSSES	0.00000E+00
28 GENERATOR HYD AND OIL COOLER (HEAT IN)	0.00000E+00
29 HEAT IN AS ELECTRIC PUMP/COMP/PAN POWER	0.00000E+00
30 NET POWER SUPPLIED	7.18085E+08
POWER OUT (ALL UNITS ARE MWE) -	
31 NET TURBINE WHEEL POWER TO GENERATORS	2.10450E+02
32 APPORTIONED GENERATOR MECHANICAL LOSSES	1.56513E+00
33 APPORTIONED GENERATOR ELECTRICAL LOSSES	2.93030E+00
34 GROSS GENERATOR POWER	2.05954E+02
35 ELECTRIC POWER USED FOR PUMP/COMP/PAN	0.00000E+00
36 APP HOUSE LOAD EXC ELEC PUMP/COMP/PAN	0.00000E+00
37 NET GENERATOR POWER	2.05954E+02
ENVELOPE PERFORMANCE, EFFICIENCY, -	9.78639E-01
ENVELOPE PERFORMANCE, HEAT RATE, BTU/KW-HR	3.48662E+03

BY DEFAULT, EFFICIENCY IS DEFINED AS (NET GENERATOR POWER / NET POWER SUPPLIED)  
 BY DEFAULT, HEAT RATE IS DEFINED AS (NET POWER SUPPLIED / NET GENERATOR POWER)

PEPSE CC BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION : CREATED 22 JAN 91 DATE 01-07-93. AGE 35  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (ACC\_6\_25\_92)

DETAILED COMBUSTOR PERFORMANCE OUTPUT

COMP NO.	FUEL FIRING RATE (LBM/HR)	AD. EXCESS AIR (-)	FLAME TEMP. (F)	EXIT TEMP. (F)	IN-AIR/IN-FUEL	OUT-REFUSE/OUT-FLU GAS	LOST TO ENVIR.	RESIDENT HX'S
501	3.183E+04	2.5148	1787.6	1787.6	2.479E+08 6.446E+08	0.000E+00 8.925E+08	0.000E+00	0.000E+00
502	3.137E+04	2.5259	1783.7	1783.7	2.447E+08 6.354E+08	0.000E+00 8.801E+08	0.000E+00	0.000E+00
503	3.156E+04	2.5374	1784.0	1784.0	2.492E+08 6.392E+08	0.000E+00 8.883E+08	0.000E+00	0.000E+00
504	3.207E+04	2.5215	1786.8	1786.8	2.509E+08 6.494E+08	0.000E+00 9.003E+08	0.000E+00	0.000E+00

PEPSE C/ BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 5 CREATED 22 JAN 91 DATE 01-07-93. AGE 38  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (ACC 6\_25\_92)

FIRST LAW OF THERMODYNAMICS PERFORMANCE - SYSTEM

HEAT SUPPLIED (ALL UNITS ARE BTU/HR) -	
BOILER HEAT TO WORKING FLUID	-7.72896E+08
1ST BOILER REHEAT (IN, TYPE 25 COMPONENT)	0.00000E+00
2ND BOILER REHEAT (IN, TYPE 25 COMPONENT)	0.00000E+00
UNSPECIFIED HEAT EXCHANGERS (HEAT IN)	0.00000E+00
GROSS HEAT SUPPLIED	-7.72896E+08
MAKEUP HEAT (BY FLOW IN)	2.55284E+09
LETDOWN HEAT (BY FLOW OUT)	7.08478E+08
CIRC WATER LOAD CREDIT (HEAT IN)	7.74565E+08
COMPONENT VESSEL LOSSES	0.00000E+00
PIPE HEAT AND ELEVATION LOSSES	-6.97500E-07
PUMP/COMP/FAN INEFFICIENCY LOSSES	1.99590E+05
PUMP GLANDS AND SEALS LOSSES	0.00000E+00
GENERATOR HYD AND OIL COOLER (HEAT IN)	0.00000E+00
NET HEAT SUPPLIED	1.84583E+09
HEAT IN AS ELECTRIC PUMP/COMP/FAN POWER	3.99180E+06
NET POWER SUPPLIED	1.84982E+09

POWER OUT (ALL UNITS ARE MWE) -	
NET TURBINE WHEEL POWER TO GENERATORS	315.126
GENERATOR MECHANICAL LOSSES	2.344
GENERATOR ELECTRICAL LOSSES	4.388
GROSS GENERATOR POWER	308.395
ELECTRIC POWER USED FOR PUMP/COMP/FAN	1.170
HOUSE LOAD POWER, EXCLUDING ELEC PUMP/COMP/FAN	0.000
NET GENERATOR POWER	307.225

SYSTEM PERFORMANCE	THERMAL EFF.	HEAT RATE
	( - )	( BTU/KW-HR )
GROSS ACTUAL TURBINE CYCLE		
(GROSS HEAT SUPPLIED / GROSS GENERATOR POWER)	-1.36149	-2506.
NET ACTUAL TURBINE CYCLE		
(MOD NET POWER SUPPLIED / NET GENERATOR POWER)	0.56664	6022.
TURBINE CYCLE STEAM RATE, LBM/KW-HR		93.5259

NOTE: MOD NET POWER SUPPLIED = NET POWER SUPPLIED + COMPONENT VESSEL LOSSES +  
 PIPE HEAT AND ELEVATION LOSSES + PUMP INEFFICIENCY LOSSES +  
 PUMP GLANDS AND SEALS LOSSES

FIRST LAW OF THERMODYNAMICS PERFORMANCE - ENVELOPE 2

TERM		
	HEAT SUPPLIED (ALL UNITS ARE BTU/HR) -	
	MAKEUP HEATS BY FLOW INTO THE ENVELOPE	
1	AT SOURCE/SINK COMPONENT, USER ID 50	-2.99873E+10
2	AT BOUNDARY STREAM, USER ID 257	2.89032E+08
	LETDOWN HEATS BY FLOW FROM THE ENVELOPE	
3	AT SOURCE/SINK COMPONENT, USER ID 51	-2.92144E+10
4	AT BOUNDARY STREAM, USER ID 204	-8.37243E+08
5	NET HEAT TO ENVELOPE BY FLOW	3.53379E+08
6	CIRC WATER LOAD CREDIT (HEAT IN)	
7	FURNACE UNACCOUNTED HEAT LOSSES	7.74565E+08
8	BOILER REHEAT (TYPE 25 COMPONENTS)	0.00000E+00
9	UNSPECIFIED HEAT EXCHANGERS (HEAT IN)	0.00000E+00
10	COMPONENT VESSEL LOSSES	0.00000E+00
11	PIPE HEAT AND ELEVATION LOSSES	0.00000E+00
12	PUMP/COMP/FAN INEFFICIENCY LOSSES	1.99590E+05
13	PUMP GLANDS AND SEALS LOSSES	0.00000E+00
14	GENERATOR HYD AND OIL COOLER (HEAT IN)	0.00000E+00
15	HEAT IN AS ELECTRIC PUMP/COMP/FAN POWER	3.99180E+06
16	NET POWER SUPPLIED	1.13174E+09
	POWER OUT (ALL UNITS ARE MWE) -	
17	NET TURBINE WHEEL POWER TO GENERATORS	1.04677E+02
18	APPORTIONED GENERATOR MECHANICAL LOSSES	7.78488E-01
19	APPORTIONED GENERATOR ELECTRICAL LOSSES	1.45752E+00
20	GROSS GENERATOR POWER	1.02441E+02
21	ELECTRIC POWER USED FOR PUMP/COMP/FAN	1.16988E+00
22	APP HOUSE LOAD EXC ELEC PUMP/COMP/FAN	0.00000E+00
23	NET GENERATOR POWER	1.01271E+02
	ENVELOPE PERFORMANCE, EFFICIENCY, -	3.05327E-01
	ENVELOPE PERFORMANCE, HEAT RATE, BTU/KW-HR	1.11754E+04

BY DEFAULT, EFFICIENCY IS DEFINED AS (NET GENERATOR POWER / NET POWER SUPPLIED)  
 BY DEFAULT, HEAT RATE IS DEFINED AS (NET POWER SUPPLIED / NET GENERATOR POWER)

PEPSE C' BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION 1 CREATED 22 JAN 91 DATE 01-07-93. AGE 40  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED stm flow, MEA stack T. (ACC\_6\_25\_92)

SPECIAL OUTPUT TABLE OF SPECIFIED VARIABLES

INDEX	DESCRIPTION	VARIABLE(ID)	VALUE
151	1ST STACK CO2, DRY FRACT. (MOLE) VOL	OPVB ( 113)	3.077116E-02
160	2ND STACK O2, DRY FRACT. (MOLE) VOL	OPVB ( 122)	1.550696E-01
161	2ND STACK CO2, DRY FRACT. (MOLE) VOL	OPVB ( 123)	3.067261E-02
170	3RD STACK O2, DRY FRACT. (MOLE) VOL	OPVB ( 132)	1.552490E-01
171	3RD STACK CO2, DRY FRACT. (MOLE) VOL	OPVB ( 133)	3.056948E-02
180	4TH STACK O2, DRY FRACT. (MOLE) VOL	OPVB ( 142)	1.550007E-01
181	4TH STACK CO2, DRY FRACT. (MOLE) VOL	OPVB ( 143)	3.071148E-02

PEPSE C BY NUS CORPORATION, IDAHO FALLS, ID.  
 VERSION : CREATED 22 JAN 91 DATE 01-07-93. AGE 39  
 THW 4 COMBINED CYCLE TEST, 6/25/92, MED STM FLOW, MEA STACK T. (ACC\_6\_25\_92)

SPECIAL OUTPUT TABLE OF SPECIFIED VARIABLES

INDEX	DESCRIPTION	VARIABLE(ID)	VALUE
10	1ST GT COMPRESSOR CALC. AIR FLOW, ACFM	OPVB ( 10)	4.455621E+05
11	FIRST GT TEST HEAT INPUT, BTU/HR	QFLHHV( 501)	7.151954E+08
12	FIRST GT TEST GROSS GENERATION, MW	BKGR0 ( 1)	5.155640E+01
13	FIRST GT TEST GROSS HEAT RATE, BTU/KWH	OPVB ( 16)	1.387210E+04
14	FIRST GT CORR. ISO GROSS HEAT RATE	OPVB ( 17)	1.343883E+04
15	FIRST GT CORR. ISO GROSS GENERATION	OPVB ( 18)	5.839952E+01
16	FIRST GT CORR. ISO AIR FLOW, LB/HR	OPVB ( 19)	2.013672E+06
17	FIRST GT CORR. ISO EXHAUST TEMP., DEGF	OPVB ( 14)	9.691300E+02
18	1ST GT COMPRESSOR EFFICIENCY	EFFPMP( 801)	8.883488E-01
19	1ST GT OVERALL EXPANDER EFFICIENCY	EFFSEC( 821)	8.783732E-01
20	2ND GT COMPRESSOR CALC. AIR FLOW, ACFM	OPVB ( 20)	4.405243E+05
21	2ND GT TEST HEAT INPUT, BTU/HR	QFLHHV( 502)	7.049019E+08
22	2ND GT TEST GROSS GENERATION, MW	BKGR0 ( 2)	5.114950E+01
23	2ND GT TEST GROSS HEAT RATE, BTU/KWH	OPVB ( 26)	1.378121E+04
24	2ND GT CORR. ISO GROSS HEAT RATE	OPVB ( 27)	1.335078E+04
25	2ND GT CORR. ISO GROSS GENERATION	OPVB ( 28)	5.793901E+01
26	2ND GT CORR. ISO AIR FLOW, LB/HR	OPVB ( 29)	1.990904E+06
27	2ND GT CORR. ISO EXHAUST TEMP., DEGF	OPVB ( 24)	9.691300E+02
28	2ND GT OVERALL EXPANDER EFFICIENCY	EFFPMP( 802)	8.816818E-01
29	2ND GT COMPRESSOR EFFICIENCY	EFFSEC( 822)	8.848555E-01
30	3RD GT COMPRESSOR CALC. AIR FLOW, ACFM	OPVB ( 30)	4.444481E+05
31	3RD GT TEST HEAT INPUT, BTU/HR	QFLHHV( 503)	7.091622E+08
32	3RD GT TEST GROSS GENERATION, MW	BKGR0 ( 3)	5.083590E+01
33	3RD GT TEST GROSS HEAT RATE, BTU/KWH	OPVB ( 36)	1.395003E+04
34	3RD GT CORR. ISO GROSS HEAT RATE	OPVB ( 37)	1.351433E+04
35	3RD GT CORR. ISO GROSS GENERATION	OPVB ( 38)	5.758378E+01
36	3RD GT CORR. ISO AIR FLOW, LB/HR	OPVB ( 39)	2.009472E+06
37	3RD GT CORR. ISO EXHAUST TEMP., DEGF	OPVB ( 34)	9.691300E+02
38	3RD GT OVERALL EXPANDER EFFICIENCY	EFFPMP( 803)	8.892937E-01
39	3RD GT COMPRESSOR EFFICIENCY	EFFSEC( 823)	8.743471E-01
40	4TH GT COMPRESSOR CALC. AIR FLOW, ACFM	OPVB ( 40)	4.497261E+05
41	4TH GT TEST HEAT INPUT, BTU/HR	QFLHHV( 504)	7.205185E+08
42	4TH GT TEST GROSS GENERATION, MW	BKGR0 ( 4)	5.239010E+01
43	4TH GT TEST GROSS HEAT RATE, BTU/KWH	OPVB ( 46)	1.375295E+04
44	4TH GT CORR. ISO GROSS HEAT RATE	OPVB ( 47)	1.332341E+04
45	4TH GT CORR. ISO GROSS GENERATION	OPVB ( 48)	5.934428E+01
46	4TH GT CORR. ISO AIR FLOW, LB/HR	OPVB ( 49)	2.032491E+06
47	4TH GT CORR. ISO EXHAUST TEMP., DEGF	OPVB ( 44)	9.691300E+02
48	4TH GT OVERALL EXPANDER EFFICIENCY	EFFPMP( 804)	8.720173E-01
49	4TH GT COMPRESSOR EFFICIENCY	EFFSEC( 824)	8.856399E-01
50	SIMPLE CYCLE GROSS GENERATION, MW	OPVB ( 70)	2.059319E+02
51	STEAM TURBINE GROSS GENERATION, KW	POWER ( 5)	1.024630E+05
52	UNIT AUXILIARY LOAD, MW	OPVB ( 71)	3.901000E+00
53	COMBINED CYCLE GROSS GENERATION, MW	OPVB ( 72)	3.083949E+02
54	COMBINED CYCLE NET GENERATION, MW	OPVB ( 73)	3.044939E+02
55	TOTAL UNIT HEAT INPUT, BTU/HR	OPVB ( 74)	2.849778E+09
56	GROSS UNIT HEAT RATE, BTU/KWH	OPVB ( 75)	9.240678E+03
57	NET UNIT HEAT RATE, BTU/KWH	OPVB ( 76)	9.359064E+03
58	GROSS STEAM TURBINE HEAT RATE, BTU/KWH	OPVB ( 77)	1.099202E+04
59	STEAM TURBINE EFFICIENCY	EFFSEC( 101)	8.656195E-01
141	1ST HRSG EFFECTIVENESS	EFFHX ( 211)	9.543887E-01
142	2ND HRSG EFFECTIVENESS	EFFHX ( 212)	9.576370E-01
143	3RD HRSG EFFECTIVENESS	EFFHX ( 213)	9.575183E-01
144	4TH HRSG EFFECTIVENESS	EFFHX ( 214)	9.566920E-01
150	1ST STACK O2, DRY FRACT. (MOLE) VOL	OPVB ( 112)	1.5488963E-01

## RESULTS AND DISCUSSION

### **COMBINED CYCLE**

The maximum capability test was performed on the T. H. Wharton Unit 4 on June 25, 1992 at a combined gross load of 308,395 KW. The gross unit heat rate was calculated at 9204.7 BTu/KHr and the net unit heat rate at 9359.1 BTu/KWHr. The steam turbine gross generation is 102,463 KW with a gross turbine heat rate of 10992.2 BTu/KWHr.

### **Unit 41 GT and HRSG**

Unit 41 GT produced a corrected output of 58,400 KW while the corrected heat rate is 13,435 BTu/KWHr. The compressor efficiency is 88.83% while the compressor suction flow is 1,886,006 lb/hr or 445,568 acfm. The expander isentropic efficiency is calculated at 87.84%.

The Unit 41 HRSG performance is based on the PEPSE calculated heat exchanger effectiveness. The Unit 41 HRSG has an effectiveness of 0.9544 with a measured stack temperature of 341.5°F. The estimated bypass stack leakage for this unit is 15.41%.

### **Unit 42 GT and HRSG**

Unit 42 GT produced a corrected output of 57,939 KW while the corrected heat rate is 13,351 BTu/KWHr. The compressor efficiency is 88.17% while the compressor suction flow is 1,864,681 lb/hr or 440,524 acfm. The expander isentropic efficiency is calculated at 88.49%.

The Unit 42 HRSG performance is based on the PEPSE calculated heat exchanger effectiveness. The Unit 42 HRSG has an effectiveness of 0.9576 with a measured stack temperature of 344.5°F. The estimated bypass stack leakage for this unit is 12.98%.

### **Unit 43 GT and HRSG**

Unit 43 GT produced a corrected output of 57,584KW while the corrected heat rate is 13,514 BTu/KWHr. The compressor efficiency is 88.93% while the compressor suction flow is 1,882,072 lb/hr or 444,448 acfm. The expander isentropic efficiency is calculated at 87.43%.

The Unit 43 HRSG performance is based on the PEPSE calculated heat exchanger effectiveness. The Unit 43 HRSG has an effectiveness of 0.9575 with a measured stack temperature of 340.0°F. The estimated bypass stack leakage for this unit is 14.41%.

### **Unit 44 GT and HRSG**

Unit 44 GT produced a corrected output of 59,344 KW while the corrected heat rate is

13,323 BTu/KW hr. The compressor efficiency is 87.20% while the compressor suction flow is 1,903,631 lb/hr or 449,726 acfm. The expander isentropic efficiency is calculated at 88.96%.

The Unit 44 HRSG performance is based on the PEPSE calculated heat exchanger effectiveness. The Unit 44 HRSG has an effectiveness of 0.9567 with a measured stack temperature of 343.5°F. The estimated bypass stack leakage for this unit is 15.18%.

### **Auxiliary Equipment**

The Condenser can reject  $7.73 \times 10^8$  BTu/Hr with an inlet temperature of 87.35°F and an outlet temperature of 114.12°F, a temperature rise of about 26.8°F. This provides a backpressure of 1.89 psia or 3.85 inHg for the steam turbine exhaust condition

The circulating water pump is delivering a flow of 57,908 gpm with a condenser inlet pressure of 34.8 psig.

The condensate pump is delivering a flow of 1696.6 gpm at a discharge head of 103 psig with an efficiency of 71.09%, the expected efficiency at this flow is 73.2% at a developed head of 280 ft or 121.21 psig.

The boiler feed pump is delivering a flow of 1686.1 gpm at a discharge head of 1260 psig with an efficiency of 74.77%, the expected efficiency at this flow is 74.2% at a developed head of 2370 ft or 1026 psig.

## **CONCLUSIONS**

The T. H. Wharton Unit 4 Combined Cycle can achieve the maximum summer rated capability of 285 MW without any equipment limitations. The Unit 44 GT is the best performing GT with higher output and lowest heat rate. There is estimated a significant leakage thru the bypass dampers on each HRSG system, the dampers should be examined and adjusted for tighter closure. If this is not possible then an additional guillotine or knife gate closure device should be installed to reduce the exhaust gas loss.

If a detailed GT, HRSG, steam turbine or other component analysis is required or any cycle critical flows, temperatures and pressures are required on an on going basis then better monitoring instrumentation will need to be installed. Plant Engineers and their Instrument and Controls personnel, Maintenance Services GT personnel and Performance Analysis personnel should meet to discuss the need for better performance monitoring and the required instrumentation.

The condensate pump is head deficient and should be inspected at the next opportunity. Initially the lift should be reset and performance monitored, if not improved, the pump



should be scheduled for maintenance.

The boiler feed pump is operating as inspected and head capability is adequate for continued operation.

The circulating water pump is operating as expected and is adequate for continued operation.

The GT Prime modifications project underway will alleviate some of the simple cycle GT deficiencies but other maintenance is required for the balance of the combined cycle system as discussed above.

## **ACKNOWLEDGEMENTS**

**A. LAU HL&P Performance Analysis Supervising Engineer for test data and PEPSE run on T. H. Wharton Unit 4.**

**ASME -American Society of Mechanical Engineers Performance Test Codes (PTC)**

**PEPSE - Trademark of Halliburton NUS Corporation**

**Bailey - Trademark of Bailey Meter Co.**

**EPRI - Electric Power Research Institute**

**GATE and EMAP - Trademarks of Gas Turbine Performance Software Products licensed by EPRI**

**PEPSE Users Manuals Volumes I & II, Halliburton Nus Corporation**

**GE-Trademark of General Electric Corporation**