

**Condenser Performance
Evaluation of Atlantic Electric's
B. L. England Unit #1**

Leif M. E. Svensen, III, P.E.

Atlantic Electric Company

ABSTRACT

The condensers on B. L. England Units 1&2 do not presently operate at their original level of performance. This is due to both chemical treatment for corrosion, which impedes heat transfer, and a change in material from the original Aluminum-brass to 90-10 copper-nickel in the late 1960s due to corrosion problems. The current condenser cleanliness factor is less than 60 percent for each unit.

The PEPSE heat balance program was used to model the performance of B. L. England Unit 1 with the proposed titanium condenser design. It was found that the new design would yield an improvement of approximately 0.7 percent in both heat rate and generating capability over that of the current condenser. Because Units 1&2 are similar in both design and heat rate, the results would also apply to B. L. England Unit 2.

Introduction

The original condenser for B. L. England Units 1 and 2 used aluminum-brass tubes, which were installed in the early 1960s. Due to their salt water service, corrosion and erosion were problems and resulting tube failures were common. In 1971, the original aluminum - brass tubes were replaced with 90-10 copper nickel tubes; these are 7 percent less effective than the original aluminum-brass. Also, even the original design was marginal considering the consistently high circulating water inlet temperatures the plant must tolerate in the summer months. These temperatures average 79°F, 19°F higher than original condenser design from June to September. Summer inlet temperatures even higher than 90°F have also been recorded for extended time periods. With the change to 90-10 copper-nickel tubes, any existing margin was eliminated so that the condenser cannot now meet the original performance expectations.

A current operating cleanliness factor of 60 percent has been determined through testing and trend data. Currently, there is a reluctance to raise the cleanliness factor by cleaning the condenser to achieve an expected operating cleanliness factor of 85 percent. This is because stripping the tubes of any coating created by chemical water treatment is undersirable although it does maintain the extra level of corrosion protection.

This PEPSE study investigated whether tube replacement can be justified by the performance gains only. Previous studies concerning replacement due to expected tube failure rates had indicated that replacement could not be cost justified at a 1.5 million dollar expenditure per condenser. But based on this PEPSE Performance Study, the expenditure for replacement can be justified.

PEPSE Modeling

The modeling was rather simple. An HEI condenser was modeled for the base case, and this was used for the subsequent upgrade cases. In the model, maximum continuous rating (MCR) steam flow to the turbine was used to evaluate conditions when maximum load is required. The circulating water temperature (for technical data and model see Appendix II), tube material, surface areas, and cleanliness were changed to come up with the upgraded condenser.

The unit was modeled to reflect the current tested heat rate and MW hour output. This was done by reducing the benchmark turbine efficiencies by about 3.12 percent. Since good extraction test data was not available, using a constant reduction produced a heat rate and MW hour output equivalent to the most current test.

Performance Analysis

The following runs were modeled for the performance evaluation.

Run	Clean- liness	Circulating Water Temps	TUBE DIA	TUBE MAT'l	Circulating Water Pump Flow	Surface Area	BWG
1	60%	40-90°F by 5°F	7/8"	90-10	Lo-sp Hi- sp one or two pumps	Original	18
2	90-100%	80-90°F "	"	"	Two pumps, Hi-sp		18
3	60%	80-90°F "	"	"	Lo-sp Hi-sp Two pumps	Original	18
4	90%	80-90°F "	7/8"	TI	Lo-sp Hi-sp Two pumps	Original	27
5	90%	80-90°F "	"	"	Lo-sp Hi-sp Two pumps	Original	25
6	90%	80-90°F "	"	"	Lo-sp Hi-sp Two pumps	Original	20
7	90%	40-90°F "	3/4"	TI	Lo-sp Hi-sp Two pumps	Upgraded By 27%	25
8	90%	40-60°F "	"	"	Lo-sp Hi-sp One pumps	Upgraded By 27%	25

Titanium tubes were chosen for all upgrades because of inherent resistance to both erosion and corrosion.

The first run was to obtain a current 90-10 condenser benchmark for heat rates and output to compare them to any upgrades. The second gave a set of heat rates as a goal when changing the material to titanium. Since a 7 percent degradation in performance occurred from the change from aluminum-brass to 90-10, the cleanliness rate for the 90-10 would have to be higher than 92 percent to be equivalent to the original condensers. The same or improved performance over the original aluminum-brass design was desired; therefore, the 90 percent, 95 percent and 100 percent cleanliness factors were run to give targets for initial comparisons.

The most cost effective option would be replacement of the 90-10 with the same size diameter titanium tubes. Therefore, PEPSE runs four through six, with the 7/8"OD TI tubes, were completed using different tube gauges and a 90 percent cleanliness factor (standard for TI condensers). It was found that improvement over the current 90-10 condenser at 60 percent cleanliness could be achieved, but it would still be worse than a 90-10 condenser at 90 percent cleanliness, even using the thin walled 27 BWG tubes for optimum heat transfer rates. Also, it was found that changing from 25 BWG tubes to 27 BWG tubes, resulted in only an insignificant the incremental decrease in heat rate. Therefore, the more common 25 BWG tube gauge will be used for subsequent upgrade cases.

The next option was to increase surface area by using to the next smaller tube diameter of 3/4". To maintain a constant velocity through the tubes, the cross sectional area available for water flow of the 3/4" diameter tubes was made equivalent to that same area for the 7/8" diameter tubes. Doing this should also yield similar condenser tubeside pressure drops between the current and upgraded versions. The effect is to increase the condenser

surface by 27 percent and the number of tubes by 40 percent. It was found that with this upgrade, using 25 BWG tubes yielded a unit heat rate performance better than the 90-10 at the 100 percent cleanliness factor.

The 27 percent increase in surface area yielded a 0.7 percent decrease in annualized heat rate and a 0.7 percent increase in annualized maximum output for Unit 1. Similar performance results are expected for Unit 2. The estimated payback from the predicted improvements would be eight and five years, respectively (See Report, Appendix I). These condensers are in the budget for replacement within the next two years.

REFERENCES

1. PEPSE Manual: Volumes I, II and III, E. I. International Inc.
P.O. Box 50736, Idaho Falls, Idaho
Revision 15, 4/12/90
2. ASTM Standards For Titanium Specifications, 1916 Race Street
Philadelphia, PA, 19103, August 1986
3. Delta T. Study, Report #86-34 Atlantic Electric's,
September 1986, J. C. Eigenbrood

APPENDIX I

M E M O R A N D U M

February 12, 1990

TO: J.C. McCullough
FROM: L.M. Svensen
SUBJECT: Condenser Performance B.L. England Units 1&2

The condensers on B.L. England Units 1&2 are not operating at their original level of performance. This is due to both chemical treatment for corrosion, which impedes heat transfer, and a change in material from the original Al-bronze to 90-10 copper-nickel in the late 60s. The current condenser cleanliness factor is less than 60 % on both Units.


A study was completed in 1986 (the Delta T Study, report #86-39) which proposed retubing the condensers with titanium tubes and tubesheets. Because the heat transfer coefficient of titanium is less than that of 90-10 copper nickel, a 27 percent increase in condenser surface area was also recommended. Condenser cleanliness factors of 90% are predicted with this configuration.

The enclosed analysis has been completed to determine the effect of these proposed condenser modifications on unit performance.

The PEPSE heat balance program was used to model the performance of B.L. England Unit 1 with the proposed titanium condenser design. It was found that the new design would yield an improvement of approximately 0.7 percent in both heat rate and generating capability. Changes in circulating water temperature Delta T are also indicated, and may be greater or less than current depending on CW pumping mode. However, all should remain within current constraints. Because Units 1&2 are similar in design the results would also apply to B.L. England Unit 2.

The estimated cost of the condenser modifications is \$1,500,000 for each unit. PROMOD III was run to determine the fuel and interchange savings that would result from the predicted performance improvements. The PROMOD study shows that the payback period would be five years for retubing Unit 2 and eight years for Unit 1. An additional savings of up to \$80,000 per year is possible if credit is taken for added installed capacity. If both condensers are modified as proposed, the summer installed capacity of B.L. England Station should increase by approximately 2 MW.

The tables and memorandum that follow summarize the results of this study.


L.M. Svensen

B.L. ENGLAND UNIT #1

CIRCULATING WATER TEMPERATURES WHEN OPTIMIZING
PERFORMANCE OF 90-10 COPPER NICKEL VS. TITANIUM.

PASSES	CWI	90-10 COPPER NICKEL				TITANIUM			
		PUMPS	FLOW	CWO	DELTA-T	PUMPS	FLOW	CWO	DELTA-T
SINGLE	40	2-LO SP	88000	54.3	14.3	1-LO SP	44000	68.7	28.7
SINGLE	45	2-LO SP	88000	59.4	14.4	1-HI SP	52000	62.3	22.3
SINGLE	50	2-LO SP	88000	64.4	14.4	2-LO SP	88000	64.4	14.4
SINGLE	55	2-LO SP	88000	69.4	14.4	2-LO SP	88000	69.4	14.4
SINGLE	60	2-LO SP	88000	74.4	14.4	2-LO SP	88000	74.4	14.4
SINGLE	65	2-HI SP	104000	77.2	12.2	2-LO SP	88000	79.4	14.4
SINGLE	70	2-HI SP	104000	82.3	12.3	2-LO SP	88000	84.4	14.4
SINGLE	75	2-HI SP	104000	87.3	12.3	2-LO SP	88000	89.5	14.5
SINGLE	80	2-HI SP	104000	92.4	12.4	2-HI SP	104000	92.3	12.3
SINGLE	85	2-HI SP	104000	97.5	12.5	2-HI SP	104000	97.3	12.3
SINGLE	90	2-HI SP	104000	102.5	12.5	2-HI SP	104000	102.4	12.4

NOTE: THIS TABLE SHOWS THAT THE NEW DELTA T'S WITH THE TITANIUM CONDENSER WILL BE WITHIN THE ALLOWABLE ENVIRONMENTAL LIMITS (IE. 16 SUMMER 35 WINTER), DURING BOTH SUMMER AND WINTER OPERATION.

B.L. ENGLAND UNIT #1

PERFORMANCE COMPARISON BETWEEN
 90-10 COPPER NICKEL AND TITANIUM CONDENSER TUBES
 WHEN VARYING CIRCULATING WATER FLOW TO OPTIMIZE
 PERFORMANCE.

NSHR: NET STATION HEAT RATE
 CWO: CIRCULATING WATER OUTLET TEMPERATURE
 CWI: CIRCULATING WATER INLET TEMPERATURE
 ABS: CONDENSER ABSOLUTE IN INCHES OF HG.

PASSES	CWI	90-10 COPPER NICKEL					TITANIUM					DIFFERENCE		
		PUMPS	FLOW	ABS.	NMW	NSHR	PUMPS	FLOW	ABS.	NMW	NSHR	ABS.	NMW	NSHR
SINGLE	40	2-LO SP	88000	1.33	132.33	9776	1-LO SP	44000	1.49	132.41	9771	0.2	0.085	-5.047
SINGLE	45	2-LO SP	88000	1.40	132.36	9780	1-HI SP	52000	1.26	132.35	9775	-0.1	-0.006	-4.648
SINGLE	50	2-LO SP	88000	1.50	132.20	9787	2-LO SP	88000	1.00	132.30	9779	-0.5	0.104	-7.831
SINGLE	55	2-LO SP	88000	1.65	132.01	9801	2-LO SP	88000	1.13	132.32	9777	-0.5	0.320	-23.53
SINGLE	60	2-LO SP	88000	1.82	131.70	9823	2-LO SP	88000	1.28	132.33	9776	-0.5	0.643	-47.08
SINGLE	65	2-HI SP	104000	1.83	131.30	9854	2-LO SP	88000	1.47	132.23	9784	-0.4	0.936	-69.70
SINGLE	70	2-HI SP	104000	2.07	130.79	9892	2-LO SP	88000	1.68	131.95	9805	-0.4	1.168	-86.97
SINGLE	75	2-HI SP	104000	2.36	129.98	9954	2-LO SP	88000	1.93	131.47	9840	-0.4	1.488	-113.4
SINGLE	80	2-HI SP	104000	2.71	129.24	10038	2-HI SP	104000	2.06	130.80	9890	-0.7	1.565	-147.1
SINGLE	85	2-HI SP	104000	3.11	127.48	10149	2-HI SP	104000	2.38	129.92	9958	-0.7	2.443	-191.1
SINGLE	90	2-HI SP	104000	3.57	125.87	10278	2-HI SP	104000	2.75	128.75	10048	-0.8	2.878	-229.6

NOTE: THIS TABLE SHOWS A COMPARISON BETWEEN BEST CASE OPERATIONS FOR A GIVEN CIRCULATING WATER INLET TEMPERATURE. IN OUR FINANCIAL ANALYSIS WE HAVE TAKEN CREDIT FOR BOTH AN IMPROVEMENT IN EFFICIENCY AND AN INCREASE IN NET GENERATION.

B.L. ENGLAND UNIT #1

CALCULATION OF PERCENT IMPROVEMENT IN HEAT RATE WITH TITANIUM CONDENSER TUBES

MONTH	FIVE YEAR AVG CWI	CIRCULATING FLOW IN GPM	DELTA H.R. IN %	FIVE YEAR MONTHLY GEN.		IMPROVEMENT %
				AVG. MONTHLY GENERATION	% OF ANNUAL GENERATION	
1	43	44000	-0.04	74752	10.29	0.00
2	47	52000	-0.03	68529	9.44	0.00
3	49	88000	-0.07	58676	8.08	0.01
4	58	88000	-0.38	45593	6.28	0.02
5	65	88000	-0.70	49423	6.81	0.05
6	76	88000	-1.20	56955	7.84	0.09
7	81	104000	-1.58	73595	10.14	0.16
8	82	104000	-1.66	74644	10.28	0.17
9	77	88000	-1.26	54366	7.49	0.09
10	63	88000	-0.61	55401	7.63	0.05
11	56	88000	-0.29	53749	7.40	0.02
12	48	88000	-0.06	60433	8.32	0.00
SUM				726117	100.00	0.7

NOTE: THE IMPROVEMENT IN PERFORMANCE WITH TITANIUM CONDENSER TUBES WILL VARY DEPENDING ON THE COOLING WATER TEMPERATURE. THIS TABLE PREDICTS THE MONTHLY PERFORMANCE IMPROVEMENT BASED ON THE EXPECTED GENERATION AND AVERAGE CIRCULATING WATER INLET TEMPERATURE FOR EACH MONTH.

B.L. ENGLAND UNIT #1

PERFORMANCE COMPARISON BETWEEN
 90-10 COPPER NICKEL AND TITANIUM CONDENSER TUBES
 WITH CONSTANT CIRCULATING WATER FLOW.

NSHR: NET STATION HEAT RATE
 CWI: CIRCULATING WATER INLET TEMPERATURE
 ABS: CONDENSER ABSOLUTE IN INCHES OF HG.

PASSES	CWI	90-10 COPPER NICKEL					TITANIUM					DELTA		
		PUMPS	FLOW	ABS.	NW	NSHR	PUMPS	FLOW	ABS.	NW	NSHR	ABS.	NW	NSHR
SINGLE	40	1-LO SP	44000	2.92	128.78	10046	1-LO SP	44000	1.49	132.41	9771	-1.423	3.63	-275
SINGLE	45	1-LO SP	44000	2.94	128.72	10052	1-LO SP	44000	1.60	132.28	9780	-1.335	3.56	-271
SINGLE	50	1-LO SP	44000	3.03	128.38	10078	1-LO SP	44000	1.74	132.05	9797	-1.288	3.67	-281
SINGLE	55	1-LO SP	44000	3.23	127.67	10133	1-LO SP	44000	1.93	131.69	9824	-1.298	4.01	-308
SINGLE	60						1-LO SP	44000	2.16	131.15	9864			
SINGLE	40	1-HI SP	52000	2.35	130.50	9914	1-HI SP	52000	1.26	132.35	9775	-1.090	1.85	-139
SINGLE	45	1-HI SP	52000	2.37	130.37	9924	1-HI SP	52000	1.36	132.33	9776	-1.011	1.96	-148
SINGLE	50	1-HI SP	52000	2.47	130.04	9948	1-HI SP	52000	1.48	132.23	9784	-0.987	2.18	-164
SINGLE	55	1-HI SP	52000	2.65	129.46	9993	1-HI SP	52000	1.65	132.01	9800	-0.999	2.55	-194
SINGLE	60						1-HI SP	52000	1.85	131.65	9827			
SINGLE	65						1-HI SP	52000	2.09	131.12	9867			
SINGLE	40	2-LO SP	88000	1.33	132.32	9776	2-LO SP	88000	0.81	132.29	9780	-0.517	-0.04	4
SINGLE	45	2-LO SP	88000	1.40	132.36	9780	2-LO SP	88000	0.90	132.33	9777	-0.504	-0.03	-2
SINGLE	50	2-LO SP	88000	1.50	132.19	9787	2-LO SP	88000	1.00	132.30	9779	-0.502	0.10	-8
SINGLE	55	2-LO SP	88000	1.65	132.00	9801	2-LO SP	88000	1.13	132.32	9777	-0.515	0.32	-24
SINGLE	60	2-LO SP	88000	1.82	131.69	9823	2-LO SP	88000	1.28	132.33	9776	-0.539	0.64	-47
SINGLE	65	2-LO SP	88000	2.04	131.23	9858	2-LO SP	88000	1.47	132.23	9784	-0.574	1.00	-75
SINGLE	70	2-LO SP	88000	2.30	130.56	9909	2-LO SP	88000	1.68	131.95	9805	-0.621	1.39	-105
SINGLE	75	2-LO SP	88000	2.62	129.54	9987	2-LO SP	88000	1.93	131.47	9840	-0.688	1.93	-147
SINGLE	80	2-LO SP	88000	3.00	128.27	10085	2-LO SP	88000	2.23	130.75	9895	-0.768	2.48	-190
SINGLE	85	2-LO SP	88000	3.45	126.69	10211	2-LO SP	88000	2.58	129.68	9976	-0.871	3.00	-235
SINGLE	90	2-LO SP	88000	3.95	125.01	10349	2-LO SP	88000	2.97	128.38	10077	-0.979	3.37	-272
SINGLE	40	2-HI SP	104000	1.15	131.93	9805	2-HI SP	104000	0.73	131.93	9805	-0.427	0.00	0
SINGLE	45	2-HI SP	104000	1.23	131.94	9805	2-HI SP	104000	0.81	131.90	9809	-0.419	-0.05	4
SINGLE	50	2-HI SP	104000	1.33	131.94	9805	2-HI SP	104000	0.91	131.94	9805	-0.419	0.00	-0
SINGLE	55	2-HI SP	104000	1.46	131.84	9813	2-HI SP	104000	1.03	131.91	9808	-0.429	0.06	-5
SINGLE	60	2-HI SP	104000	1.63	131.64	9827	2-HI SP	104000	1.17	131.94	9805	-0.454	0.30	-22
SINGLE	65	2-HI SP	104000	1.83	131.29	9854	2-HI SP	104000	1.34	131.93	9806	-0.484	0.64	-47
SINGLE	70	2-HI SP	104000	2.07	130.78	9892	2-HI SP	104000	1.54	131.75	9819	-0.523	0.97	-72
SINGLE	75	2-HI SP	104000	2.36	129.98	9954	2-HI SP	104000	1.78	131.38	9847	-0.580	1.40	-107
SINGLE	80	2-HI SP	104000	2.71	129.23	10038	2-HI SP	104000	2.06	130.80	9890	-0.651	1.56	-147
SINGLE	85	2-HI SP	104000	3.11	127.48	10149	2-HI SP	104000	2.38	129.92	9958	-0.734	2.44	-191
SINGLE	90	2-HI SP	104000	3.57	125.87	10278	2-HI SP	104000	2.75	128.75	10048	-0.828	2.88	-230

ENGLAND UNIT #1

GTR: GROSS TURBINE HEAT RATE
 NSR: NET STATION HEAT RATE
 CL: CLEANLINESS FACTOR IN PERCENT


CWI: CIRCULATING WATER INLET TEMPERATURE
 CWO: CIRCULATING WATER OUTLET TEMPERATURE
 COND ABS: CONDENSER ABSOLUTE IN INCHES OF HG.

COMPARING CURRENT PERFORMANCE WITH TI CONDENSER. OPERATING
 THE UNIT AT THE SAME GWW AS CURRENT PERFORMANCE INDICATES.

TEAM	FLOW	NUMBER OF	BWG	MAT'L	FLOW	CL%	CWI	COND	GW	GTR	AUX	NW	NSR	PREDICTED	DELTA	REDUCTION	HEAT RATE
NO		TUBES						ABS.		CURRENT	MW			CWO	TEMP.	IN DELTA	IMPROVEMENT
										CONDITIONS						+ OR - F	%
100.0		9152	18	90-10	88000	0.6	70	2.30	138.17	8240	7.610	130.56	9909	85	14.5		
100.0		9152	18	90-10	88000	0.6	75	2.62	137.15	8301	7.610	129.54	9987	90	14.6		
100.0		9152	18	90-10	88000	0.6	80	3.00	135.88	8378	7.610	128.27	10085	95	14.7		
100.0		9152	18	90-10	88000	0.6	85	3.45	134.30	8476	7.610	126.69	10211	100	15.0		
100.0		9152	18	90-10	88000	0.6	90	3.95	132.63	8584	7.610	125.02	10349	105	15.0		
100.0		9152	19	90-10	104000	0.6	70	2.07	138.79	8203	8.000	130.79	9892	82	12.3		
100.0		9152	18	90-10	104000	0.6	75	2.36	137.98	8251	8.000	129.98	9954	87	12.3		
100.0		9152	18	90-10	104000	0.6	80	2.71	137.24	8319	8.000	129.24	10038	92	12.4		
100.0		9152	18	90-10	104000	0.6	85	3.11	135.48	8403	8.000	127.48	10149	97	12.5		
100.0		9152	18	90-10	104000	0.6	90	3.57	133.87	8504	8.000	125.87	10278	103	12.5		
98.8	13558		25	TI	88000	0.9	70	1.66	138.18	8156	7.610	130.57	9808	84	14.3	0.3	1.03
98.3	13558		25	TI	88000	0.9	75	1.91	137.15	8183	7.610	129.54	9846	89	14.3	0.4	1.43
97.8	13558		25	TI	88000	0.9	80	2.20	135.89	8227	7.610	128.28	9903	94	14.3	0.5	1.84
97.3	13558		25	TI	88000	0.9	85	2.54	134.31	8290	7.610	126.70	9987	99	14.3	0.7	2.24
97.0	13558		25	TI	88000	0.9	90	2.92	132.63	8372	7.610	125.02	10092	104	14.3	0.6	2.54
99.1	13558		25	TI	104000	0.9	70	1.54	138.79	8144	8.000	130.79	9821	82	12.1	0.2	0.72
98.7	13558		25	TI	104000	0.9	75	1.77	137.98	8166	8.000	129.98	9851	87	12.1	0.2	1.05
98.6	13558		25	TI	104000	0.9	80	2.04	137.23	8201	8.000	129.23	9896	92	12.1	0.3	1.43
97.8	13558		25	TI	104000	0.9	85	2.35	135.49	8253	8.000	127.49	9967	97	12.1	0.4	1.82
97.4	13558		25	TI	104000	0.9	90	2.71	133.87	8325	8.000	125.87	10062	102	12.1	0.4	2.15


B.L. ENGLAND #1 N.S.H.R. VS.

CIRC. WATER TEMP. AT SPECIFIC FLOWS




B.L. ENGLAND #1 N.S.H.R. VS.

CIRC. WATER TEMP. AT SPECIFIC FLOWS




NET STATION HEAT RATE VRS.

CIRC. WATER TEMP. AT SPECIFIC FLOWS



B.L. ENGLAND #1 NET MWS VRS.

CIRC. WATER TEMP. AT SPECIFIC FLOWS



□ 88,90-10

+

104,90-10

◇

88,TI

△

104,TI

M E M O R A N D U M

December 22, 1989

To: L. M. Svensen

From: R. E. Herrmann

Subject: Estimated Energy Cost Savings Due to Improving
BLE 1&2 Heat Rate and Capacity

Our analysis of the energy cost savings of a 1% improvement in the heat rate and capability of BLE 1&2 is attached. The analyses were performed for each unit separately and for both units together. There is virtually no difference in the separate and combined results.

The analysis shows the following annualized savings (in 1990 dollars) over the period 1990-1999:

	Unit 1	Unit 2	Combined
1% Heat Rate improvement	\$107,000	\$222,000	\$327,000
1% Capability improvement*	150,000	180,000	328,000

* 1 MW on Unit 1, 2 MW on unit 2

The analysis was performed using the PROMOD III production costing model, and is based on the 1990-1992 Budget database. The savings were de-escalated to 1990 levels using the compound escalation rate of #6 oil, which drives the value of replacement (or displaced) energy.

The additional 3 MW of capability may offset future installed capacity requirements. The estimated 1990 PJM capacity deficiency rate of \$179/MW-day, factored up by AE's reserve requirement of 17%, is a proxy of its value, assuming it is required 6 months per year:

$$(3 \text{ MW} * \$179/\text{MW-day} * 1.17 * 365 \text{ days/year} * 0.5) = \$115,000/\text{year}$$

If you have any questions or need additional analysis, please let me know.



cc: E. R. Zimmerman

Analysis of Energy Cost Savings Associated with
BLE 1&2 1X Capacity Improvements

	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	Total Savings	Annual Savings
BLE 1 Capacity												
"Base" Fuel \$	155036	177701	213232	268516	289145	297001	326080	341473	358969	401305		
Fuel \$ w/Capacity Improvement	154908	177597	213125	268386	289026	296860	325859	341237	358719	401036		
Value of Capacity Improvement	128	104	107	130	119	141	221	236	250	269		
Value in 1990 \$	128	95	89	99	82	89	128	124	120	118	1072	107
BLE 2 Capacity												
"Base" Fuel \$	155036	177701	213232	268516	289145	297001	326080	341473	358969	401305		
Fuel \$ w/Capacity Improvement	154809	177472	212980	268250	288892	296716	325664	340997	358410	400712		
Value of Capacity Improvement	227	229	252	266	253	285	416	476	559	593		
Value in 1990 \$	227	209	210	202	175	180	240	251	268	260	2222	222
BLE 1&2 Capacity												
"Base" Fuel \$	155036	177701	213232	268516	289145	297001	326080	341473	358969	401305		
Fuel \$ w/Capacity Improvement	154716	177370	212859	268133	288768	296560	325449	340748	358163	400451		
Value of Capacity Improvement	320	331	373	363	377	441	631	725	806	854		
Value in 1990 \$	320	302	311	291	261	279	364	382	387	374	3271	327

Prepared by Power Economics
12/22/89

Analysis of Energy Cost Savings Associated with
BLE 1&2 1% Heat Rate Improvements

	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	Total Savings	Annual Savings
--	------	------	------	------	------	------	------	------	------	------	---------------	----------------

BLE 1 Heat Rate

"Base" Fuel \$	155036	177701	213232	268516	289145	297001	326080	341473	358969	401305		
Fuel \$ w/Heat	154823	177508	213044	268318	288962	296796	325814	341216	358697	401020		
Rate Improvement Value of Heat	213	193	188	198	183	205	266	257	272	285		
Rate Improvement Value in 1990 \$	213	176	157	150	127	130	153	135	131	125	1497	150

BLE 2 Heat Rate

"Base" Fuel \$	155036	177701	213232	268516	289145	297001	326080	341473	358969	401305		
Fuel \$ w/Heat	154819	177469	212985	268266	288896	296793	325772	341142	358655	400923		
Rate Improvement Value of Heat	217	232	247	250	249	208	308	331	314	382		
Rate Improvement Value in 1990 \$	217	212	206	190	173	132	178	174	151	167	1798	180

BLE 1&2 Heat Rate

"Base" Fuel \$	155036	177701	213232	268516	289145	297001	326080	341473	358969	401305		
Fuel \$ w/Heat	154629	177277	212792	268066	288720	296574	325533	340879	358363	400638		
Rate Improvement Value of Heat	407	424	440	450	425	427	547	594	606	667		
Rate Improvement Value in 1990 \$	407	387	366	342	295	270	316	313	291	292	3278	328

M E M O R A N D U M

March 27, 1990

TO: H. C. Schwemm G. E. Walters
J. C. McCullough V. N. Bhamidipati
J. A. Isabella E. Essington

FROM: L. M. Svensen

SUBJECT: B. L. England 1&2 Condenser Study
(dated 2/12/90 attached)


During the March 6, 1990 B. L. England production engineering meeting concern was expressed that the increased MW output of the units with new upgraded condensers might increase the heat rejection to the bay.

The condenser performance study was completed using constant inlet steam conditions, including throttle steam flow. An upgraded condenser would allow the turbine steam to exhaust to that condenser at a lower pressure than is permitted by the existing condenser. As the exhaust pressure is decreased, the turbine realizes a greater pressure drop to extract additional energy from steam; therefore, an increase in MW output for the same throttle steam flow results. Because of the greater amounts of energy extracted from each pound of steam with the upgrade condenser, for the same throttle flow the energy in BTU/hr rejected to the bay would be less with the upgraded condenser than with the existing condenser.

Another way of looking at this would be to use the temperature Entropy (T-S) diagram (see attached figure) and a simple rankine cycle. With the existing condenser, the cycle would be A,B,C,D, E and have a heat rejection equal the area A,E,F,G. The rankine cycle with the upgraded condenser would be A',B,C,D,E', and have a heat rejection area of E', F, G', A' which is less than the area of A,E,F,G.

The attached table summarizes the study results. At temperatures below 60°F there is barely a difference between the performance of the existing condenser and the performance of the upgraded condenser.

Please feel free to contact me at 625-6964 if you have any questions..



L. M. Svensen

LMS/jnk

xc: E. N. Belski
M. L. Puri
E. N. Adolfsen

T-S DIAGRAM

TEMPERTURE



ENTROPY

E.L. ENGLAND UNIT #1

PERFORMANCE COMPARISON BETWEEN
90-10 COPPER NICKEL AND TITANIUM CONDENSER TUBES
FOR HEAT REJECTION TO THE CIRCULATING WATER.

NSHR: NET STATION HEAT RATE
NMW: NET MEGA WATTS
CWI: CIRCULATING WATER INLET TEMPERATURE
ABS: CONDENSER ABSOLUTE IN INCHES OF HG.
Q: HEAT REJECTION TO THE CIRCULATING WATER


PASSES	CWI	PUMPS	FLOW	90-10 COPPER NICKEL				TITANIUM				DIFFERENCE	
				ABS.	NMW	NSHR	Q (BTU/HR)	ABS.	NMW	NSHR	Q (BTU/HR)	Q %	Q (BTU/HR)
SINGLE	40	2-LO SP	88000	1.33	132.33	9776	6.491E+08	0.81	132.29	9780	6.495E+08	0.07	4.750E+05
SINGLE	45	2-LO SP	88000	1.40	132.36	9780	6.492E+08	0.90	132.33	9777	6.494E+08	0.03	1.800E+05
SINGLE	50	2-LO SP	88000	1.50	132.20	9787	6.491E+08	1.00	132.30	9779	6.492E+08	0.01	8.500E+04
SINGLE	55	2-LO SP	88000	1.65	132.01	9801	6.491E+08	1.13	132.32	9777	6.491E+08	0.01	7.200E+04
SINGLE	60	2-LO SP	88000	1.82	131.70	9823	6.492E+08	1.28	132.33	9776	6.491E+08	-0.01	-8.300E+04
SINGLE	65	2-LO SP	88000	2.04	131.24	9858	6.499E+08	1.47	132.23	9784	6.490E+08	-0.13	-8.520E+05
SINGLE	70	2-LO SP	88000	2.30	130.56	9909	6.512E+08	1.68	131.95	9805	6.494E+08	-0.28	-1.804E+06
SINGLE	75	2-LO SP	88000	2.62	129.54	9987	6.532E+08	1.93	131.47	9840	6.505E+08	-0.42	-2.773E+06
SINGLE	80	2-LO SP	88000	3.00	128.27	10085	6.563E+08	2.23	130.75	9895	6.523E+08	-0.61	-4.003E+06
SINGLE	85	2-LO SP	88000	3.45	126.69	10211	6.604E+08	2.58	129.68	9976	6.549E+08	-0.83	-5.466E+06
SINGLE	90	2-LO SP	88000	3.95	125.02	10349	6.655E+08	2.97	128.38	10077	6.588E+08	-1.00	-6.666E+06
SINGLE	40	2-HI SP	104000	1.15	131.94	9805	6.492E+08	0.73	131.93	9805	6.496E+08	0.07	4.340E+05
SINGLE	45	2-HI SP	104000	1.23	131.95	9805	6.491E+08	0.81	131.90	9809	6.495E+08	0.06	3.980E+05
SINGLE	50	2-HI SP	104000	1.33	131.94	9805	6.492E+08	0.91	131.94	9805	6.493E+08	0.02	1.220E+05
SINGLE	55	2-HI SP	104000	1.46	131.85	9813	6.491E+08	1.03	131.91	9808	6.491E+08	0.00	2.000E+04
SINGLE	60	2-HI SP	104000	1.63	131.64	9827	6.491E+08	1.17	131.94	9805	6.492E+08	0.02	1.380E+05
SINGLE	65	2-HI SP	104000	1.83	131.30	9854	6.493E+08	1.34	131.93	9806	6.491E+08	-0.04	-2.730E+05
SINGLE	70	2-HI SP	104000	2.07	130.79	9892	6.502E+08	1.54	131.75	9819	6.491E+08	-0.18	-1.141E+06
SINGLE	75	2-HI SP	104000	2.36	129.98	9954	6.519E+08	1.78	131.38	9847	6.498E+08	-0.31	-2.038E+06
SINGLE	80	2-HI SP	104000	2.71	129.24	10038	6.543E+08	2.06	130.80	9890	6.513E+08	-0.46	-3.001E+06
SINGLE	85	2-HI SP	104000	3.11	127.48	10149	6.578E+08	2.38	129.92	9958	6.535E+08	-0.66	-4.356E+06
SINGLE	90	2-HI SP	104000	3.57	125.87	10278	6.623E+08	2.75	128.75	10048	6.568E+08	-0.83	-5.525E+06

APPENDIX II

3051
M2-216-1

512 G11 605

CALCULATED DATA - NOT GUARANTEED
FOR ENGINEERING PURPOSES ONLY



Legend: h = Enthalpy, Btu/Lb.
 t = Temperature, °F
 F = Flow, Lb/Hr.
 P = Pressure, PSIA

Generator Output
133,516 KW
30 PSIG H₂ Pressure
0.866 PF
1700 KW-Gas. Losses
539 KW-Fixed Losses

11,000 KW 3600 RPM TC2F-26"
1300 PSIG 1000*/1000* 1.5" IUC ADS.
GEN: 160 MVA @ 30 PSIG H₂ PRESS. & 0.95 PF
(CONV.)

*GROSS HEAT RATE = (851,000 + 1000 + 150) (1480.4) + 2500 (1339.5) + 4200 (694.8)
= 837,150 (431.2) - 4500 (308.5) + 796,355 (1522.0)
= 775,565 (1331.4) - 21,300 (306.5)

*INCLUDES ALL HEAT ADDED TO THE CYCLE BY BOILER AND REHEATER

ATLANTIC CITY ELECTRIC COMPANY
BEESLEY'S POINT GENERATING STATION, UNIT NO. 1
HEAT BALANCE DIAGRAM - DESIGN LOAD

GENERAL ELECTRIC COMPANY, SCHENECTADY, NEW YORK

BECHTEL CORPORATION JOB 3031

309 H3 225

11
10
9
8
7
6
5
4
3
2
1

CONDENSER

Manufacturer	Ingersoll-Rand
Type	Single Pass, Divided Waterbox
Cooling Surface	62,500 sq. ft.
Hotwell Capacity	5600 GPM
Shell and Tube Support Plates	A285 Gr. C (Copper bearing)
Tube Sheets	Silicon Bronze
Water Boxes	Steel, fibre-glass lined
Tubes	Arsenical Aluminum Brass ← 1971 CHANGED TO 90-10
Number	9152
Dia. & Gauge	7/8" O.D. 18 BWG
Effective Length	29'-9-3/4"
Total Length	30'-0'1/4"
No. of Inlet Nozzles	2-54" dia.
No. of Discharge Nozzles	4-48" dia.
Water Box Design Pressure	25 psig
Design Steam Load, #/hr.	630,000
Btu Rejected, per lb. of Steam	975
Abs. Pressure, in Hg.	1.30
Circulating Water	88,000 GPM at 60°F
Cleanliness Factor	85
Oxygen Content of Condensate	0.03 cc/liter

Condenser Weights

Dry	465,000 lbs.
Operating	630,000 lbs.
Flooded	1,080,000 lbs.

#RUEI VWG DESIGN DATA HEAT BALANCE

P. L. ENGLAND UNIT 1

MODIFICATIONS BY EI 5/88

#00000 ENGLISH

010000 2 3 1 1 1 9 0.0 -1.50

***EI REMOVE DEBUG

010010 1 1 1 1 3600 160000. 0.866 30. 30. 138516.

***EI H2 P ABS?

010011 639.0 0.0

***EI REMOVE 1700.0

012000 30 50. 50.

#00201 2 *FWITER - OPTIONAL CARD TO DECREASE RUNTIME

***EI

#00002 NOPRNT

#00004 NOPRNT

#00005 NOPRNT

#00007 NOPRNT

#00006 NOPRNT

#00021 NOPRNT

#00008 NOPRNT

#00023 NOPRNT

#GEOMETRY

501010	01,	U,	02,	I
501020	02,	U,	03,	I
501030	03,	U,	04,	I
501040	04,	U,	05,	I
501050	05,	U,	06,	I
501060	06,	U,	07,	I
501070	07,	U,	08,	I
501080	08,	U,	09,	IA
501090	09,	U,	10,	I
501100	10,	U,	11,	IA
501110	11,	U,	12,	T
501120	12,	T,	13,	IA
501130	13,	U,	20,	I
501140	20,	U,	21,	I
501150	21,	U,	22,	I
501160	22,	U,	23,	I
501170	23,	U,	24,	I
501180	24,	U,	25,	I
501190	35,	U,	26,	IA
501200	25,	U,	29,	I
501210	06,	B,	13,	IB
502000	29,	D,	30,	I
502010	30,	U,	31,	I
502020	31,	B,	32,	T
502030	31,	U,	33,	T
502040	34,	U,	36,	T
502050	36,	T,	38,	T
502060	38,	D,	37,	IA
502070	37,	U,	35,	IB
502080	38,	T,	39,	T
502090	39,	T,	41,	IA
502100	39,	D,	40,	I
502110	40,	U,	41,	IB
502120	41,	U,	42,	T
502130	42,	T,	43,	T

502140	43,	T,	53,	IA
502150	10,	B,	52,	C
502160	52,	D,	51,	D
502170	51,	D,	44,	D
502180	53,	U,	44,	FW
502190	44,	D,	48,	I
502200	48,	U,	49,	I
502210	49,	B,	50,	I
502220	30,	B,	58,	I
502230	50,	U,	11,	IB
502240	49,	U,	51,	T
502250	51,	T,	52,	T
502260	43,	D,	42,	D
502270	42,	D,	39,	D
502280	57,	U,	35,	IA
502290	26,	U,	29,	D
502300	52,	T,	60,	I
502310	32,	T,	34,	IA
502320	33,	T,	34,	IB
502330	44,	B,	46,	T
502340	36,	D,	37,	IB
504010	20,	E,	51,	S
504020	21,	E,	27,	IB
504030	27,	U,	54,	IA
504040	34,	U,	44,	C
504050	22,	E,	43,	C
504060	23,	E,	42,	S
504070	24,	E,	28,	IA
504080	28,	U,	39,	S
*504090	45,	U,	44,	S
505010	04,	B,	14,	I
505020	14,	B,	15,	IB
505030	08,	B,	19,	I
505040	19,	U,	27,	IB
505050	19,	B,	15,	IA
505060	46,	T,	47,	I
505080	15,	U,	16,	I
505090	16,	U,	17,	I
505100	16,	B,	26,	IB
505110	17,	B,	38,	S
505120	17,	U,	28,	IB
505130	14,	U,	09,	IB
505140	02,	B,	18,	I
505150	18,	U,	36,	S
505160	18,	B,	61,	I
505170	47,	U,	53,	IB
505180	59,	U,	34,	IB
506010	55,	U,	29,	T
506020	29,	T,	56,	I

```

*
# MODIFY GEOMETRY FOR HP EXHAUST
501080      08,  U,  10,  I
501090      10,  U,  09,  IA
501100      09,  U,  11,  IA

```

```

#
# MODIFY GEOMETRY FOR SSR COMPONENT
505090      16,  B,  17,  I
505100      16,  U,  26,  IB
505120      17,  U,  26,  IB

```

* SPECIAL STREAM CONDITIONS

604000	2	.020619	
604010	2	.051546	
604030	2	.051357	
604050	2	.079622	***EI
604060	2	.051367	
604070	2	.051492	
601080	2	.03	
601120	2	.02	
601160	2	.02	***EI NOT RECOMMENDED IPLP

* T G CYCLE COMPONENT SPECIFICATIONS

* TURBINES

* GOVERNING STAGE

700050	08	1	2	0	1	0	1	5	.0	***EI
700055	1357.000	1456.6								
700059	1760.0	1480.4	879371.0							

* I.P.

700070	08	1	2	0	2	0	1	5	.00	***EI W5
700075	448.00	1333.0								
700079	1357.000	1456.6000	859326.0							

* I.P.

700200	08	1	0	1	3	0	1	5	.03	-29171.
700205	195.00	1433.0								
700209	406.70	1520.395	816710.0							***EI

700210	08	1	1	1	3	0	1	5	.03	-36690.
700215	109.00	1369.0								
700220	08	1	3	1	3	0	1	5	.0	-37748.
700225	54.00	1300.0								***EI W5

* I.P.

700230	08	1	0	1	4	0	2	5	.03	-33444.
700235	21.30	1220.0								
700239	52.92	1300.0	713361.0							

700240	08	1	1	1	4	0	2	5	.03	-40441.
700245	7.6390	1147.0								
700250	08	1	3	0	4	0	2	5	.0	0.0 41.1
700255	-1.500	1015.7								***EI

* BENCHMARK SOLUTION TURBINES ***EI NEW EFFICIENCIES

* GOVERNING STAGE

700050	08	1	2	0	1	0	1	1	.0	
700051	.63816	-1.297								

* I.P.

700070	08	1	2	0	2	0	1	1	.00	
700071	.67761	-3.029								

* I.P.

700200	08	1	0	1	3	0	1	3	.03	-29171.
700203	.81816	1.10441E5								
700210	08	1	1	1	3	0	1	3	.03	-36690.
700213	.54826	1.78434E5								

700220	08	1	3	1	3	0	1	1	.0	-37748.
700221	.65733	-2.610								

* I.P.

700230	08	1	0	1	4	0	2	3	.03	-33444.
700235	.90977	7.02307E5								
700240	08	1	1	1	4	0	2	3	.03	-40441.
700243	.87595	1.65631E6								
700250	08	1	3	0	4	0	2	1	.0	0.0 41.1
700251	.90355	.757								*EI

* CURRENT DEGRADED TURBINE SOLUTIONS

***EI NEW EFFICIENCIES

* GOVERNING STAGE

700050 08 1 2 0 1 0 1 1 .0

700051 .60968 -1.297

* H.P.

700070 08 1 2 0 2 0 1 1 .00

700071 .94641 -3.029

* I.F.

700200 08 1 0 1 3 0 1 3 .03 -29171.

700203 .78696 1.10441E5

700210 08 1 1 1 3 0 1 3 .03 -36690.

700213 .81706 1.78434E5

700220 08 1 3 1 3 0 1 1 .0 -37748.

700221 .82613 -2.018

* H.P.

700230 08 1 0 1 4 0 2 3 .03 -33444.

700233 .86937 7.02307E5

700240 08 1 1 1 4 0 2 3 .03 -40441.

700243 .86473 1.65031E6

700250 08 1 3 0 4 0 2 1 .0 0.0 40.1

700251 .87235 .737

*EI

*
*

* CONDENSER

700290 10 1 2 0.0 -1.5

* FEEDWATER HEATERS

700390 17 1 24 3 0.0 5.300

700420 16 1 23 3 0.0 5.20000 10.5

700430 16 0 22 3 0.0 5.200 10.4

700440 15 1 21 0.0 0.0 00.00 0.0 0.0 0.0 0.0 0.0

+ 0.0 0.0 0.0 1 8600.0 .99973

700510 18 1 20 3 0.0 0.0 10.0

700520 18 0 -10 3 0.0 -1.9 10.1

* HEAT EXCHANGERS

700120 25 2 998.57 .045011

700320 26 2 .9900

***EI COULD FIND CLOSER VALUE

700330 26 1 .9900

700460 27 -7674640.

700380 20 390.

* STEAM JET AIR EJECTOR

700360 20 0. 0. 0. 0. 0. 0. 638.75

* THROTTLE VALVE

700030 35 -2.00 -2.00 -2.00 0.3 1815. 1480.4 883000.

700031 1815. 1480.4 883000.

* PUMPS

700300 41 150.

700470 41 125.

700480 41 2393. 0.9 1.0 0.8 0.05 9.9

***EI COULD INPUT EFF&REMOVE H RISE

700400 41 125.

* MIXERS

700150 50 0

700130 50 1

700260 50 0

700270 50 1

700340 50 1
700350 50 1
700360 50 1
700370 50 0
700380 50 0
700390 50 0
700400 50 0
700410 50 0
700420 50 0
700430 50 1
700440 50 1

* SPLITTERS

700450 60 0.0 25800.
700460 61 0.0 1750.
700470 61 0.0 1000.
700480 63 3629. 58.16 1760.5
700490 63 809. 12.966 1760.5
700500 64 409.524
700510 64 507.015
700520 64 761.720

***EI SCR ADDED

700530 67 0 0.0 16. 2500.
700540 61 0.00 1370.
700550 60 0.00 77477.
700560 60 0.00 4500.
700570 63 0.00 0.5

*700450 60 1187.1 8600.

* INPUT COMPONENT

700580 33 1000.48 1615. 884750.
700590 31 82. 26. 5948.

700590 31 330.00 100.0 1952.

* OUTPUT COMPONENT

700600 32
700610 30
700620 30

* INFINITE SOURCE

700630 31 60. 21.7 45173450.97

* INFINITE SINK

700640 30

*
* CONTROLS

*
*840100 PACLEK,6,2.0045E4,0.0,1.,WW,121
*840200 PACLEK,8,9.104E3,0.0,1.,WW,503
*840300 PACLEK,19,3.052E3,0.0,1.,WW,505
*
*840400 TTVSC,1,1480.4,1.0E-4,1.0,HH,102
*840500 TTTORH,12,1522.0,1.0E-4,1.0,HH,112
*

* OPERATIONS

*
890000 1
890010 1000.
890020 HH, -101, NUL, WW, -101, OPVB,1
890030 HH, 230, NUL, WW, 230, OPVB,2
890040 HH, -110, NUL, WW, -110, OPVB,3
890050 HH, -112, NUL, WW, -112, OPVB,4
890060 OPVB, 4, SUB, OPVB, 3, OPVB, 6
890070 HH, 223, NUL, WW, 223, OPVB,7
890080 HH, -518, NUL, WW, -518, OPVB,8
890090 HH, -228, NUL, WW, -228, OPVB,9
890100 HH, -222, NUL, WW, -222, OPVB,10
***EI890009 F10.4

880100 OPVB, 1, SUB, OPVB, 2, OPVB, 11
 880110 OPVB, 11, ADD, OPVB, 6, OPVB, 12
 880120 OPVB, 12, SUB, OPVB, 7, OPVB, 13
 880130 OPVB, 13, ADD, OPVB, 8, OPVB, 14
 880140 OPVB, 14, ADD, OPVB, 9, OPVB, 15
 880150 OPVB, 15, SUB, OPVB, 10, OPVB, 16
 880160 HH, -233, MUL, WW, -233, OPVB, 17
 880170 HH, 506, MUL, WW, 506, OPVB, 18
 880180 OPVB, 17, SUB, OPVB, 18, OPVB, 19
 880190 OPVB, 18, SUB, OPVB, 19, OPVB, 20
 880200 OPVB, 16, DIV, BKGRS, 0, OPVB, 21
 880210 OPVB, 20, DIV, BKGRS, 0, OPVB, 22
 880220 OPVB, 21, DIV, OPVB, 23, OPVB, 24
 880230 OPVB, 22, DIV, OPVB, 23, OPVB, 25

* SPECIAL OUTPUT TABLE

890016 'GROSS TURBINE HEAT RATE'
 890017 OPVB, 21
 890026 'MAIN STEAM HEAT IN'
 890027 OPVB, 1
 890036 'FEEDWATER HEAT OUT'
 890037 OPVB, 2
 890046 'REHEAT STN HEAT OUT'
 890047 OPVB, 3
 890056 'REHEAT STN HEAT IN'
 890057 OPVB, 4
 890066 'NET REHEAT STN HEAT IN'
 890067 OPVB, 6
 890076 'REHEAT ATTEMP HEAT OUT'
 890077 OPVB, 7
 890086 'BLOWDOWN STN HEAT IN'
 890087 OPVB, 8
 890096 'MAKEUP WATER HEAT IN'
 890097 OPVB, 9
 890106 'MAIN STN ATTEMP HEAT OUT'
 890107 OPVB, 10
 890116 'MAIN STN HT - FW HT'
 890117 OPVB, 11
 890126 'MAIN STN HT - FW HT + NT RH ST HT IN'
 890127 OPVB, 12
 890136 'RN ST - FW + NT RH ST - RH ATT HT'
 890137 OPVB, 13
 890146 'RN ST -FW +NT RH ST - RH ATT +BD HT'
 890147 OPVB, 14
 890156 'RN ST-FW+NT RH-RH ATT+BD+MU'
 890157 OPVB, 15
 890166 'RN ST-FW+NT RH-RH ATT+BD+MU+MS ATT'
 890167 OPVB, 16
 890176 'STN TO SCA/H'
 890177 OPVB, 17
 890186 'CONDENSATE FROM SCA/H'
 890187 OPVB, 18
 890196 'NET HT TO SCA/H'
 890197 OPVB, 19
 890206 'TOT HT TO TUR CYC - HT TO SCA/H'
 890207 OPVB, 20
 890216 'GR TUR H.R. INCLUDING HT TO SCA/H'
 890217 OPVB, 24
 890226 'GR TUR H.R. EXCLUDING HT TO SCA/H'

890201 OPVB, 25
890550 'MAX CONT. 5TH FLOW'
890551 WWSO.I.928750.I

= CONDENSER HEI 85% CL 60F 90-10
700550 31 60. 21.7 53386805.00
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -1.85
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 60.0, I

= CONDENSER HEI 60% CL 40F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -1.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 40.0, I

= CONDENSER HEI 60% CL 45F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -1.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 45.0, I

= CONDENSER HEI 60% CL 50F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -1.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 50.0, I

= CONDENSER HEI 60% CL 55F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -1.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 55.0, I

= CONDENSER HEI 60% CL 60F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -1.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 60.0, I

= CONDENSER HEI 60% CL 65F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -1.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 65.0, I

= CONDENSER HEI 60% CL 70F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -1.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 70.0, I

= CONDENSER HEI 60% CL 75F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 75.0, I
/

= CONDENSER HEI 60% CL 80F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 80.0, I
/

= CONDENSER HEI 60% CL 85F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 85.0, I
/

= CONDENSER HEI 60% CL 90F 90-10
700550 31 60. 21.7 45173450.97
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -.6
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 90.0, I
/

= CONDENSER HEI 60% CL 40F 90-10 HIGHER FLOW
700550 31 60. 21.7 53386805.00
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -.60
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 40.0, I
/

= CONDENSER HEI 60% CL 45F 90-10 HIGHER FLOW
700550 31 60. 21.7 53386805.00
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -.60
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 45.0, I
/

= CONDENSER HEI 60% CL 50F 90-10 HIGHER FLOW
700550 31 60. 21.7 53386805.00
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -.60
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 50.0, I
/

= CONDENSER HEI 60% CL 55F 90-10 HIGHER FLOW
700550 31 60. 21.7 53386805.00
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -.60
890530 'CIRC WATER INLET TEMP'
890531 TTVSC , 55, 55.0, I
/

= CONDENSER HEI 60% CL 60F 90-10 HIGHER FLOW
700550 31 60. 21.7 53386805.00
700290 10 1 5 0.0 -1.5
700295 3 .826 .875 357.756 9152. 1 -.60

890530 'CIRC WATER INLET TEMP'

890531 TTVSC , 55, 60.0, I

= CONDENSER HEI 60% CL 65F 90-10 HIGHER FLOW

700550 31 60. 21.7 53386805.00

700290 10 1 5 0.0 -1.5

700295 3 .826 .875 357.756 9152. 1 -.60

890530 'CIRC WATER INLET TEMP'

890531 TTVSC , 55, 65.0, I

= CONDENSER HEI 60% CL 70F 90-10 HIGHER FLOW

700550 31 60. 21.7 53386805.00

700290 10 1 5 0.0 -1.5

700295 3 .826 .875 357.756 9152. 1 -.60

890530 'CIRC WATER INLET TEMP'

890531 TTVSC , 55, 70.0, I

= CONDENSER HEI 60% CL 75F 90-10 HIGHER FLOW

700550 31 60. 21.7 53386805.00

700290 10 1 5 0.0 -1.5

700295 3 .826 .875 357.756 9152. 1 -.60

890530 'CIRC WATER INLET TEMP'

890531 TTVSC , 55, 75.0, I

= CONDENSER HEI 60% CL 80F 90-10 HIGHER FLOW

700550 31 60. 21.7 53386805.00

700290 10 1 5 0.0 -1.5

700295 3 .826 .875 357.756 9152. 1 -.60

890530 'CIRC WATER INLET TEMP'

890531 TTVSC , 55, 80.0, I

= CONDENSER HEI 60% CL 85F 90-10 HIGHER FLOW

700550 31 60. 21.7 53386805.00

700290 10 1 5 0.0 -1.5

700295 3 .826 .875 357.756 9152. 1 -.60

890530 'CIRC WATER INLET TEMP'

890531 TTVSC , 55, 85.0, I

= CONDENSER HEI 60% CL 90F 90-10 HIGHER FLOW

700550 31 60. 21.7 53386805.00

700290 10 1 5 0.0 -1.5

700295 3 .826 .875 357.756 9152. 1 -.60

890530 'CIRC WATER INLET TEMP'

890531 TTVSC , 55, 90.0, I