

FAMOS Enhanced Fleet-Wide Monitoring

January 2020 Curtiss
Wright Plant Symposium



FAMOS



Monitoring and Diagnostics (M&D) Center Performance Monitoring

Monitoring
& Diagnostics
Center



Exelon
Generation

M + D
Center



Exelon.

Exelon Fleet Background

- Exelon operates 21 Units across 12 Sites in the Mid Atlantic, Northeast, and Midwest Regions
 - In the Mid Atlantic and Northeast Regions:
 - Nine Mile Point Units 1 & 2 (2x BWR)
 - Peach Bottom Units 1 & 2 (2x BWR)
 - James A. Fitzpatrick Nuclear Power Plant (1 x PWR)
 - Limerick Units 1 & 2 (2x BWR)
 - R.E Ginna (1 x PWR)
 - Calvert Cliffs Units 1 & 2 (2x PWR)
 - In the Midwest Region:
 - Quad Cities Units 1 & 2 (2x BWR)
 - Clinton Power Station (1x BWR)
 - LaSalle Units 1 & 2 (2x BWR)
 - Dresden Units 2 & 3 (2x BWR)
 - Braidwood Units 1 & 2 (2x PWR)
 - Byron Units 1 & 2 (2x PWR)


13 BWR Units

8 PWR Units

FAMOS Fleet Level Display

- The default homepage serves as the center for each Site's trends and reports while providing a fleet overview

16-AUG-18
15:34:00

Health 

FAMOS
FLEET ASSET MANAGEMENT OPTIMIZATION SYSTEM

Fleet Reports

Performance
vs CWT
Trends

Power History
Trends


Contacts /
Help

Exelon	Braidwood 1	Byron 1	Calvert Cliffs 1	Clinton	Dresden 2	FitzPatrick	Ginna	LaSalle 1	Limerick 1	NMP 1	Oyster Creek	Peach Bottom 2	Quad Cities 1	Three Mile Island
	Braidwood 2	Byron 2	Calvert Cliffs 2		Dresden 3			LaSalle 2	Limerick 2	NMP 2		Peach Bottom 3	Quad Cities 2	


		Exelon	Braidwood 1	Braidwood 2	Byron 1	Byron 2	Calvert Cliffs 1	Calvert Cliffs 2	Clinton	Dresden 2	Dresden 3	Fitzpatrick	Ginna
			Unit Comparison		Unit Comparison		Unit Comparison			Unit Comparison			
Ratings:			MW Loss	MW Loss	MW Loss	MW Loss	MW Loss	MW Loss	MW Loss	MW Loss	MW Loss	MW Loss	MW Loss
Licensed Reactor Thermal Power	MWth	72158.0	3645	3645	3645	3645	2737	2737	3473	2957	2957	2536	1775
Rated Unit Power (Gross/Net)	MWe	24907.7	1268	1241	1268	1241	955	945	1184.5	1003	1003	896.2	613
Generation:													
Current Reactor Thermal Power	MWth	71159.8	3640.3	3640.8	3644.5	3645.1	2734.1	2733.5	3430.0	2955.5	2955.4	2206.5	1771.2
% Reactor Power	%	98.617	99.872	99.884	99.977	99.993	99.893	99.871	98.763	99.958	99.947	87.019	99.785
Gross Generation	MWe	23410.1	1240.9	1208.9	1232.4	1200.9	919.8	898.0	1109.6	945.8	931.5	727.9	581.3
Net Generation	MWe	19117.0	1212.5	1181.9	1195.4	1149.8	885.4	860.4	1066.6	910.6	889.6	818.1	521.2
CW Pumps In Service			3	3	3	3	6	6	3	3	3	3	2
Average Circ Water Inlet Temp	°F		91.2	95.8	94.5	90.4	83.5	83.0R	85.0	87.1	85.2	78.9	39.1
Average Absolute Back Pressure	inHg		3.8	3.8	4.0	4.1	3.2	3.3	3.9	3.6	4.2	4.1	3.3
Average Expected Absolute Back Pressure	inHg		3.7	3.8	4.0	3.8	3.0	3.1	3.9	3.6	3.8	4.5	3.2
Energy Losses:													
Expected Gross Generation	MWe	23858.7	1247.0	1209.6	1236.1	1204.8	929.6	908.4	1114.3	949.8	944.3	835.7	585.1
Margin from License Reactor Power	MWe	-348.6	-1.6	-1.4	-0.3	-0.1	-1.0	-1.2	-14.1	-0.4	-0.5	-116.3	-1.4
Condenser Performance Losses	MWe	-52.7	-2.8	-0.1	-1.7	-5.4	-5.3	-4.6	0.6	-1.8	-9.8	5.4	-4.9
Feedwater Heater Performance Losses	MWe	-22.2	0.4	0.2	0.3	-2.2	-0.1	0.8	1.1	0.7	0.3	-1.9	0.3
Reheater Performance Losses	MWe	-5.5	-0.3	-0.0	0.1	0.0	-1.6	-1.2	0.7	NA	NA	-0.0	-0.1
Cycle Isolation Losses	MWe	-48.0	-1.2	-0.5	-0.2	-0.3	-0.7	-0.7	-5.4	-2.5	-2.6	0.0	0.0
Other Known Losses	MWe	-13.9	-1.4	-1.2	-0.7	-0.7	-1.6	-1.2	7.7	0.0	0.0	-0.0	0.5
Unaccounted Losses	MWe	24.8	0.7	-0.0	-0.9	-0.4	-1.6	-3.6	4.7	-0.4	3.7	6.3	3.3
Alarms:		34	0	0	0	0	1	0	0	0	0	3	2

Continuous Monitoring of Power/Performance

- Fleet overview of plant performance vs expectations based on Circ Water Inlet Temperature




- Fleet overview of power history vs. expectations
- Adjustable graphs enable close monitoring




Unit Specific MWe Advisor

- Summary of Unit Specific MWe Accounting / Balance Sheet




Unit Specific Plant Overview

- Simplified Diagram of Plant




System Specific Performance Monitoring

- Multiple Systems available to review in detail for each Unit




Dual-Unit Site Performance Comparison

- Shows performance of each unit at dual-unit sites side by side



“What If” Analysis

- Run PEPSE Analyses from PMAX Web to assess “what-if” scenarios that simulate plant changes



Cycle Isolation Valve Leakage

- Ability to monitor 2,400 cycle isolation valves modeled in PMAX with calculations included in MWe Accounting

Valve Cycle Isolation Worksheet

17-JAN-20 16:52:36 BAD 6 IVM 10 Health Alarm

Limerick Nuclear Station Unit 1

Gross MW 1172.0 Best Achievable (MW) 1230.3 Delta (MW) -58.3

Thermal Power (MWth) 3504.8 (%) 99.7

Lost MW Advisor Lost MW Event Plant Overview Reactor HP Turbine LP A LP B LP C MSs Condensers Cooling Towers FWH HP LP Pumps Generator Cycle Isolation Manual Inputs What If? Site Reports PdP Rules LGS2 Unit Compare Exelon

Update Data Entry Date JAN-17-2020 14:29:04

Before entering data, please read instructions at bottom

Cycle Isolation	Valve Name	Valve Description	Current Tailpipe Temp (°F)	Normal Temp (°F)	Threshold Temp (°F)	User Correction (0-1)	Estimated Leakage Flow (lb/hr)	ΔMW (MWe)
Cycle Isolation 1	PSV-004-105B	#5 FW HTR Relief	126.0M	125.0M	145.0M	0.75M	0.0	0.0
Cycle Isolation 2	PSV-004-105C	#5 FW HTR Relief	115.0M	120.0M	140.0M	0.75M	0.0	0.0
Cycle Isolation 3	PSV-004-106A	#6 FW HTR Relief	78.0M	100.0M	120.0M	0.75M	0.0	0.0
Cycle Isolation 4	PSV-004-106B	#6 FW HTR Relief	91.0M	100.0M	120.0M	0.75M	0.0	0.0
Cycle Isolation 5	PSV-004-106C	#6 FW HTR Relief	79.0M	115.0M	135.0M	0.75M	0.0	0.0
Cycle Isolation 6	PSV-006-103A	#6 FW HTR FW Relief	75.0M	105.0M	125.0M	0.75M	0.0	0.0
Cycle Isolation 7	PSV-006-103B	#6 FW HTR FW Relief	92.0M	130.0M	150.0M	0.75M	0.0	0.0
Cycle Isolation 8	PSV-006-103C	#6 FW HTR FW Relief	84.0M	120.0M	140.0M	0.75M	0.0	0.0
	PSV-007-103A	SJAE Cond Main Steam Supply	89.0M	95.0M	115.0M	0.75M	0.0	0.0
	PSV-007-103B	SJAE Cond Main Steam Supply	95.0M	100.0M	120.0M	0.75M	0.0	0.0
	PSV-007-151A	SSE Relief Valve	150.0M	145.0M	165.0M	0.75M	0.0	0.0
	PSV-007-151B	SSE Relief Valve	0.0M	100.0M	220.0M	0.75M	0.0	0.0
	PSV-007-151C	SSE Relief Valve	0.0M	130.0M	150.0M	0.75M	0.0	0.0
	PSV-007-151D	SSE Relief Valve	149.0M	150.0M	170.0M	0.75M	0.0	0.0
	PSV-007-151DRN	SSE Relief Valve Drain	129.0M	125.0M	145.0M	0.75M	0.0	0.0
	PSV-007-151E	SSE Relief Valve	152.0M	150.0M	170.0M	0.75M	0.0	0.0
	PSV-007-151F	SSE Relief Valve	147.0M	145.0M	165.0M	0.75M	0.0	0.0
	PSV-007-156	SSE	134.0M	130.0M	150.0M	0.75M	0.0	0.0
	PVC-007-153 DOWNSTREAM	SSE Main Steam In	273.0M	240.0M	250.0M	0.75M	25507.8	-2.7
	MSL-041-1F013A	MSL A Safety Relief Valve	142.6M	157.0M	180.0M	0.75M	0.0	0.0


Valve Total ΔMW (MWe) -6.1

Total Losses ΔMW (MWe) -6.1

Be consistent with collection of temperatures – same IR gun, don't adjust gun settings, same collection method, etc.
When using an IR gun, be aware of the surface condition/color. Flat black is best. Shiny, polished or white/light colors produce poor temperature measurements.
If using thermocouples, check issues with metal contact or drifting issues.
Changing the User Correction factor for the final estimated leakage is advised when justifying valve maintenance regardless of the conditions of the water or steam conditions upstream of valves.
Know the drawings/locations:
• Sometimes there is a header(s) upstream from pipe measurement locations producing incorrect temperature readings.
• Be aware of conduction near valve/piping - take measurements at least 10 pipe diameters downstream from valve. Don't measure at the valve stem!
• Taking measurements close to a heat source or sink (condenser) will likely provide an incorrect reading.
• Be aware of bypass orifices which are common. These generally increase the downstream temperature.

Cooling Towers

- Ability to monitor parameters related to cooling tower performance




FAMOS Lost MW Events Tracker

Reference Mwe Deviation from expected. Updated weekly to prevent flagging slow declines as “events”.

Delta between actual Mwe Deviation and Reference Mwe Deviation is trended.









Small events are not saved or reported

Events tracked and loss integrated when MW loss exceeds threshold




Fleet Reports

- Reports are designed to provide fleet overview information on-demand.
- These reports are made accessible to anyone who can access the FAMOS Web Viewer.

Energy Loss Events	Fleet Reports
 January 2019	Fleet Performance vs. CWIT  Run Report 01/17/20 12:38 PM
 February 2019	Fleet Power History  Run Report 01/17/20 06:09 AM
 March 2019	Fleet MW Accounting  Run Report 01/13/20 06:18 AM
 April 2019	Fleet Best Estimate CTP  Run Report 01/13/20 06:31 AM
 May 2019	Fleet Reactor Power Optimization  Run Report 01/06/20 01:52 PM
 June 2019	Cycle Isolation Report  Run Report 01/13/20 06:48 AM
 July 2019	
 August 2019	
 September 2019	
 October 2019	
 November 2019	
 December 2019	


Fleet Performance vs. CWIT

- Summary graphs for fleet-wide monitoring of Plant Performance vs. CWIT automatically generated



Fleet Reactor Power Optimization

- Summary of Plant and Fleet Operation approaching 100% CTP



Site Reports

- Reports are designed to provide site specific information on-demand. Additional reports including cooling towers and energy loss events are currently in development

Site Reports

Gross MW: 1172.2 | Best Achievable (MW): 1230.3 | Delta (MW): -58.0

Limerick Nuclear Station Unit 1 | Thermal Power (MWth): 3507.9 | (%): 99.8

Report Name	Run Report	Timestamp
Thermal Performance Report	Run Report	JAN-13-2020 03:32:00
MW Accounting Report	Run Report	JAN-01-2020 02:32:16
Best Estimate CTP Report	Run Report	JAN-01-2020 00:32:48
Key Performance Indicator Report	Run Report	JAN-01-2020 01:32:32
PJM Report	Run Report	OCT-15-2019 13:16:48
NERC Capability Test Report	Run Report	DEC-31-1969 19:02:03
Condenser Performance Report	Run Report	OCT-15-2019 13:16:48
Cycle Isolation Report	Run Report	JAN-15-2020 04:14:40

Cycle Isolation Losses Accounting


- For each site cycle isolation loss reports are automatically generated and made accessible as PDF's

LGS 1 Cycle Isolation and Work Management by Valve

1/17/2020


Valve	Valve Name	AR / WO #	Temp	Leakage	MW Loss
FVC-006-106B	RFP Min Flow Recirc	(blank)	167	13146	-0.14
HV-001-104-2	MSL Start-up Drn	WO 4820503	140	0	0.00
HV-006-112C-1	RFPT HP Stop VLV B Seat Drr	AR 4160823	226	83	-0.01
HV-006-122-2	Crossaround Header Drn	AR 4161480	273	2418	-0.16
HV-007-152A	Aux Steam to Air Ejector	AR 4256835	211	1239	-0.13
HVC-002-115	HP Turbine Cond Water Drn	WO 4813346	0	0	0.00
HVC-004-114A-1	#4 FW HTR Start-up Vent	WO 4813346	0	0	0.00
LVC-001-103B	Moist Sep Dump	(blank)	268	24510	-0.32
LVC-004-103C	#3 FW HTR Dump	WO 4821160	0	0	0.00
LVC-004-105A	#5 FW HTR Dump	WO 4821159	0	0	0.00
LVC-004-106A	#6 FW HTR Dump	(blank)	196	12980	-0.17
LVC-004-106B	#6 FW HTR Dump	WO 04813346	38	0	0.00
LVC-004-106C	#6 FW HTR Dump	(blank)	196	11043	-0.14
PSV-001-120C	Crossaround Relief	WO 4813346	150	23028	-1.56
PSV-007-151C	SSE Relief Valve	AR 4161478	0	0	0.00
PVC-007-153 DOWN	SSE Main Steam In	AR 4211505	273	25508	-2.73
Grand Total				113955	-5.37

LGS 1 Leaking Valves MW Loss >0.05



Site Thermal Performance Reports (POD)

- Site Thermal Performance Reports (POD) standardized and auto-generated



Site MWe Accounting Sheet

- Site's MWe Accounting Reports are standardized and automatically generated through FAMOS

MW Accounting Balance Sheet				
Calvert Cliffs Nuclear Station				
Report from 7/9/2018 For 4 hours	Unit 1		Unit 2	
Item	Actual	Expected	Actual	Expected
Reactor Power (MWth)	2733.5	2737.0	2734.1	2737.0
Reactor Power (%)	99.9	100.0	99.9	100.0
Gross Generation (MWe)	932.4	934.9	911.0	916.7
Gross Heat Rate (Btu/kwh)	10064.0	10037.0	10302.2	10238.3
Net Generation (MWe)	896.6	897.9	874.0	880.7
Net Heat Rate (Btu/kwh)	10466.5	10450.5	10737.9	10656.8
Auxiliary Power (Mwe)	36.5	37.0	37.0	36.0
MW Deviations				
	Unit 1	Unit 2		
Recoverable Losses	-1.7	-1.5		
Unrecoverable Losses	0.8	-0.1		
Total Accounted MW Deviations	-0.9	-1.7		
Unaccounted MW Deviations	-1.6	-4.0		
Recoverable Losses				
	Unit 1	Unit 2		
Reactor Power Less than 100%	-1.2	-0.9		
Condenser and CW Performance	1.6	0.4		
Off-nominal MSR Operation/Condition	-1.3	-0.9		
Generator Electrical Loss Adjustment	0.0	0.0		
Off-nominal FW Heater Performance	-0.1	0.6		
Cycle Isolation and Valve Leakage	-0.7	-0.7		
Feedwater Errors	0.0	0.0		
Other Abnormal Operation or Line-up	0.0	0.0		
Unrecoverable Losses				
	Unit 1	Unit 2		
Turb. Des. Doesn't Match Rx Licensed Pwr	0.0	0.0		
FW Heater Variations and Adjustments	0.0	0.0		
MSR Variations and Adjustments	0.8	0.0		
RWCU & CRD Flow Var./Adjust. (BWRs)	NA	NA		
HP & LP Turbine Shortfall from Design	0.0	NA		
Operation Condition Variations	-0.1	0.1		
Reactor Recirc. Pump Power Var. (BWRs)	NA	NA		
Steam Generation Blowdown (PWRs)	0.1	NA		
Generation Electrical Losss Adjustment	0.0	0.0		
Other Unrecoverable Effects	0.0	0.0		
External Losses				
	Unit 1	Unit 2		
Cooling Tower Performance Loss Effect	NA	NA		
External Issues Affecting Generation	0.0	0.0		

Next Steps

- Performing independent assessment of FAMOS/PMAX Tool to verify accuracy and capability
- Continue Webinar training and provide additional mentoring and training for Corporate Thermal Performance Engineers
- Continue refinement of PMAX and PEPSE Models
- Additional points to be added to models for enhanced monitoring
- Site and Fleet reports are to be enhanced and updated and additional reports are to be created.
- Several new displays to be added and existing displays enhancements.
- Add DVR (data validation & reconciliation) points to R*Time and PMAX display.
- Provide additional “What-If” capabilities.

Questions?

FAMOS Enhanced
Fleet-Wide Monitoring

