

Cooling Towers Real Time Performance Monitoring

EPRI Cooling Tower Technology Conference - 2018

Jeff Marion – Exelon

Greg Alder – Curtiss-Wright




Exelon Generation®

Cooling Tower Purpose

- Remove heat from circulating water system
- Principal of operation:
 - Use cool air flow to remove sensible and latent heat from circulating water by heat transfer and evaporation
 - Air is heated as it passes through the circulating water spray decreasing density and providing buoyancy to maintain flow (natural draft) or fans (mechanical draft) are used to push or pull air through the tower
- Types:
 - Natural Draft Cooling Tower
 - Mechanical Draft Cooling Tower

Cooling Tower Operational Theory




A cooling tower is a heat exchanger where two fluids (air and water) are brought into direct contact.

The heat gained by the air equals the heat lost by the water

$$G(h_2 - h_1) = L(t_1 - t_2)$$

- G = Mass flow of dry air lbm/min
- h_1 = Enthalpy of entering air btu/lbm (dry air)
- h_2 = Enthalpy of leaving air btu/lbm (dry air)
- L = Mass flow of water lb/min
- t_1 = Hot water temperature entering tower
- t_2 = cold water temperature leaving tower

Cooling Tower Temperature Relationships



Cooling Tower Performance Calculation – Input Parameters

- WBT (Wet Bulb Temperature)
- DBT (Dry Bulb Temperature)
- RH (Relative Humidity) ● ● ●
- CWT (Cold Water Temperature)
- HWT (Hot Water Temperature)
- CW Flow (Circulating Water)
- Fan Horse Power

When $RH = 100\%$, the air is not able to hold any more water and so water will not evaporate in 100% humid air ($WBT = DBT$). But when the RH is less than 100%, the WBT will be less than the DBT and water will evaporate.



Performance Calculation Results & Definitions

- Cooling Tower Range = HWT minus CWT
- Cooling Tower Approach = CWT minus WBT
 - lower is better; good parameter to trend
 - approach changes are inverse to airflow passing through tower
 - airflow in natural draft towers is a function of buoyancy from air density delta between inside to outside of tower
- Predicted CW Flow
 - obtained from manufacturer design curves and input parameters
- Capability = Ratio of actual and predicted CW flow
 - actual flow corrected for fan power in mechanical draft towers
- Predicted CWT
 - obtained from manufacturer design curves and input parameters
- Generation Impact
 - difference in generation based upon actual and predicted CWTs

Cooling Tower Capability

- The capability is an indicator of how close the tower is able to bring the CWT to the WBT of the incoming air (lower approach).
- A larger cooling tower [i.e. moves more air and/or has more fill] will produce a lower approach for a given heat load, flow rate and entering air condition.
- The lower the WBT (indicates either cool air, low humidity or a combination of the two) the better the tower can cool the water.
 - the thermal performance of the cooling tower is thus affected by the entering WBT

Cooling Tower Predicted CW Flow and Temperatures

- Obtained using set of manufacturers performance curves
- Curve outputs include:
 - CWT
- Curve inputs include:
 - WBT
 - Range
 - RH

The Following Slides Show Step by Step How to Calculate Predicted CW Flow and Capability

Step 1: Collect Curve Input Data (test or real-time)

Step 1: Test Data		
Parameter	Reading	Units
Flow	9500	gpm
CWT	85	Deg F
WBT	79.8	Deg F
Range	28	Deg F
Fan Power	110	HP


Step 2: Read Predicted Values from Curves

Step 2: Read Predicted Values From Vendor Supplied Performance Curves at Measured Wet Bulb Temperature and CW Flows

Step 2 Plot Perf. Curve Data			
Range	9000	10000	11000
24	83.9	84.5	85.0
30	84.3	85.1	85.9
36	84.5	85.2	86.4


Cooling Tower Performance Curve – 9000 GPM

9000 gpm vendor performance curve




Cooling Tower Performance Curve -10000 GPM

10000 gpm vendor performance curve



Cooling Tower Performance Curve -11000 GPM




Step 3: Use Step 2 Data to Produce CWT/Range Curves

- Plot data from Step 2 to produce CWT vs. Range Curves.
- Solve for each flow curve at the range measured by the input data.

Step 3: Plot CWT vs Range	
Flow rate	CWT
11000	85.7
10000	85.0
9000	84.2

Step 3: Use Step 2 Data to Produce CWT/Range Curves

Plot CWT VS Range for all flows (Step 3)




Step 4: Determine Predicted CW Flow

Step 4: Determine Predicted CW Flow

- Cross plot Step 4 graph to produce a CWT vs. Predicted CW Flow curve.
- Read from this curve the Predicted CW Flow at the measured CWT.

Step 4: Plot CWT vs. Predicted Flow

Plot of CWT vs Predicted Flow and test range and Wet Bulb Temperature (step 4)



Step 5: Correct Actual CW Flow for Fan Power


Adjusted Test Flow =

Test Flow * (Design Fan HP/Test Fan HP)^{1/3}

Design Fan HP = 120

Measured Fan HP = 108

Adjusted Test Flow = 9500 * (120/108)^{1/3} = 9780 gpm



Mechanical Draft only.
Natural draft has no flow
correction.

Step 6: Calculate Cooling Tower Capability

$$\% \text{ CAPABILITY} = \frac{\text{ADJUSTED CW FLOW}}{\text{PREDICTED CW FLOW}} \times 100$$

$$\% \text{ CAPABILITY} = \frac{9780 \text{ GPM}}{10024 \text{ GPM}} \times 100 = 97.56\%$$

Exelon Nuclear Units with Cooling Towers

- Byron Unit 1 & 2 (Counterflow Conversion from Cross flow)
- Nine Mile Point Unit 2 (Counterflow)
- Limerick Unit 1 & 2 (Crossflow)
- TMI A (Counterflow Conversion) & B (Crossflow)
- Dresden 2 & 3 (Mechanical Draft, Counterflow)
- Peach Bottom 2 & 3 (Mechanical Draft, Crossflow)

Byron 1 & 2 (Counterflow Conversion from Crossflow)




Exelon Cooling Tower Thermal Performance Background

Background:

- Cooling tower monitoring with Excel lacked functionality due to software upgrades and using off-line data
- PMAX, a recently available real-time cooling tower monitoring tool needed verification to be used as a replacement to Excel based performance calculations

Goals:

- Audit the site-specific spreadsheets and PMAX engineering models and then compare to ensure accurate performance monitoring of cooling towers
- Replace site-specific spreadsheets with PMAX



Exelon Cooling Tower Calculation (Excel Based)

Exelon Nuclear		Cooling Tower Capability Calculation (Q)	
		Exelon Nuclear Fleet	
Byron 1 NDCT		Select site at left (in RED)	
		These blocks are formulas DO NOT EDIT	
Start Date	mm/dd/yy hh:mm:ss	7/5/18 1:00 PM	Type in your start time at left
End Date	hrs	7/5/18 2:00 PM	
Window length	hrs	1	
Wet bulb temperature	deg F	72.7	
Dry bulb temperature	deg F	80.4	
Barometric pressure	psia	14.7	
Relative humidity	%	69.4	
Inlet (hot) water temperature	deg F	117.7	
Outlet (cold) water temperature	deg F	91.5	
Range	deg F	26.2	
MDCT only- Fan Driver Power (test)	bhp	#N/A	
MDCT ONLY-Fan Driver Power (design)	bhp	#N/A	
Design Water Flow Rate	gpm	726750.000	
Circ water flow rate (test)	gpm	712154.8	
Predicted Circ Water Flow	gpm	753314.8	
Tower Capability (Q)	%	94.54	

Cooling Tower

MET TOWER

Air

Water

Pump

Measured -Temperature of Hot water

Measured -Temperature of Cold water

PMAX Real-Time Cooling Tower Performance Displays (web based)



Exelon Real-Time Cooling Tower Performance Display

24-JUL-18
15:13:46

BAD 16
IVM 4

Health ●
Alarm ●

Cooling Tower

Gross MW 1235.1

Best Achievable (MW) 1238.2

Delta (MW) -3.1

Byron Nuclear Station Unit 1

Thermal Power (MWth) 3641.5

(%) 99.9

Lost MW Advisor

Plant Overview

Steam Generator

HP Turbine

LP A

LP B

LP C

MSRs

Condensers

Cooling Towers

FWH

HP

LP

Pumps

Generator

Cycle Isolation

Manual Inputs

What If?

Site Reports

PdP

Rules

BYR2


Unit Compare

Exelon


Ambient Conditions		Ground	Met Tower
Pressure	psia	14.7	
Pressure	in. hg	29.9	
Temperature	°F	80.6	80.4
Relative Humidity	%	55.1	
Wet Bulb Temperature	°F	68.8	
Dew Point Temperature	°F	62.8	62.8R

Wind		@ 30 Feet	@ 250 Feet
Speed	mph	9	11
Direction	deg	322	

Cooling Tower Performance		Value
Hot Water Temperature	°F	116.4
Cold Water Temperature	°F	93.6
Cooling Tower Range	°F	22.6
Cooling Tower Approach	°F	24.8
Circ Water Flow	GPM	727628
Circ Water Flow (predicted)	GPM	841476
Capability	%	86.5



		Actual	Expected	Δ
Basin Temp	°F	93.6	89.6	4.1



Start Time: 07/24/2018 13:07:49

Archive Rate: 5 minutes

End Time: 07/24/2018 15:07:49

Update Rate: 1 minutes

Exelon Real-Time Condenser Performance Display

24-JUL-18
15:27:29
BAD 15
IVM 4
Health ●
Alarm ●

Condensers

Gross MW 1234.8 Best Achievable (MW) 1238.0 Delta (MW) -3.2

Byron Nuclear Station Unit 1
Thermal Power (MWth) 3643.3 (%) 100.0

Lost MW Advisor | Plant Overview | Steam Generator | HP Turbine LP A LP B LP C | MSRs | Condensers | Cooling Towers | FWH HP LP | Pumps | Generator | Cycle Isolation | Manual Inputs | What If? | Site Reports | PdP | Rules | **BYR2** | Unit Compare | Exelon

Circ Water Conditions	Cond A	Cond B	Cond C
Inlet Temp (°F)	93.7	101.6	108.8
Outlet Temp (°F)	102.5	110.8	116.3
Temp Rise (°F)	8.0	7.4	7.4
Flow (mlb/hr)	357.1	357.1	357.1
Flow (kgpm)	718.9	718.9	718.9
Flow (kgpm)*	729.2	729.2	729.2

CWP OOS

CW Flow Normal

Circ Water Conditions	Wbox A	Wbox B	Wbox C	Wbox D
Waterbox DT (°F)	21.2	20.1	24.7	24.6


Performance Indices	Cond A	Cond B	Cond C
Heat Duty (MBtu/hr)	2858.0	2624.8	2611.6
Heat Duty (MBtu/hr)*	2892.4	2670.2	2672.1
HTC (Btu/hr-°F-ft)	384.6	418.9	412.5
TTD (°F)	16.5	15.3	13.7

*Power Method

Cleanliness Factor	Actual	Expected	Δ
Condenser A	0.94	0.90	0.04
Condenser B	0.92	0.90	0.02
Condenser C	0.92	0.90	0.01

Subcooling (°F)	Actual	Expected	Δ	MW Effect
Condenser	0.0	0.0	0.0	0.0


Condenser Sub Cooling



Steam Conditions	Cond A	Cond B	Cond C
Flow (mlb/hr)	2.78	2.77	2.78
Pressure (in hga)	3.27	3.86	4.50
Hood Temp (°F)	119.6	122.2	131.3
Hood Press (in hga)	3.41	3.66	4.69





Condenser Drain Inlet	Cond A	Cond B	Cond C
Flow (mlb/hr)	1.04	4.63	8.28
Enthalpy (Btu/lb)	317.0	94.64	97.1
Back Pressure (in hga)	Average	Expected	MW Effect
Condenser Performance	3.9	3.9	-0.28

Hotwell Levels (inches)




Air In Leak Indicators	Cation	Specific
Conductivity (umhos)	23.99	10.18
Dissolved O2 (%)	23.24	
Total CW Flow	Actual	Design
Flow (kgpm)	718.9	741.0

Generation vs ABP Actual (MW) Expected (MW)



Sample Cooling Tower Performance Trend

– Approach and Range



Sample Cooling Tower Performance Weekly Report


Cooling Tower Report

Byron Nuclear Station

7/24/2018

Tag Description	Units	Unit 1	Unit 2
Wet Bulb Temperature	Deg F	68.5	64.2
Dry Bulb Temperature	Deg F	80.3	80.3
Dew Point Temperature	Deg F	62.5	62.4
Barometric Pressure	psia	14.7	14.7
Relative Humidity	%	55.1	40.8
Inlet Water Temperature	Deg F	116.4	113.6
Outlet Water Temperature	Deg F	93.7	89.5
PMAX Calculated Water Flow Rate	gpm	728330	694984
Predicted Water Flow Rate	gpm	848677	799430
Tower Capability	%	85.8	86.9
Predicted Outlet Water Temp	Deg F	89.4	87.6
Range	Deg F	22.6	24.1
Approach	Deg F	25.2	25.3
MW Impact	MWe	-9.1	-3.2

Byron Cooling Tower Capability (%)



Exelon Cooling Tower Thermal Performance Overview

Results :

- Excel spreadsheets and PMAX models were reviewed and updated as needed
- Side by side comparison was made between spreadsheets and PMAX using the same input data
- Deltas identified between PMAX and spreadsheets and modifications made as needed to ensure accuracy in the PMAX including instrument validation
- CW flow interpolation issue found and resolved

Benefits:

- Will allow M&D center to trend real-time cooling tower performance reliably using web based displays and utilities
- PMAX will also monitor long term performance (archived results), which facilitates maintenance decisions
- Excel sheet will be replaced using PMAX
 - PMAX uses real-time data and validates input
 - PMAX has a more accurate methodology for calculating flow

Conclusion

- Cooling tower performance results are calculated and presented in real-time
- Instruments can be validated before entering performance calculations
- Cooling tower performance calculation inputs and results are archived and available for trends, reports (automated and manual), alarm checks, and diagnostics
- Web based displays presenting cooling tower performance information are available to all users within the utility to assist with quickly finding thermal performance issues quickly



Questions?