


JANUARY 2017

Integrating Scientech PdP recommendations into NSP Asset Management Systems


Nova Scotia's Renewable Energy Transformation

- 25% Renewable Energy by 2015
- 40% Renewable Energy by 2020
- Peak demand : 2100 MWLow load: 625 MW
- Wind Generation: >600 MW





The NSP Asset Management Pyramid





NSP AMO IT Toolkit

System	Vendor	Usage
Meridium	GE	Measurement and Recommendation storage, Elog,GAA, KPIs
Directline	Megamation	Work Management
FAMOS	Scientech	Heat Loss and Predictive Analytics
Aware	Intertek	Boiler Maintenance/Inspections and Unit Life Assessment
CBT	Inhouse	Competency Based Training and Operations Procedure Review
SharePoint	Microsoft	Storage and Organization of RCA and 3rd party Assessments
Microsoft Office	Microsoft	Access for specialty reporting (DAFOR), Excel for targeted lists



IT Security Considerations

- Scientech Technicians have NSP VPN network access
- Scientech Technicians have NSP network accounts
- Scientech Technicians have administrative access to the FAMOS servers
- Scientech Technicians have Meridium accounts



FAMOS Recommendation Capture(Business Process):




Scientech Analyst



Event Sources(Weekly):


M&D Surveillance Review Data History Review Previous Findings



Email Review Weekly Recommendations




Meridium Recommendation Entry





Meridium Recommendation Entry







Anomaly Detection Report

Station: Lingan

Unit: 4

Model: 4bBFPpm


PI Point: LG4VID_TE4505

Date : March 23, 2015

Anomaly: The IB Bearing Temp on BFP B increased after the 3/17/15 pump start-up and is currently operating 7-12 deg. C above predicted temps. Verify sensor calibration.

Check lube oil supply to bearing.


PdP Web Viewer Trend



Meridium Recommendation Entry Time: 20 minutes/entry 5-7 Entries per week, 2 hours per week



PdP Recommendations Query



Pd	PdP_Recommendations_All : Select Query											
Plant	Recommendation ID	Model	Sensor	Functional Location ID	Functional Location Descrip	Work Order Number	Status	Recommendation Headline	Recommendation Description	Creation Date	NSP Work Request Generated	Reference Document
▶ LIN	REC-16823	4ESPTR 12	LG4VID_TR1PRIMVOLTS	43325001	ELECTRO-STATIC PRECIPITATORS		CREATED	(1) High	The Primary Voltage on TR1 decreased sharply	2017-01-17 10:29:56	False	201728537 RCID.pptx
LIN	REC-16822	3bBFPpm	LG3VID_TE4497	34311002	B-BOILER FEED PUMP -		CREATED	(1) High	3B BFP Thrust Bearing Temperature is gradually	2017-01-16 14:40:58	False	201513868 RCID.pptx
LIN	REC-16801	4bAirHtr	LG4VID_TE0321B	43324002	B-LJUNGSTRUM AIR HEATER		CREATED	(3) Low	4B Air Heater Air Outlet Temperature (B) has	2017-01-10 12:38:54	True	199950191 RCID.pptx
LIN	REC-16722	2bBFPpm	LG2VID_TE4513	24311002	B-BOILER FEED PUMP	383728	CREATED	(2) Medium	BFP B Motor OB Bearing Temperature has	2016-12-26 11:53:22	True	196181151 RCID.pptx
LIN	REC-16699	3aAirHtr	LG3VID_TE0552	33324001	A-LJUNGSTRUM AIR HEATER	383668	CREATED	(1) High	Air Heater A Bottom Bearing Temperature	2016-12-20 10:52:12	True	194755596 RCID.pptx
LIN	REC-16693	2aCWP	LG2VID_TE5396A	24221001	A-CIRCULATING WATER PUMP	383669	CREATED	(1) High	CWP A Motor Phase C Winding Temperature	2016-12-19 14:11:59	True	194532658 RCID.pptx
LIN	REC-16658	3BOILR	LG3VID_BNRTILTPOSN1	3331	BOILER	383086	CREATED	(2) Medium	The indicated Burner Tilt Position 1 failed on	2016-12-13 10:00:45	True	192948701 RCID.pptx
LIN	REC-16636	4HPFWHp	LG4LIT4750	44314006	NO.6 HIGH PRESSURE HEATER	382880	CREATED	(2) Medium	Heater #6 Level has been indicating flat-line	2016-12-06 13:45:52	True	191218748 RCID.pptx
LIN	REC-16623	2bAirHtr	LD2VID_AIRINTEMPB	23324002	B-LJUNGSTRUM AIR HEATER	382881	CREATED	(3) Low	Sensor data for the Air Heater B Air Inlet	2016-12-06 09:04:42	True	191169993 RCID.pptx
LIN	REC-16523	1GENR	LG1VID_PIT3286	1412	GENERATOR & AUXILIARIES	382658	CREATED	(1) High	Since 11/10/16 there has been a gradual	2016-11-29 11:18:28	True	189611627 RCID.pptx
LIN	REC-16456	4GENR	LG4VID_TE3296B	4412	GENERATOR & AUXILIARIES	382454	CREATED	(1) High	The Generator Bearing 6 Outlet Oil	2016-11-22 14:08:41	True	188022050 RCID.pptx
LIN	REC-16453	1HP-IPp	LG1VID_GOVPOSITION	14116100	TURBINE HIGH PRESSURE SECTION	382455	CREATED	(3) Low	The indicated Governor Position decreased	2016-11-21 12:46:28	True	187770314 RCID.pptx
LIN	REC-16450	4aMILLpm	LG4VID_MILLA_OUTPRS	43531001	A-COAL PULVERIZER	382456	CREATED	(2) Medium	Mill A Outlet Pressure has been gradually	2016-11-21 09:12:11	True	187735150 RCID.pptx
LIN	REC-16426	4dMILLpm	LG4VID_TE5355	43531004	D-COAL PULVERIZER	382457	CREATED	(1) High	Mill D Motor DE Bearing Temperature has been	2016-11-15 13:29:08	True	186464323 RCID.pptx
LIN	REC-16422	4DAHTRp	LG4VID_AIT4947	44337003	DA HEATER VESSEL	382458	CREATED	(2) Medium	The Deaerator Outlet Dissolved O2 has been	2016-11-15 11:30:50	True	186447221 RCID.pptx
LIN	REC-16421	4aMILLpm	MILLAFDRPV	43531001	A-COAL PULVERIZER	382459	CREATED	(3) Low	4A Mill Feeder Speed has been operating 2-3	2016-11-15 09:35:50	True	186424677 RCID.pptx



FAMOS Recommendations

From:

To:

MCKINNON, M 1;
MEDECKI, JERRY;
MACLELLAN, RYAN;
DEANE, DAVID;
STEVENS, TONY;
DOBSON, ROY;
TAIT, JASON;
JORDAN, FRED;
SMITH, JEREMY;
LEWIS, JACK;
ANTLE, DION;
BUJOLD, JIM;
MACISAAC, CLETUS;
CROWDIS, TYLER;
DICKSON, ANDREW;
NOW
CO:
MACNELL, JEFREY

Co:
MACNELL, ROBERT;
CARLIN, GREG;
RODGERS, WARREN;
KIBBLE, GAVIN;
MACINTOSH, JONATHAN;
MCNEIL, BLAISE;
CONDON, SHANE;
REFENE, MIKE;
MACNELL, ERIN;
Raithby, Scott

FW: 16-10-28 Weekly PdP Report For Your Review

Work requests will be created for the following:

From: Nedrow, Scott [mailto:SNedrow@CURTISSWRIGHT.com]

Sent: Monday, October 31, 2016 6:15 PM

To: Herzau, James; MACNEIL, ROBERT; TOMPKINS, JOAN; KIBBLE, GAVIN; RODGERS, WARREN; CARLIN, GREG; CONDON, SHANE; MACNEIL, ERIN; MACINTOSH, JONATHAN

Cc: Brower, James; Alder, Greg; Kosak, James; GREENE, MIKE

Subject: 16-10-28 Weekly PdP Report For Your Review

M & D Weekly Overview

Date: 10/22 to 10/28

Units Reviewed: LIN1, LIN2, LIN4, POA1, TRE6, TUC2, TUC3, TUP2, TUC6, TUC4

Issues reported: 6


Issues reviewed: 0

Models tuned: 0

				Functional		Work						
1	Recommendation			Location		Order		Recommendation	Recommendation		NSP Work Request	
Plant	ID	Model	Sensor	ID	Functional Location Descrip	Number	Status	Headline	Description	Creation Date	Generated	Reference Document
									The I/B Bearing			
									Temperature on FD Fan			
									A is displaying periods of			
									erratic sensor output			
									with extremely high			
									temperature spikes.			
									Inspect sensor			
									installation/connections.			
									Replace sensor if			
									required.	10/25/2016		
LIN	REC-16324	2aFDFNp	LG2VID_TE0556	23321001	A-FORCED DRAFT FAN		CREATED	(1) High	(LG2VID_TE0556)	10:47	FALSE	181697097_RCID.pptx
									The Generator H2 Purity			
									decreased rapidly on			
									10/26/16 by more than			
									4%. Verify current H2			
									purity. Add H2 if			
									required.	10/27/2016		
TRE	REC-16350	6GENRr	TR6VID_A3702	64113	GENERATOR		CREATED	(1) High	(TR6VID_A3702)	10:33	FALSE	182172716_RCID.pptx
									T 1: 5 : 0V			



Closing the Loop on WO Recommendations



CREATED

CREATED

COMPLETED

SC

WC


Scheduled by PM system

Scoping Required

Work Complete




Meridium Interfaces





Operational Risk Policy






Meridium Policy Advantages

- Can do fuzzy logic
- Inputs can be manual readings, PI tag values, Recommendations, standard math
- Result of Policy can update a Health Indicator
- Result of Policy can send email notification
- Policy execution can be scheduled at any interval



PdP Recommendations integrated with other types






Recommendations from varying business sources






PdP Recommendations by Plant






PdP Recommendations by Equipment Class






What's Next? (Wireless Instruments and IoT)






What's Next? (Remote Access to System 1 Console





What's Next? (Mobile Work Management)





What's Next? (Mobile Operator Rounds)

