

**INTERPRETING A THERMAL KIT**

**Michael Hunt**

**Louisiana Power & Light Company**

## INTERPRETING A THERMAL KIT

### ABSTRACT

Proper interpretation and application of the turbine vendor thermal kit are the keys to developing a good PEPSE model.

This paper will discuss thermal kit methodology and how to properly apply this information when making PEPSE analyses.

Users are asked to submit in advance any questionable thermal kit information for inclusion in the presentation.

# PREDICTING THE PERFORMANCE OF 1800-RPM LARGE STEAM TURBINE-GENERATORS OPERATING WITH LIGHT WATER-COOLED REACTORS

F. G. Baily, J. A. Booth, K. C. Cotton and E. H. Miller

*Steam Turbine-Generator Products Division  
General Electric Company  
Schenectady, New York*




TABLE I

**EFFICIENCY CALCULATION PROCEDURES**  
(Corrections are multiplying factors)

TURBINE SECTION	LOW PRESSURE						
	HIGH PRESSURE			NONCONDENSING			
	NONCONDENSING			CONDENSING			
Column	1	2	3	4	5	6	7
Bowl conditions	Wet to 100 F superheat	Superheated	Superheated	Saturated/Wet	Superheated	Superheated	Saturated/Wet
Exhaust conditions	Wet	Superheated	Saturated	Wet	Superheated	Saturated	Wet
Note	1	2	3	1	2	3	1
<b>EFFICIENCY CALCULATION:</b>							
Base efficiency	Fig. 3	Fig. 3	Fig. 3	Fig. 4	Fig. 3	Fig. 3	Fig. 4
Initial volume flow, correction	----	----	----	Fig. 5	----	----	Fig. 5
Governing stage correction	Fig. 1A-C	----	----	----	----	----	----
Moisture, correction	Fig. 2	----	----	Fig. 7	----	----	Fig. 7
<b>END POINT CORRECTION:</b>							
Condensing exhaust pressure	----	----	----	----	Fig. 14, 16	----	Fig. 14, 15
Exhaust loss	Fig. 8	Fig. 8	----	Fig. 8	Fig. 14, 16	----	Fig. 14, 16


NOTE: 1) Use AE from equilibrium properties, superheated or saturated/wet, as appropriate.

2) Use AE from equilibrium, superheat properties when the isentrope ends in the superheat region.  
Use AE from Fig. 9, supersaturated enthalpy when the isentrope ends in the moisture region.

3) Columns 3 and 6 are used to calculate the dry portion of the superheated to wet expansion - that is, from the bowl to the saturation line.  
The following column, 4 or 7, is used to calculate the wet portion of the expansion - that is, from the saturation line to exhaust.

For superheated bowl to saturation line expansion (Columns 3 and 6), use AE from Fig. 9, supersaturated enthalpy.

CHANGE IN EXPANSION LINE END POINT WITH 0 PERCENT MOISTURE (BTU/LB)



- (1) When expansion line end point at 1.5 in. Hga is in the Moisture Region, use the following equation:  
 $\Delta ELEP = \Delta ELEP_{M=0} (0.87)(1-0.01M)(1-0.0065M)$   
 M=Percent moisture at ELEP at 1.5 in. Hga.
- (2) When the expansion line end point at 1.5 in. Hga is in the superheat region multiply the change in expansion line end point at 0 percent moisture both by the factor 0.87 and the ratio of specific volume at the expansion line end point under consideration to the dry saturated specific volume at 1.5 in. Hga.

EXHAUST PRESSURE (IN. HGA)

Fig. 15. Correction to expansion line end point for exhaust pressure

698 VH 52E

406,500 KW @ 3.5" HG. ABS. 3% MU  
TC4F-26" LSB 3600 RPM  
2400 PSIG 1000°/1000°F

EXTRACTION STAGE SHELL PRESSURES

TO DETERMINE THE EXTRACTION STAGE SHELL PRESSURE MULTIPLY  
THE FOLLOWING FACTORS BY:  $\frac{\text{FLOW TO THE FOLLOWING STAGE}}{10^6}$

EXTR. NO.	1	2	3 (XO)	4	5	6	7
FACTOR	187.6	95.5	59.0	37.9	15.7	10.1	6.1

NOTE:

1. APPLY THE FACTOR FOR EXTRACTION NO. 1 TO THE FLOW TO THE FIRST REHEAT STAGE TO DETERMINE THE PRESSURE AHEAD OF THE INTERCEPT VALVE. HIGH PRESSURE TURBINE EXHAUST FLANGE PRESSURE EQUALS PRESSURE AHEAD OF THE INTERCEPT VALVE DIVIDED BY 0.90.
2. FLOW TO FOLLOWING STAGE EQUALS THROTTLE FLOW MINUS LEAKAGES AND ALL EXTRACTIONS FROM PRECEDING STAGES AND STAGE IN QUESTION PLUS ANY STEAM RETURNED TO THE TURBINE AHEAD OF THE STAGE IN QUESTION.
3. USE 3% PRESSURE DROP BETWEEN SHELL STAGE PRESSURE AND TURBINE SHELL FLANGE PRESSURE EXCEPT WHERE EXTRACTIONS ARE AT THE END OF A SHELL CASING.
4. THESE FACTORS ARE TO BE APPLIED FOR HEAT BALANCE CALCULATIONS AT RATED STEAM TEMPERATURES ONLY.
5. THE GENERAL ELECTRIC CO. RECOMMENDS THAT EXTRACTION PIPING AND FEEDWATER HEATERS BE DESIGNED FOR 15% GREATER PRESSURE THAN THAT OBTAINED AT MAXIMUM GUARANTEE THROTTLE FLOW TO ALLOW FOR POSSIBLE VARIATIONS OF EXTRACTION PRESSURES FROM EXPECTED VALUES DUE TO MANUFACTURING TOLERANCE ON DRAWING AREAS, FLOW COEFFICIENTS, DEPOSITS IN STEAM PATHS, ETC.


GENERAL ELECTRIC COMPANY  
SCHENECTADY, NEW YORK

1/7/63

325 HA 869

*R.C. L.A. Eisen*

2915-174R-0






# LOUISIANA POWER AND LIGHT

Vapor (dry) Pipes T and 2

TP - Turbine - E-W - Pressure

(2412)



Reheat steam flow  $\times 10^3$  (lb/hr)

5/7/76


Y 635 - 0309 b

5/7/76

Engineering Division







SIGNATURE JHL/JLW

DATE 11/30/72

CURVE NO. AE085-0508

D-1171-9167

Unit 2




Figure 16



EXHAUST LOSS CURVE

LAST ROW BLADE LENGTH = 40.0"  
 LAST ROW MEAN DIAMETER = 120.0"  
 LAST ROW ANNULUS AREA = 105.7 FT<sup>2</sup>

HELEP =  $h_{TEP} - e_{TEL}$  (1-.01M)  
 $\Delta h_{TEP} = \Delta h_{ELEP}$  (1-.01M)


WHERE:

- HELEP = ENTHALPY @ EXPANSION LINE END POINT
  - $h_{TEP}$  = ENTHALPY @ TURBINE END POINT
  - ELEP = EFFECTIVE TOTAL EXHAUST LOSS
  - M = % MOISTURE @ EXPANSION LINE END POINT
- EXHAUST VOLUMETRIC FLOW BASED ON SPECIFIC VOLUME AT EXPANSION LINE END POINT

$V_{ELEP} \approx V_{DS}$  (1-.01M)

EXHAUST PRESSURE (IN. HGA.)


0.5	1256.6
1.0	652.4
1.5	445.0
2.0	339.3
2.5	275.0
3.0	231.6
3.5	200.3



EXHAUST VOLUMETRIC FLOW PER END - FT<sup>3</sup>/HR X 10<sup>6</sup>



AX913-0007






CLEARPRINT CHARTS

# LOUISIANA POWER AND LIGHT

Waterford units 1 and 2  
Expansion on line and points



6/1/65

Northwest Union  
Y. 653 - 0309  
5/11/65

2000  
2500

Projected steam flow x 10<sup>6</sup> (lb/hr)

Density

high pressure turbine


3.5' low diameter turbine

2.5'

2.0'

0.5'





MOLLER CHART  
 ENTHALPY-ENTROPY DIAGRAM  
 1957 ASME STEAM TABLES

LOUISIANA POWER PLANT


Reheat and Units 1 and 2


EXPANSION LINES  
 (Throttle Controlled)

- 1) 100% Flow
- 2) 60% Flow
- 3) 64.5% Flow
- 4) 52% Flow









GUARANTEED QUALITY

# LOUISIANA POWER AND LIGHT

Waterford Units 1 and 2

Exhaust pressure correction to test rate


AIR (A)

throttle  
flow


to be subtracted


to be added

This curves are for correction of  
measured heat rate to us. 10.67d  
visuon for specified conditions.



5/12/75  
V 693 - 0309 C






# LOUISIANA POWER AND LIGHT

Wattmeter Units 1 and 2  
Initial temperature correction to heat rate

the curve is invalid for  
full open valves.

% change in heat rate



This curve is for correction of  
measured heat rate to give  
values for specified conditions



Worksheet Unit V 693 - 0309 0

7/21/76

File