

PTC 12.1 Calculations Using PEPSE – Beta Testing

by

Gene Minner – Curtiss Wright

Jerry Weber – Midwest Generation, EME

Edison Mission Energy

- Coal Fired Capacity
 - 6 sites in Illinois – Midwest Generation
 - 1 site in Pennsylvania
 - 1 site in West Virginia
- Wind Capacity – 812 WTGs and growing
- Gas Fired -9 sites in California and Washington

PTC 12.1

Feedwater Heater Acceptance Testing

- Purpose – perform acceptance testing on new heaters or test existing heaters
- Conducted within 10% of design feedwater flow
- Other parameters have corresponding limits
- Steady state generation (constant load)
- Test code equations and methodology corrects design performance conditions to actual test conditions for comparison with actual measured values

Feedwater Heater Zones

One to three possible zones

- Desuperheating – applicable to fossil unit HP heaters, cools steam to within 5 – 50 deg of saturation temp
- Condensing – latent heat of condensation
- Drain Cooling – Subcools drains below saturation temperature for ease of transport to lower pressure heater and for efficiency
 - Can exist separately or as part of a two or three zone heater

Heat Transfer Equations Utilized

Resistances

- $U = 1/(r_{\text{shell film}} + r_{\text{shell fouling}} + r_{\text{t fouling}} + r_{\text{metal}} + r_{\text{t film}})$
 - Overall heat transfer coefficient
 - Utilized to obtain shell side film resistance
 - Supplied by heater manufacturer for each zone
- $r_{\text{shell fouling}} + r_{\text{t fouling}}$ are constants
- R_{metal} = Tube wall conduction

$$= d_o/24K (\ln (d_o/d_i))$$
- $R_{\text{t film}}$ = Tube side convection

$$= 0.0378((u^{0.4}/(K^{0.6}p^{0.8}C_p^{0.4}))(d_o/d_i^{0.8})(1/V^{0.8})$$

$$= 1/ (0.023 (Re^{0.8})(Pr^{0.4}))$$

Heat Transfer Equations

Applied to Each Zone

- $U = 1/(r_{\text{shell film}} + r_{\text{shell fouling}} + r_{\text{t fouling}} + r_{\text{metal}} + r_{\text{t film}})$
- Uses NTUs with the heat transfer resistances to calculate the performance
- Heat capacity flow rates
 - $C_{\text{shell side}} = W_{\text{s actual}} Q / (W_{\text{s design}} (T_1 - T_2))$
 - $C_{\text{fw side}} = w_{\text{fw actual}} Q / (w_{\text{fw design}} (t_2 - t_1))$
- Heat capacity ratio = $R = C_{\text{fw side}} / C_{\text{shell side}}$
- Number of transfer units = $\text{NTU} = UA / C_{\text{fw side}}$

Heat Transfer Equations

- Zone effectiveness = for DS and DC Zones:

$$E = (1 - e^{(NTU * (R-1))}) / (1 - Re^{(NTU * (R-1))})$$

$$E = 1 - e^{-NTU} \text{ for condensing zone only}$$

- Feedwater temperature leaving zone =

$$T_{fw \text{ out}} = E(T_{\text{shell side in}} - t_{fw \text{ in}}) + t_{fw \text{ in}}$$

- Need to perform calculations for each zone in heater beginning with drain cooling zone and ending in desuperheat zone
- Iteratively converge to solution that satisfies an energy balance
- Calculate TTD and DCA

Performance

- Terminal Temperature Difference

$$TTD = T_{\text{sat}} - T_{\text{fw outlet}}$$

- Drain Cooler Approach (if applicable)

$$DCA = T_{\text{drain out}} - T_{\text{fw inlet}}$$

Design data corrections

Pressure Drops

- Pressure Drops adjustments

- $\Delta P_{\text{shell}} = \Delta P_{\text{design}} (W_{\text{s actual}}/W_{\text{s design}})^{1.8}$

- Performed in each heater zone
 - Assumed negligible in condensing zone

- $\Delta p_{\text{fw}} = \Delta p_{\text{design}} (w_{\text{fw actual}}/w_{\text{fw design}})^{1.8}$

Design Data Corrections

Heat Transfer Resistances

- Heat Transfer Resistances – Each Zone
- $r_{\text{shell film}}, r_{\text{metal}}, r_{\text{t film}}, r_{\text{shell fouling}}, r_{\text{t fouling}}$
- $r_{\text{shell film}} = r_{\text{shell film design}} (W_{\text{s design}}/W_{\text{s actual}})^{0.6}$
- r_{metal} - adjusted for temperature effect on K
- $r_{\text{fw film}} = r_{\text{fw film design}} (w_{\text{fw design}}/w_{\text{fw actual}})^{0.8}$
- $r_{\text{shell fouling}}$ and $r_{\text{t fouling}}$ are constants

PEPSE Calculations

- Incorporates all the PTC code methodology and calculations
- User inputs data from manufacturers design spreadsheet plus resistance data that can be easily calculated
- PEPSE calculates the off design predictions and compares to actual performance

Heater Specification Sheet Data

Adobe Reader - [FW Spec sheet.pdf]

File Edit View Document Tools Window Help

Save a Copy Search Select 110% Help Search Web

Shell Side				Tube Side		
5. Fluid Circulating	Steam	Drains		Feedwater		
6. Total Fluid Entering	Lb/Hr	51,365	91,612	1,134,590		
7.						
8. Inlet Enthalpy	Btu/Lb	1444.9	399.9	338.9		
9. Outlet Enthalpy	Btu/Lb		351.5	392.3		
10. Inlet Temperature	Deg. F	843.7 (410.8 SAT.)		363.1		
11. Outlet Temperature	Deg. F		378.1	413.8		
12. Operating Pressure	Psia	279.19				
13. Number of Passes		3 Zones		2 Pass		
14. Velocity	Ft/Sec			6.82 @ 388.5 Deg. F		
15. Pressure Drop	Psi	DSH 4.0 DC 1.0		6.8		
	Heat Exchanged Btu / Hr	Surface Sq. Ft Effective	LMTD Deg. F	Transfer Rate Btu/ Hr*Sq. Ft* F	Baffle Spacing in	Reference Temperature Differences
16. Desuperheating Zone	10618000	558	186.3	102		
17. Condensing Zone	45146000	3628	16.9	737		TTD -3.0 Deg. F
18. Drain Subcooling Zone	4829000	395	26.3	464		DCA 15.0 Deg. F
CONSTRUCTION-EACH SHELL						
Shell Side				Tube Side		
19. Design Pressure	Psig	360.00 /FV			3000	
20. Test Pressure	Psig	468			3900	
21. Design Temperature (Max)	Deg. F	Shell 650.0	Skirt 920.0	450.0		
22. Tubes	Note #1 (U's)	418	O.D. 0.75	Avg. 0.073	Length 335	in

7 of 8

Resistance data – PEPSE Inputs

Available from manufacturer or can be calculated

- $R_{\text{metal}} = d_o / 24K (\ln (d_o / d_i))$
- $R_{\text{Feedwater film}} = 0.0378((u^{0.4} / (K^{0.6} p^{0.8} C_p^{0.4})) (d_o / d_i^{0.8}) (1 / V^{0.8}))$
- $U = 1 / (r_{\text{shell film}} + r_{\text{shell fouling}} + r_{\text{t fouling}} + r_{\text{metal}} + r_{\text{t film}})$
utilized to obtain shell side film resistance

PEPSE inputs for Design Data

PTC12.1-UGM.xls [Compatibility Mode] - Microsoft Excel

Three Zone Heater (Type 18)							
Term	Units	Desuperheating		Condensing		Drain Cooling	
		Symbol	Value	Symbol	Value	Symbol	Value
Design Data (supplied by manufacturer)							
Feedwater flow rate	(lbm/hr)			w'	1134590		
Steam flow rate	(lbm/hr)	W'_s	51365				
Drains flow rate	(lbm/hr)					W'_1	142977
Steam inlet pressure	(psi)	P'_3	279.19				
Shell side pressure loss	(psi)	$\Delta P'_{ds}$	4			$\Delta P'_{dc}$	1
Shell side temperature in	(°F)	T'_3	843.7	T'_2	409.51		
Shell side temperature out	(°F)	T'_{ds}	464.3477			T'_1	378.1
Feedwater temperature in	(°F)					t'_1	363.1
Feedwater temperature out	(°F)	t'_4	413.79	t'_3	405.01	t'_2	367.20
Feedwater pressure loss	(psi)			$\Delta p'_t$	6.8		
Heat transferred	(Btu/hr)	Q'_3	10618000	Q'_2	45146000	Q'_1	4829000
Heat transfer area	(ft^2)	A'_3	558	A'_2	3628	A'_1	395
Feedwater film resistance	(hr-ft^2-°F/Btu)	r'_{t3}	0.0004	r'_{t2}	0.00041	r'_{t1}	0.00042
Feedwater fouling resistance	(hr-ft^2-°F/Btu)	r'_{ft3}	0.000237	r'_{ft2}	0.000237	r'_{ft1}	0.000237
Tube material resistance	(hr-ft^2-°F/Btu)	r'_{m3}	0.000271	r'_{m2}	0.000271	r'_{m1}	0.000271
Shell side fouling resistance	(hr-ft^2-°F/Btu)	r'_{fs3}	0.0003	r'_{fs2}	0	r'_{fs1}	0.0003
Shell side film resistance (r'_{s1} corrected for reheat by the manufacturer)	(hr-ft^2-°F/Btu)	r'_{s3}	0.008596	r'_{s2}	0.00044	r'_{s1}	0.000928
Terminal temperature difference and Drain cooler approach	(°F)	TTD'	-3			DCA'	15

Ready | Average: 1105904.139 | Count: 145 | Sum: 61930631.76

PEPSE Inputs for Test Data

PTC12.1-wauk7F.xls [Compatibility Mode] - Microsoft Excel

Line No.	Term	Units	Desuperheating		Condensing		Drain Cooling	
			Symbol	Value	Symbol	Value	Symbol	Value
18	Terminal temperature difference and Drain cooler approach	(°F)	TTD'	-3			DCA'	15
Test Data								
19	Actual feedwater flow rate	(lbm/hr)			w	1134590		
20	Actual shell side temperature in	(°F)	T_3	843.7				
21	Actual shell side temperature out	(°F)			T_2		T_1	378.1
22	Actual feedwater outlet temperature	(°F)	t_4	413.79				
23	Actual feedwater inlet temperature	(°F)					t_1	363.1
24	Actual shell side pressure loss	(psi)	ΔP_{ds}				ΔP_{dc}	
25	Actual feedwater pressure loss	(psi)			Δp_t	6.8		
26	Actual steam pressure in	(psi)	p_3	279.19	p_2			
27	Actual drain pressure out	(psi)			p_1	274.19		
28	Actual feedwater pressure in	(psi)			p_1	2350		
29	Actual feedwater pressure out	(psi)	p_4	2343.2				
30	Shell side fouling resistance (by agreement)	(hr-ft ² -°F/Btu)	r_{fs3}	0.0003	r_{fs2}	0	r_{fs1}	0.0003
31	Feedwater fouling resistance (by agreement)	(hr-ft ² -°F/Btu)	r_{fs}	0.000237	r_{ft2}	0.000237	r_{ft1}	0.000237
32	☐ Feedwater fouling resistance is ID based							
33	Actual drain outlet flow rate	(lbm/hr)					W_1	142977
34	Number of drain inlet connections							
35	Actual 1st drains inlet pressure	(psi)			P_{d1}	275.2		
36	Actual 1st drains inlet temperature	(°F)			T_{d1}	409.51		
37	Actual 1st drains inlet flow rate	(lbm/hr)			W_{d1}	91612		

Ready | Average: 1105904.139 | Count: 145 | Sum: 61930631.76 | 100%

PEPSE Outputs

PTC12.1-UGM.xls [Compatibility Mode] - Microsoft Excel														
Home Insert Page Layout Formulas Data Review View Developer Add-Ins Get Started														
Clipboard Font Alignment Number Styles Cells Editing														
110 385.422485351562														
Computed Data														
5														
6	38	Steam flow rate		(lbm/hr)				W_{s1}	52755.38					
7	39	Feedwater enthalpy in		(Btu/lbm)				h_1	338.8809					
8	40	Feedwater enthalpy out		(Btu/lbm)	h_{s4}	392.4411								
9	41	Steam enthalpy in		(Btu/lbm)	H_3	1444.913								
10	42	Drains enthalpy in		(Btu/lbm)				H_d	385.4225					
11	43	Drain enthalpy out		(Btu/lbm)						H_{s1}	351.7			
12	44	Assumed feedwater outlet temperature		(°F)	t_{s40}	413.9243								
13	45	Total heat load		(Btu/hr)				Q^*	60768788					
14	46	Feedwater pressure loss		(psi)				Δp_{s1}	6.8					
15	47	Steam pressure in condensing zone		(psi)				P_{s2}	274.993					
16	48	Saturated steam temperature at steam inlet P_3		(°F)	T_s	410.8093								
17	49	Drains flow rate		(lbm/hr)				W_{d1}	91612	W_{s1}	144367			
18	50	Shell side temperature in		(°F)				T_{s2}	409.4452	T_{s2}	409.4452			
19	51	Shell side temperature out		(°F)				T_{s2}	409.4452	T_{s1}	378.2129			
20	52	Feedwater film resistance		(hr-ft ² -°F/Btu)	r_{s12}	0.0004		r_{s12}	0.00041	r_{s12}	0.00042			
21	53	Shell side film resistance		(hr-ft ² -°F/Btu)	r_{s12}	0.00846				r_{s12}	0.000923			
22	54	Overall heat transfer coefficient		(Btu/hr-ft ² -°F)	U_{s3}	103.4419		U_{s2}	737	U_{s1}	465.1596			
23	55	Hourly heat capacity flow rate of shell side fluid		(Btu/(hr-°F))	C_{s3}	28747.46				C_{s1}	155235.9			
24	56	Hourly heat capacity flow rate of feedwater fluid		(Btu/(hr-°F))	c_{s3}	1209220		c_{s2}	1194160	c_{s1}	1176799			
25	57	Hourly heat capacity ratio		(--)	R_{s3}	42.06355				R_{s1}	7.580715			
26	58	Number of transfer units		(--)	$(NTU)_{s3}$	0.047734		$(NTU)_{s2}$	2.239093	$(NTU)_{s1}$	0.156134			
27	59	Effectiveness		(--)	ϵ_{s3}	0.020494		ϵ_{s2}	0.893445	ϵ_{s1}	0.088897			
28	60	Feedwater outlet temperature		(°F)	t_{s4}	413.9376		t_{s2}	404.9459	t_{s2}	367.22			
29	61	Predicted terminal temperature difference		(°F)	TTD^*	-3.12837								
30	62	Predicted drain cooler approach		(°F)						DCA^*	15.11285			
31	63	Predicted shell side pressure loss		(psi)	ΔP_{s3}	4.197001				ΔP_{s3}	1.017572			
32	64	Actual test point shell side pressure loss		(psi)	ΔP_{s3}	279.19				ΔP_{s3}	-274.19			
33	65	Actual test point terminal temperature difference		(°F)	TTD	-2.98076								
34	66	Actual test point drain cooler approach		(°F)						DCA	15			
35	67	Discrepancy of shell side pressure loss		(psi)	δP_{s3}	-274.993				δP_{s3}	275.2076			
36	68	Actual feedwater pressure loss		(psi)				ΔP_{s1}	6.8					
37	69	Discrepancy of feedwater side pressure loss (FWH)		(psi)				δP_{s1}	0					
38	70	Assumed drain cooling zone drain outlet temp		(°F)						T_{s10}	378.1			
39	71	Discrepancy of drain cooler approach		(°F)						δDCA	0.112854			
40	72	Discrepancy of terminal temperature difference		(°F)	δTTD	-0.14761								

Comparisons to Design

Actual to Corrected Design

- Calculated zone heat transfer coefficients
- **TTD**
- **DCA** (if applicable)
- Zone shell pressure drops
- Feedwater pressure drop

Future Enhancement Ideas From Beta Test on 3 Zone Heater

- Incorporate resistance calculations
- Revise the input sheet to designate as optional parameters that can be calculated:
 - Shell side temp leaving condensing zone
 - DS zone pressure drop
 - DC zone pressure drop
 - Condensing zone pressure
 - Note that these are zone dependent and data will be needed for single zone heater

Reference

- ASME PTC 12.1 – 2000 version