

**Power Uprate Studies for Nuclear Power Plants
Using PEPSE - Lessons Learned**

William C. Kettenacker
SCIENTECH, Inc.
P.O. Box 292606
Lewisville, TX 75029

Power Uprate Studies for Nuclear Power Plants Using PEPSE - Lessons Learned

William C. Kettenacker
SCIENTECH, Inc.
P.O. Box 292606
Lewisville, TX 75029

Abstract

In recent years many nuclear plants have investigated and implemented changes to their plants in order to obtain more electrical generation. In some cases the changes have included an uprate to their licensed reactor power levels, in other cases it has been a change in equipment in their secondary system (turbine cycle), and in many cases it has been a combination of these. In order to investigate these changes before they are implemented, many have used the PEPSE (Performance Evaluation of Power System Efficiencies)^[1] energy balance software to simulate these changes and determine ahead of time the plant response to these changes. Key lessons have been learned in implementing model simulations, interpreting and using plant data, and applying the results.

Developing a Base Model

The first step in these studies is to develop a base PEPSE model that can be verified against some standard performance. This standard performance is usually the original turbine vendor heat balance diagrams at several loads or the “new” turbine vendor heat balances produced by the new turbine vendor if new turbines are to be part of the power uprate effort. It can also be the plant performance measured during a recent performance test, or simply data collected on a day-to-day basis. Tuning the model to actual data is sometimes called the “as-built” plant model. If the power uprate is to be done in steps, i.e., power uprate first then new turbines added later, then the first step in the development of the base model would be based on the original turbine vendor’s heat balances (not the new turbine vendor turbine performance characteristics found on the new turbine vendor heat balance diagrams - that process is described later).

When developing the base PEPSE model, a “one-line” model (single string of turbines, single string of feedwater heaters) is acceptable, but a more rigorous model may be required if the model is to be tuned to actual plant data in the future, i.e., an as-built plant model. In addition, a one-line model will not adequately simulate the effects of different condenser pressures if the plant has a multi-zone condenser or multiple condensers with each zone or condenser at a different backpressure. Modeling both “ends” of a double-flow HP (high pressure) turbine and each “end” of all the double-flow LP (low pressure) turbines ensures the greatest detail, but this

is also the most complicated. In some cases this is not justified. Experience has shown a good compromise is to represent a double-flow HP as a single string of PEPSE turbine components and each double-flow LP as a string. Ultimately the heater arrangement and the extraction arrangement will dictate the best approach. For example, if the HP extractions from each end of the HP turbine are connected in some type of header arrangement before splitting to the high pressure heaters, there is no need to separate the HP turbine ends. Their effects are “mixed” and separating them will tell you nothing unique. If, however, in this arrangement, the extractions do not mix but instead go directly to separate heaters, then modeling separate ends of the HP may be of benefit. Figure 1 shows several ways to model the turbines.




Figure 1
Turbine Modeling Options

If the model is to be tuned eventually to actual plant data, all feedwater heater strings should be included. This will allow for the differences in heater data and heater performance for the heaters in the different strings.

The level of modeling complexity for the other components in the model is variable and should be evaluated based on their thermodynamic impact. One example would be pumps. Including all condensate pumps and all circulating water pumps does nothing to enhance (or hinder) the thermodynamic calculations. This may not be the case for main feed pumps, especially if they

are turbine-driven, because the steam supply may vary based on pump and turbine performance. Another example is valve components, which are not needed to accurately represent the thermodynamics of the model. It is true that valve components can be used to simulate pressure drops and also can be opened or closed to allow flow to pass or be cut off, but these same effects can also be obtained using a stream. Using a stream for pressure drops or shutting off flow is simpler than using a valve. With all this said, the “political factor” should be considered when deciding to include components or not. Usually someone in management must be “sold” on the PEPSE results. A rigorous model rather than a simplified model may be a better way to do this.

Where available in PEPSE, the components should be characterized using the design mode input option. By enabling these basic-principles formulations to calculate the performance for these components automatically, this option gives the model greater flexibility when changing load, changing operating conditions, or changing inlet boundary conditions. It is easier to do this using the design mode rather than using the performance mode input option. The design mode requires input data that describes hydraulics and heat transfer rather than just gross performance parameters. In most cases, after preparing the design mode input, the user must “tweak” or adjust the calculations to match a specified performance because PEPSE does not have the specific operational calculations for each equipment manufacturer. PEPSE’s design mode calculations are based on industry-standard first-principles calculations that adapt with variation of operating conditions but do not necessarily match a particular component vendor. The adjustment of the design mode calculations using adjustment factors allows PEPSE’s performance to match that of the manufacturer.

Turbine types 1-3 invoke the design mode for the turbines. As with all design mode components, PEPSE’s turbine calculations for types 1-3 are based on a particular set of turbine procedures and must be adjusted to match the performance of your turbines. These adjustment factors are called efficiency multiplying factors and expansion line shape factors. Type 8 (general) turbines may be used in lieu of types 1-3 and do not require adjustment; however, type 8 turbines (performance mode turbines) do not offer the load generality that types 1-3 offer.

PEPSE allows several options for the feedwater heaters in the design mode. It is recommended that the Simplified Design Mode be used. The inputs are easier than the other design mode options while offering the same calculational accuracy. There are many adjustment factors for the feedwater heaters in the design mode but the most common is a multiplying factor on the overall heat transfer coefficient.

Condensers should be modeled using the HEI design mode option. This is discussed in more detail later.

At the time of the writing of this paper, the use of the design mode for nuclear reheaters is not recommended. This design mode calculation does not offer the flexibility needed to model the complex reheaters of today. The next release of PEPSE, Version 67, will remedy this.

Miscellaneous heat exchangers may also be modeled using the design mode input option. However, finding all the required input data may be difficult. Generally, modeling them in the performance mode does not diminish the flexibility or accuracy of the model.

Base Model Using Original Turbine Vendor Heat Balance Diagrams and Thermal Kit

Using the original turbine vendor's heat balance diagrams and thermal kit is the most common method of developing and tuning a base PEPSE model. This information is readily available and the model has usually been developed previously. This model should match the vendor's heat balances at several loads, most importantly VWO (valves wide open) and 100% power. Loads that match to within 500 kW and thermodynamic properties that match to within 0.25% are considered good.

Usually all of the data required by PEPSE for this type of model are found on the heat balances or in the thermal kit. Missing data can be obtained by contacting the turbine manufacturer or by making educated guesses based on knowledge of the system and previous modeling experience.

If the base model is to be based on the original turbine vendor heat balances and thermal kit only and will not be modified later to reflect new turbines or actual plant data, it may not be necessary to use the design mode input option for the feedwater heaters. The heat balance values of TTD (terminal temperature difference) and DCA (drain cooler approach temperature difference) may be sufficient for bounding the results when going to a different power level.

Base Model Using New Turbine Vendor Heat Balance Diagrams with New Turbines

Sometimes a power uprate will include a simultaneous turbine upgrade, either to the HP or LP turbine. If heat balance diagrams are available with both the power uprate and new turbine performance included, the PEPSE model should be developed and tuned to these balances. The same procedure as outlined in the previous section should be followed.

Base Model Using Performance Test Data

The most accurate power uprate model is based on actual plant data - this model represents the plant as it is currently operating and not necessarily as it was designed. Data for this model may be from a recent performance test or from the daily data logs.

It is imperative for matching as-tested performance that as many components as possible be characterized using the design mode input option. The plant data are used to tune the calculations for these components to their current performance using the design mode option adjustment factors. Then, when the power uprate condition is applied to the model, the results for these components will float to their new condition, giving an accurate prediction of the power uprate.

It is best to start with the base model that was originally constructed from the turbine vendor's heat balances. Then, put all components as possible in the design mode. Following that, using PEPSE's control feature, control individual component adjustment factors to match the measured performance. When this is completed, take these adjustment factors and put them into the

model, remove the controls, and run the model at the new power level. A systematic way of doing this is to develop a series of sets that step through this process and pass the required information from one set to the next automatically. One way to do this would be the example as follows:

- Set 1 - Base Model Using Turbine Vendor Heat Balance at 100% Load
- Set 2 - Plant Data at 100% Load - Tuning Using Controls
- Set 3 - Power Uprate Study Using Adjustment Results from Set 2 Tuning

In Set 2, use a series of controls to get the adjustment factors, but turn these controls off in Set 3. These factors will be automatically passed to Set 3. Set 2 must be characterized using the Run Separator = SAVE CASE. This is illustrated in Figure 2.




Figure 2
Tuning to Actual Performance Data – Run Set Sequence

Base Model Using Performance Test Data and New Turbine Vendor Heat Balance Diagrams with New Turbines

If a new turbine (or turbines) will be part of the uprate project, it is best to develop the model using actual plant data as described in the previous section and then bring the description of the new turbine(s) into this model.

First, obtain the performance of the new turbine(s) from the turbine manufacturer. This is usually supplied in the form of new heat balance diagrams with the new turbine(s) included.

Because the other plant components in these new heat balance diagrams are at assumed conditions, not your real plant conditions, you should not tune the turbine adjustment factors in the existing model. Instead, build a separate submodel including just the new turbine(s) and tune the adjustment factors using the data from the new heat balance diagrams, i.e. tweak the turbine(s) using the adjustment factors to match the specified performance on the new heat balance diagrams. An example of an HP turbine submodel is shown in Figure 3. Finally, take the new turbine data and adjustment factors from the submodel and put them in the model that has been tuned to actual plant data – put them in Set 3 (see discussion in previous section).




Figure 3
High Pressure Turbine Section Submodel Example

Setting the Input Thermal Power

Dialing in the thermal input power and having PEPSE determine the cycle behavior is the desired result of a power uprate study. There are several ways to set the thermal input power to the turbine cycle. In all cases the thermal power is the net thermal power to the turbine cycle, not the reactor power.

Special Option 4

Special Option 4 is a quick way to set the turbine cycle thermal input power. PEPSE looks at the final feedwater energy out from the turbine cycle model (at the output component type 32), the main steam inlet energy (at the input component type 33), and adjusts the flow to the turbine cycle model at the input component to match the target net thermal input power to the turbine cycle model. Only flow is adjusted.

Steam Generator

A steam generator component (or components) can be used to simulate the steam generator(s) in a PWR plant or the reactor in a BWR plant. When using this component, the model becomes “closed”; there is a complete loop. The output flows from the final feedwater heaters go to the steam generator(s) and the output flows from the steam generator(s) go to the HP turbine. There is no open cycle as there is when the final feedwater flow terminates at the output component and the main steam flow originates from the input component.

One of the inputs on the steam generator component is thermal power, the amount of energy that passes from the primary to secondary side in the steam generator. When this is specified, PEPSE adjusts the outlet energy (enthalpy) of the main steam that exits from the steam generator(s). Unlike Special Option 4, this thermal input power option does not adjust the user-specified flow.

User Action

The user can employ a variety of methods to set the thermal input power outside of traditional methods. One way would be to write a series of operations that use the final feedwater conditions as the net energy out from the turbine cycle, and then adjust one of the input variables for the main steam inlet component (the input component energy in), such as flow, enthalpy, quality, or pressure, to match the desired turbine cycle thermal input power. The same matching could be done using PEPSE’s control feature.

Another method would be to use one of PEPSE’s general heat exchangers (type 20 or type 27) to simulate the steam generator(s) or reactor by specifying an energy input equal to the desired thermal input power.

Condenser Modeling

It is very common for a nuclear plant to have a multi-zone condenser with each zone at a different backpressure. Usually different backpressures result because the circulating water is in series, going from one zone to the next at a hotter and hotter temperature. In plants where there is some kind of equalizing line (pipe or duct) intended to keep the pressures equal in the various zones, the pressures are often slightly different in the zones. Slightly different backpressures can also occur in multi-zone condensers where the circulating water is piped in parallel, i.e., all zones have the same circulating water inlet temperature. In other words, whether intended or not, the pressures in the various zones are rarely equal. A difference of 0.1 “ Hga can cause as much as a 1 MWe swing in electrical output. Because of this, it is recommend that all zones be included in the PEPSE model by using a separate condenser component to simulate each zone.

It is also common for each LP turbine section to exhaust to a different condenser zone. If so, then in the PEPSE model each LP section must exhaust into the proper zone (condenser component) without mixing the LP section exhaust lines together. This must be strictly adhered to. The correction to the LP expansion line endpoint that is based on actual condenser pressure is made in the LP turbine itself. To properly account for this requires the correct condenser connections. This is illustrated in Figure 4.




Figure 4
PEPSE Modeling for Multiple Condenser Zones

Modeling the plant condenser(s) using the design mode input option allows the condenser(s) performance to adjust automatically to changing circulating water inlet temperatures. A popular method for this has been to use the HEI condenser calculations that are included in PEPSE. They offer good results with a minimum of input requirements.

One troubling observation that has emerged in using the various condenser design mode calculational methods has been the variability of the cleanliness factor (inferred from performance test data) at different circulating water inlet temperatures. When the cleanliness factor is adjusted to obtain a match between calculated and measured backpressure, the factor must change with changing circulating water inlet temperatures. This has been observed not only with the built-in PEPSE calculations, but also with other unrelated applications of cleanliness factor methodology. It has been seen at several nuclear plants where they have included a design mode type calculation in their day-to-day plant reporting.

The literature addresses use of the cleanliness factor in this fashion. Quoting from ASME PTC 12.2^[2], “The cleanliness factor is a unique value, since it applies to only one specific operating condition. To use it as a constant factor of new clean tube heat transfer or other conditions of operation introduces error. The amount of this error varies directly with the degree of heat transfer change from a value corresponding to the reference performance point to a value corresponding to some other performance point. Although it is common practice to use an established condenser cleanliness factor as a constant for any operating condition for a given condenser, the user of this Code is cautioned to estimate the error which may result in following this practice before accepting this procedure as a satisfactory means for establishing condenser performance at conditions other than the cleanliness factor determination reference point.”

Typically, the cleanliness factor is used as a multiplier (x) on the overall heat transfer in the equation below^[3]:

$$q = xUA\Delta T \quad (1)$$

where:

- q = heat transferred
- U = overall heat transfer coefficient
- A = heat transfer area
- ΔT = temperature difference
- x = cleanliness factor

But cleanliness is frequently interpreted as representing a fouling term, usually on the inside of the tubes. The accounting for fouling is more rigorously accounted as an additive thermal resistive term, not a multiplicative term, in the “U” overall heat transfer coefficient^[3]:

$$U = \frac{1}{\frac{1}{h_o} + R_o + R_k + \frac{R_i A_o}{A_i} + \frac{A_o}{h_i A_i}} \quad (2)$$

where:

- U = overall heat transfer coefficient
- h_o = tube outside film coefficient
- h_i = tube inside film coefficient
- R_o = tube outside fouling resistance
- R_i = tube inside fouling (or “cleanliness factor”) resistance
- R_k = tubing wall resistance
- A_o = tube outside area
- A_i = tube inside area

Using the fouling as an additive term may be a better characterization, but it may not give better results. This term, if inferred from test data, may still vary over the load range or over a range of circulating water inlet temperatures. One way to test this would be to use an internal (and optionally external) fouling factor in the form used in Equation (2).

If cleanliness factor is the choice for tuning, a common method of addressing the variability of the cleanliness factor is to input this factor in a curve (schedule) as a function of circulating

water inlet temperature. A better way is to input the cleanliness factor as a function of both the circulating water inlet temperature and heat duty on the condenser using a bivariate schedule.

Primary Side Components - Reactors and Steam Generators

It is not necessary to model the reactor for a PWR or BWR plant, or the steam generator(s) for a PWR plant. PEPSE's input component (type 33) and output component (type 32) can serve as the boundary conditions for these. Some companies include the primary side components for the sake of completeness while others believe their inclusion complicates the model. When modeled, these components close the cycle, or "close the loop", and it is no longer open-ended; the main flow makes a continuous loop.

If you choose to model the reactor and/or steam generator(s), several recommendations are offered. An input component and an output component should still be used. First, they are the components used by PEPSE to calculate the turbine cycle heat rate. If not present, the thermodynamic calculations will be unaffected, but a heat rate number will not be calculated or printed in the output. Secondly, they serve as anchor points in the cycle analysis. They allow you to set thermodynamic properties at these points for a given number of iterations, stabilizing the model. Finally, they allow you to remove the reactor and/or steam generator(s) without having to add additional components later. When using the input component and output component, connect their optional inlet connection and outlet connection, respectively, to the primary side components. For the input component, use the optional data input form to flag PEPSE that it is "double-ended" and flag the option that allows the pressure, temperature, and flow to be passed from inlet to outlet after a certain number of iterations (the pass-through flag), usually 15. For the output component, just flag the double-ended option. Figure 5 shows an example of a connection using double-ended input and output components.

When the loop is closed by including primary side components, the turbine cycle inlet conditions are NOT dictated by the input component specifications. They are set by either the steam generator(s) input parameters or by the reactor parameters. The input component temperature (or quality), pressure, flow, and optionally enthalpy, serve as a first guess only and are used up to an iteration number specified by the user. If the user fails to set this iteration number and the pass-through flag, there will always be an energy imbalance in the input component and the model will not converge.




Figure 5
Use of a Double-Ended Input and Output Component

Pressurized Water Reactor Plant

The reactor and the steam generator(s) may be modeled, or just the steam generator(s) may be modeled. If only the steam generators are modeled, the flow from the reactor will come from an infinite source (type 31) and the flow back to the reactor will go to an infinite sink (type 30). If the reactor is modeled, use a type 27 for the reactor, include the reactor coolant pumps in the primary loop, and make sure to include an infinite source (type 31) in the primary loop to set the flow and initial conditions (also set the double-ended flag and the pressure/temperature/flow pass-through iteration number).

The reactor power will be an input in the type 27 component, specified in BTU/hr. The steam generator input will allow several options, the most important being the exit pressure, the exit temperature (or quality), blowdown, and the thermal power supplied by the steam generator(s). If both the exit temperature (or quality) and the thermal power are input, the temperature

(quality) will override the thermal power. As stated earlier, if the thermal power is input, its value will be used to set the steam generator(s) outlet thermodynamic conditions, not the specified flow rate to the turbine cycle. If the temperature (or quality) is input, make sure you are not specifying the turbine cycle inlet temperature (or quality). Usually a pressure drop is modeled from the steam generator(s) outlet to the main turbine inlet valves. If so, the temperature (or quality) would be different because of the pressure drop.

Boiling Water Reactor Plant

Either a type 27 component can be used for the reactor, or a steam generator component (type 76) can be used. If a steam generator component is used (it actually affords more input options and flexibility), use an infinite source (type 31) to supply a “dummy” reactor side flow, and use an infinite sink to receive the primary-side outflow from the steam generator component.

Reheaters

A reheater is typically a multi-pass or multi-zone heat exchanger with different heat transfer regimes occurring in the different passes. Heating steam from throttle (or from the HP turbine) has a high quality and represents steam-to-tube heat transfer. This heating steam condenses inside of the tubes, approaching a saturated liquid condition. In some circumstances, subcooling of the liquid occurs inside of the tubes near the exit.. On the heated steam side, the steam is usually saturated, perhaps with slight liquid carryover from the moisture separator. The heating produces superheated cycle steam at the reheater outlet. Modeling these different regimes requires a model with multiple passes. This is accomplished with multiple reheater components (type 22) or one reheater component and one or more general heat exchanger components (type 20).

Figure 6 shows an example of a reheater with several passes and the PEPSE model used to simulate it. The water/steam separation between passes 2 and 3 is represented using a moisture separator (type 62) component. Normally this component is used to simulate the moisture removal phase at the inlet of the MSR’s (moisture separator - reheater), but it may be used to simulate any water and steam separation process.

If multiple reheaters are installed in the plant, all should be included in the PEPSE model unless a one-line model is being built.




Figure 6
Multi-Pass Reheater Modeling Example

Using the Existing Model

Almost every plant has a PEPSE model. Sometimes it was constructed recently using the latest version of PEPSE; sometimes it is an old “mainframe” version with the graphics on a piece of paper. Some models have been developed recently by the current performance engineer and reflect the latest heat balances or plant data. Others have been modified over the years by many people, and no one knows what’s “in there”. The best approach – if the model cannot be verified as “current” by the plant performance engineer who has a good working knowledge of PEPSE, then build a new model by starting from scratch using the latest turbine vendor’s heat balances.

Matching Several Loads

Experience has shown that tuning the as-built model to match at one load point does not guarantee a match at other loads. Usually the difference in load points is attributable to different

condenser backpressures. Summer backpressures are generally higher than in winter and can represent a swing of 10-50 MWe. Tuning the model to one load (backpressure) and then inputting another backpressure may not give the measured plant output. How can this be? There may be something wrong with the input data or the assumptions used when setting up the model. Some of the discrepancies may be explained as follows:

- a. The model was tuned using bad data, or the new load data are bad
- b. There may be inconsistencies in how the data were taken at the two loads
- c. There may be performance factor changes that are not known
- d. There may be component performance changes between the two data sets
- e. There may be real physical effects that are not accounted for in the model
- f. Others

How do you get the PEPSE model to match the plant at all loads? A little experience helps here. Usually the exhaust loss curve is modified or the last stage LP turbine adjustment factor (efficiency multiplying factor) is modified to match the measured output. The last LP stage is influenced by the backpressure. It is logical (and accepted) to modify the last LP stage to make the model match the plant. These modifications can be set up in a curve (schedule) versus some parameter such as electrical load, thermal power, or main steam flow.

Conclusions

Making a set of mathematical equations such as those in PEPSE match “mother nature” (the plant) requires experience, practice, and a little luck. These lessons learned are based on experience, a lot of practice, and a little luck. Passing them on to others will make their modeling experience a little more user-friendly. As they say, “There’s no teacher like experience - someone else’s!”.

References

1. G. L. Minner, W. C. Kettenacker, D. R. Fleming, G. C. Rice, *PEPSE - User Input Description*, SCIENSTECH, Inc., Idaho Falls, Idaho, 2001.
2. *Code on Steam Condensing Apparatus*, ANSI/ASME PTC 12.2, The American Society of Mechanical Engineers, New York, New York, 1983.
3. Krieth, Frank, *Principles of Heat Transfer*, International Textbook Company, Scranton, Pennsylvania, 1965.