

**Predictive Cooling Tower Modeling
Using PEPSE[®]**

Marcus B. Caudill

Colorado-Ute Electric Association

Predictive Cooling Tower Modeling Using PEPSE

M. B. Caudill
Performance Engineer
Colorado Ute Electric Association

ABSTRACT

Cooling tower tests are typically run as close to design ambient conditions as possible. This is done to allow a good comparison to design tower capability. The drawback to this approach is that design ambient conditions are achieved for only a small percentage of the year. This does not allow the use of the test information to directly determine the cold water temperature to the condenser under varied conditions. However, by using the as tested capability information and the vendor performance curves, it is possible to predict the cold water temperature to the condenser for a wide range of ambient weather conditions. This paper presents a summary of the modeling methodology and the results of tests comparing predicted cold water temperature to actual cold water temperature under various conditions.

BACKGROUND

Craig Station Unit 1 is a nominal 447 Mw unit with a GE turbine, a B&W boiler and a 10 cell Marley crossflow cooling tower. The Unit is jointly owned and is routinely operated at five percent overpressure to obtain the maximum generation. During the summer season, the circulating water inlet temperature is often well above the 84°F design, causing condenser pressure to rise above the design point of 3.17 inches Hga. Since the condenser pressure vs. generation loss curve (Figure 1) is so steep above design condenser pressure, any increase in circulating water inlet temperature causes a significant decrease in generation. In the past, any increase in condenser pressure during the summer was attributed to poor cooling tower performance, but no easy method was available to determine which losses were due to the cooling tower, and which were due to other causes. The motivation behind this study was to be able to predict the generation loss due to the effects of weather conditions, and to determine how much effect cooling tower performance has on condenser and turbine performance.




Figure 1 -- Generation Change vs. Condenser Pressure

MODELING APPROACH

Since Craig 1 has a predictive PEPSE turbine cycle model, we decided to try to utilize the PEPSE cooling tower model and HEI condenser model for predicting generation loss. This way, the cooling tower and condenser model could be used alone or in conjunction with the turbine cycle model. So the first step was to construct a cooling tower sub model.

The PEPSE cooling tower component, Type 75, is a performance mode component, and therefore is quite simple in input and calculation method. Two critical input values are variable APTOWI, the tower approach (Approach = Cold water temperature - Wet Bulb temperature), and TTUA, the temperature of the air exiting the tower. The problem is that the critical result of a predictive cooling tower model is the cold water outlet temperature, and the known parameter is the wet bulb temperature. If the approach remains constant, prediction of circulating water outlet temperature becomes a simple subtraction problem. The second difficulty is measuring the temperature of the air exiting the tower. An extensive temperature grid or a traverse would be required to get an accurate indication of air out temperature. We wanted to utilize a minimal input set of easily collected information, and we wanted the ability to employ the results of annual cooling tower tests. The Cooling Tower Institute Performance Curve method is used for capability calculation at Colorado Ute, and for consistency, we decided to employ the same basic method in PEPSE. Since so many changes to the cooling tower model were required, we opted to use PEPSE's special features to simulate cooling tower performance, instead of the Type 75 cooling tower model.

COOLING TOWER SUB MODEL

To simplify model debugging, we began with a simple HEI condenser sub model, shown in Figure 2. All component, stream and special feature numbers were made to be compatible with the Craig Unit 1 turbine cycle model for later ease of integration. The importance of the condenser model is that cooling tower performance is driven by cooling range and ambient weather conditions. The weather conditions are inputs, but the cooling range is defined by the heat load to the condenser and circulating water flow rate. The HEI condenser simulates actual condenser performance very well. A design mode condenser could also be used, however, the HEI model has a much smaller input data set while still providing a reasonable simulation of condenser performance. Our condenser model was benchmarked against Westinghouse design data (Appendix B), and matched very well.




Figure 2 -- HEI Condenser Submodel

After the condenser model was complete, the Marley cooling tower performance curves (Appendix C) were input using PEPSE's Schedule feature. These curves present cold water temperature as a function of wet bulb temperature and cooling range. Three bivariate schedules were used, one each for 90, 100 and 110 percent design flow. These are schedules 1, 2 and 3. Since the schedules were constructed by picking points off of the original curves, a model was also set up to calculate tower capability based on test data. This way a consistent set of curves would be used to calculate the tower capability and to predict the cold water temperature.

Essentially, predicting cold water temperature from test results is little different from calculating capability. First, cold water temperature for each design flow is calculated based on wet bulb temperature and cooling range. The wet bulb is determined from a plant relative humidity instrument or psychrometer, and the range is calculated by the HEI condenser model. Adjustment must be made to the circulating water flow for off design fan horsepower, yielding adjusted test flow. Next, the predicted flow is back calculated from the adjusted test flow and the test capability. These are operations 56 through 61, in Appendix A.

Using a binary if operation (BIF), the predicted flow is located in relation to design flow. If less than design flow, predicted cold water temperature is calculated by linear interpolation between cold water temperatures at 90 and 100 percent design flow. If predicted predicted flow is greater than design, the 100 and 110 percent flow values for cold water temperature are used.

To integrate the cold water temperature into the HEI condenser model, the cooling range must be calculated from the condenser model and then transferred to the cooling tower model. This is done in operation 65. Then the cold water temperature from the cooling tower model is transferred to the HEI condenser via operation 170. In this way the cooling tower model is integrated into the iteration scheme.

ANALYSIS RESULTS

Before integrating the Condenser/Cooling Tower model into the full turbine cycle model, several sets of historical cooling tower data were used for verification. All produced results consistent with the actual test results.

Model integration was as simple as removing source component 10 and sink component 700 from the condenser/cooling tower sub model. Since the sub model was numbered consistent with the turbine cycle model, all of the geometry, components and special features ran with no problems.

Figure 3 presents the results of a sensitivity study performed with the new cooling tower model, and presents maximum generating capability of Craig Unit 1 as a function of wet bulb temperature, for two different capabilities. This analysis is based on cooling tower test data from a June 1990 cooling tower performance test.




Figure 3 -- Gross Generation vs. Wet Bulb Temperature

CONCLUSION

The cooling tower model, combined with the PEPSE turbine cycle model provides a convenient method of predicting generation losses during the summer months, in addition to quantifying the portion of generation losses that can truly be attributed to the cooling tower. The method is relatively simple to implement if performance curves are available from the tower vendor, and also provides a consistent method for cooling tower test data analysis.

We have not yet had an opportunity to benchmark the cooling tower predictive model against current test data. We plan to complete cooling tower testing on Craig 1 during July 1991, and then compare the actual predictive abilities of the model to plant data throughout the summer and fall.

REFERENCES

- (1) PEPSE Computer Code, NUS Corporation, PO Box 50736, Idaho Falls, ID., Version 55I, 1990.
- (2) PEPSE Manual: Volume I, User Input Description, NUS Corporation, PO Box 50736, Idaho Falls, ID., Revision 15, 1990.
- (3) PEPSE Manual: Volume II, Engineering Model Description, NUS Corporation, PO Box 50736, Idaho Falls, ID., Revision 15, 1990.
- (4) ASME PTC 23, Atmospheric Water Cooling Equipment, United Engineering Center, 345 East 47th Street, NY, NY, 1986.
- (5) ATC 105, Acceptance Test Code for Water-Cooling Towers, Cooling Tower Institute, 19627 IH-45 North, Houston, TX, June 1982.

APPENDIX A

```

*
*
*       PEPSE USER : ADMIN
*       DATE       : 06/01/91
*       TIME       : 16:45
*       MODEL FILE ID : C2COOL
*       JOB FILE ID  : \EASEPLUS\DEMO\C2cool.JOB
*       RESULTS FILE ID : \EASEPLUS\DEMO\C2cool.OUT
*
= Craig 1 HEI Condenser/Cooling Tower Sub Model

```

```

*****
*       GENERIC INPUT DATA
*****

```

```

*       CYCLE FLAGS
010200   0       0       0       0       0       0       0.       0.
*
*       CYCLE CONVERGENCE DATA
012000  50       0.       0.       0.       0.       0.       0       0.

```

```

*       PEPSE OUTPUT SUPPRESSION CARDS

```

```

*****
*       GEOMETRY CARDS
*****

```

```

500100   10       U   400       S
504000   400       T   910       I
504020   400       D   700       I
509000   900       U   400       T
509900   990       U   400       D

```

```

*****
*       COMPONENT DATA
*****

```

```

*****
*       CONDENSERS AND FEEDWATER HEATERS

```

```

*       Main Condenser - HEI Model
704000   10       1       5       0.   3.17
704005   1       0.902   1.   456.  21916.   2   -0.85

```

```

*****
*       SOURCES, SINKS, AND VALVES

```

```

*       Input Component for Condenser Sub Model
700100   33       0.   1.556  1954043.   0.  1044.916016

```

```

* Circ Water Inlet From Cooling Tower
709000 31 84. 30. -141843. 0. 0.
* Condenser Drain Inlet Flow
709900 31 0. 30. 2600. 0. 719.900024
* Output Component - Condensate to Heaters
707000 32
* Hot Water To Cooling Tower - Sink
709100 30

```

```

*****
* SPECIAL FEATURES
*****

```

```

***** SCHEDULES

```

```

*
800100 '90% Design Flow'
* X VALUES
810100 45. 50. 55. 60. 65.
* Z AND Y VALUES
810110 19. 69.000000 71.500000 74.000000 76.750000 79.500000
810120 23. 72.000000 74.000000 76.300003 78.800003 81.500000
810130 27. 74.250000 76.300003 78.500000 80.750000 83.250000
810140 31. 76.650002 78.300003 80.500000 82.500000 84.750000

```

```

*
800200 '100% Design Flow'
* X VALUES
810200 45. 50. 55. 60. 65.
* Z AND Y VALUES
810210 19. 71.000000 73.500000 75.750000 78.400002 81.250000
810220 23. 74.000000 76.199997 78.500000 80.750000 83.250000
810230 27. 76.500000 78.000000 80.599998 82.750000 85.000000
810240 31. 77.800003 80.599998 82.500000 84.500000 86.750000

```

```

*
800300 '110% Design Flow'
* X VALUES
810300 45. 50. 55. 60. 65.
* Z AND Y VALUES
810310 19. 73.500000 75.750000 78.000000 80.500000 83.000000
810320 23. 76.599998 78.500000 80.750000 83.000000 85.500000
810330 27. 79.250000 81.000000 83.199997 85.000000 87.500000
810340 31. 81.500000 83.300003 85.250000 87.000000 89.000000

```

```

***** SCHEDULE VARIABLES

```

```

*
* 90% Design Flow Cold Water Temp
830100 1 OPVB 100 OPVB 52 OPVB 53
*
* 100% Design Flow Cold Water Temp
830200 2 OPVB 101 OPVB 52 OPVB 53

```

```

*
* 110% Design Flow Cold Water Temp
830300      3  OPVB  102  OPVB  52  OPVB  53
*
***** OPERATIONAL VARIABLES
*
* OPVB(2) = -1.0
870020      -1.
* Set OPVB(40) = 0.333
870400      0.333
* Set OPVB(41) = 100.0
870410      100.
* Design Circ Water Flow
870420      153000.
* 90% Design Flow
870430      137700.
* 110% Design Flow
870440      168000.
* Design Fan Horsepower
870500      170.
* As Tested Tower Capability
870510      100.
* Test Wet Bulb Temperature
870520      63.
* Cooling Range - For Debug
870530      26.799999
* Test Flow
870540      153000.
* Test Fan Horsepower
870550      170.
*
***** OPERATIONS
*
* Des HP/Test HP
880560      OPVB      50      DIV      OPVB      55      OPVB      56
* OPVB(56)^1/3
880570      OPVB      56      TO      OPVB      40      OPVB      57
* OPVB(57)*TEST FLOW
880580      OPVB      57      MUL      OPVB      54      OPVB      58
* Calculate Predicted Flow
880600      OPVB      58      MUL      OPVB      41      OPVB      60
* Finish Predicted Flow Calculation
880610      OPVB      60      DIV      OPVB      51      OPVB      61
* Calculate Cooling Range
880650      TT      402      SUB      TT      900      OPVB      53
* Test Flow > Design = 0:Test Flow < Design = 1
881100      OPVB      61      BIF      OPVB      42      OPVB      110
* Test Flow < Design = 0:Test Flow > Design = 1
881110      OPVB      42      BIF      OPVB      61      OPVB      111
* Calculate Slope Between 90% and 100% Design Flow
881200      OPVB      101      SUB      OPVB      100      OPVB      120
* Denominator

```

```

881210    OPVB      42      SUB      OPVB      43      OPVB      121
* Calculate Slope
881220    OPVB      120     DIV      OPVB      121     OPVB      122
* Multiply Result * Bound (111)
881230    OPVB      122     MUL      OPVB      111     OPVB      123
* Calculate Slope Between 100% and 110% Design Flow
881250    OPVB      102     SUB      OPVB      101     OPVB      125
* Denominator
881260    OPVB      44      SUB      OPVB      42      OPVB      126
* Calculate Slope
881270    OPVB      125     DIV      OPVB      126     OPVB      127
* Multiply Result * Bound (110)
881280    OPVB      127     MUL      OPVB      110     OPVB      128
* Add Resultant Slopes to Yield One Slope
881300    OPVB      128     ADD      OPVB      123     OPVB      130
* Calculate Intercept Based on Know Flow and CWT
881400    OPVB      130     MUL      OPVB      42      OPVB      140
* CWT - MX = INTERCEPT
881410    OPVB      101     SUB      OPVB      140     OPVB      141
* Calc Predicted CWT -- Slope * Predicted Test Flow
881500    OPVB      130     MUL      OPVB      61      OPVB      150
* Add Intercept to Yield Cold Water Temp
881600    OPVB      150     ADD      OPVB      141     OPVB      160
* Input CWT to Circ Water Source
881700    OPVB      160     EQL      TTVSC     900
* Input Test Flow to Circ Water Inlet Source
881710    OPVB      54      MUL      OPVB      2      WWVSC     900

```

```

*
***** SPECIAL INPUT/OUTPUT

```

```

*
891000    'Cold Water Temp to Condenser'
891001    OPVB      160
891009    F5.1

```

```

*
*
.
```

APPENDIX B

SPECIAL DATA

MAIN SURFACE CONDENSER

Size sq. ft.	<u>218000</u>
Number of Water Passes	<u>2</u>
Steam Condensed lbs/hr	<u>1954043</u>
Cooling Water g.p.m.	<u>141843</u>
Cooling Water Temperature °F	<u>84</u>
Tube Cleanliness Factor %	<u>85</u>
Absolute Pressure inches of Hg	<u>3.17</u>

Tubes	Air Core Section and Impingement Areas	Bulk of Condenser
Number	1760	20156
Size O.D.	1.00"	1.00"
Wall	18 BWG	18 BWG
Length	38'2.5"	38'2.5"
Material-ASTM	B-111 90-10 CuNi Alloy 706	B-111 Admiralty-Alloy 44


APPENDIC C

PERFORMANCE CURVE
 FOR
 COLORADO-UTE ELECTRIC ASSOCIATION
 CRAIG STATION UNIT 1 OR 2

MODEL 6516-4-10 COOLING TOWER
 336 HP 4-8 FANS AT 1700 RPM 7137 RPM
 DESIGN 153,000 GPM AT 119.6-84-63

THE HARLEY COOLING TOWER COMPANY
 MISSION, KANSAS
 O.O. 12-197-74 / 12-209-74

90% DESIGN FLOW
 137,700 GPM




PERFORMANCE CURVE
FOR
COLORADO UTILITY ELECTRIC ASSOCIATION
CRAIG STATION UNIT 1-CR-2

MODEL 6516-4-10 COOLING TOWER
336 HP 4-8 FANS AT 1701 BHP 2137 RPM
DESIGN 153,000 GPM AT 119.8-84-63

THE HARLEY COOLING TOWER COMPANY
MISSION, KANSAS
O.D. 12-197-74 / 12-209-74

100% DESIGN FLOW
153,000 GPM



PERFORMANCE CURVE
 FOR
 COLORADO ELEC TRIC ASSOCIATION
 CRAIG STATION UNIT 1 OR 2

MODEL 6516 4-19 COOLING TOWER
 335 HP 4-8 FANS AT 1701 BHP 7137 RPM
 DESIGN 153,000 GPM AT 110.8 54 63

THE MARLEY COOLING TOWER COMPANY
 MISSION, KANSAS
 O.C. 12 197-74 / 12 209-74

110% DESIGN FLOW
 168,300 GPM

