

Temperature Effects on Reheat when
Sending Process Steam to a Wallboard Plant
(Drying Gypsum)
At Winyah Station

Leif Svensen P.E.

Santee Cooper

2006

Abstract

This study is to determine the impact of supplying 113,750,000 Btus/hour heat to a wallboard plant for drying Gypsum. The plant will be on a piece of land adjacent to our Winyah Generating Station and the steam will be coming from one of the units on the site. After a short review, we decided that the most feasible location for this extraction is the cold reheat line. We also considered one other location that which was a closer match for the process's desired steam conditions, the extraction just before the crossover line. This location was not selected because General Electric determined that it would require a major modification to the extraction nozzle. The cold reheat extraction point did not require major modifications. To determine the value of the steam we ran turbine models first. I then ran combined the turbine/boiler models to find the effects of taking this steam from the cold reheat line and the impact it has on superheat and hot reheat temperature.

Introduction

Winyah Generating Station is located in Georgetown, South Carolina. It has four generating units Winyah 1, 2, and 3 are General Electric (GE) turbines and Winyah 4 is a Westinghouse turbine. All have a gross output of 303 MW at 1,983,000 lbs./hr steam flow, 1000/1000 °F throttle/reheat inlet temperatures, 2 inches Hg condenser pressure and 2,400 psig throttle pressure. All the boilers are Riley coal fired boiler and rated at 2,100,000 lbs./hr, 1005/1005 °F superheat/ reheat temperatures and 2,475 psig superheater outlet pressure. The boiler for Winyah 1 is a wall-fired unit Winyah 2, 3, and 4 are turbo-fired units with Winyah unit #2 having a radiant reheater section. Winyah unit #1 operates at a lower than design reheat temperature. This has been since the unit's start date and it is determined that the design of the boiler is the cause.

With upgrades and the addition of new sulfur scrubbers and the station's capability to produce wallboard quality gypsum, Santee Cooper has searched for buyers to use this new "product" stream. Siting the wallboard plant on site proved to be the optimal solution. A wallboard manufacturer is now under contract to purchase the Gypsum. This plant will require approximately 113,750,000 Btus/hour of heat in the drying process that is supplemented with natural gas for temperature control. One Winyah unit at a time will supply the heat for the process but all four could have the capability to supply the steam. At this point in time only Winyah units 1 and 3 are being considered to supply the steam.

This paper will concentrate on Winyah unit #1 boiler since it operates with the reheat temperature that is anywhere 20 °F to 50 °F deficient throughout the generation range.

PEPSE Modeling

We used two models to complete this study, a turbine model created in 1996 and a boiler model created in 2002. The turbine model was developed with the heat balances from 1995 blading change out to the aero design for the high-pressure and intermediate pressure turbine sections. See my paper from the June 11-14, 1996 users group meeting titled "Customization of GE Turbine Expansion Line Curves to Model a GE Advanced Aero Design Steam Turbine Upgrade". This model was then linked to a boiler model of Winyah Unit #1 boiler. Both of these models are also setup to run multi-load PEPSE® cases.

This boiler is a Riley unit with an in service date of 1975. It originally did not attain reheat temperature during its acceptance tests and had the reheat surface area increased in 1977. After the second addition of surface the unit operated at higher temperatures but with the installation of low NO_x burners reheat temperature is a concern again. The boiler modeling was first completed using the original design data from 1975 and matched with the original test data. Next, a model with the increased surface area was constructed. I also benchmarked this model to test data from 1977. The unit was still short on reheat temperature.

At the time of boiler modeling we noticed that the as built economizer surface area square footage was less than the original specification. We ran another model with the original specified area and got increases in both superheat and reheat temperatures of about 5 °F and 15 °F respectively. This

showed us that an increase in economizer surface area could help the temperature situation.

To link these two PEPSE® models I use special option 11. To keep the modeling simple I decided not to transfer any spray flows between models and let the superheat and reheat temperatures rise. The biggest dilemma was in how I should run the boiler model. I decided that for the base cases (no steam flow to the Wallboard plant) that to balance the drum I would use fuel flow. When running the cases in which there is steam sent to the Wallboard plant that I balance the drum in the boiler model using feedwater flow. I decided on this because I wanted to see what the effects were when the fuel flow was fixed to the amounts that are in the baseline PEPSE® runs. Each model has some unique modeling modifications to achieve the desired results.

I modified the turbine model by the addition of a heat exchanger to simulate the effect of the wall board plant.. I have modeled this heat exchanger's steam supply coming from the cold reheat line. In the model the heat exchanger drains into the inlet to the deaerator. The wallboard plant will take and condense the steam returning condensate to a point in the steam cycle close to the returning wallboard condensate. This drying process requires a fixed amount of energy, which amounts to 113,750,000 Btus/hr (see Figure 1 below).




Figure 1

I also used controls for the base cases to control the steam flow in order to get the desired

generation output. This was to have the base cases at set outputs. I could then compare these base cases to the cases using process steam to show the amount of generation lost that the PEPSE® runs predicted. An example of this control is shown in the figures 2 and 3.

W1gypdyD.MDL, Control : 2, Set : 1

Required Data Optional Data Gain Values (Optional) Shutoff (Optional)

CONTROL INPUT DATA

Description: control steam flow for MWg output

Goal value, Y VALYC = 190.0

Goal convergence criterion YCNVRG = 0.001

Goal variable Y definition (Press F1 for help, equation 15-1)

| | Variable Name | Variable ID | Multiplier C(i) (optional, default=1.0) |
|----------------|---------------|-------------|--|
| Y(1), required | BKGROS | 0 | 1.0 |
| Y(2), optional | | 0 | 1.0 |
| Y(3), optional | | 0 | 1.0 |
| Y(4), optional | | 0 | 1.0 |
| Y(5), optional | | 0 | 1.0 |

Control variable name, X CXVAR = WWVSC

Control variable ID NXUIDC = 10

Optional

Initial value of control variable XINVAL = 0.0

OK Cancel Notes Copy to... Steam Tables...

Figure 2

W1gypdyD.MDL, Control : 2, Set : 1

| Required Data | Optional Data | Gain Values (Optional) | Shutoff (Optional) |
|---|---|---|--|
| CONTROL INPUT DATA | | | |
| Control iteration interval | | INRCON = | <input type="text" value="3"/> |
| PEPSE iteration when control initiates | | IBGCON = | <input type="text" value="0"/> |
| Control relaxation factor | | RELAXC = | <input type="text" value="0.0"/> |
| Factor for limiting the fractional change of X | | FUPMXA = | <input type="text" value="0.0"/> |
| Factor for limiting the size of the X increment | | FUPMXB = | <input type="text" value="0.0"/> |
| Control deletion status (enter DELETE or leave blank) | | STATUS = | <input type="text" value="DELETE"/> |
| Minimum value of control variable | | XCLO = | <input type="text" value="1000000.0"/> |
| Maximum value of control variable | | XCHI = | <input type="text" value="2250000.0"/> |
| Control calculation method flag: | <input type="text" value="Standard"/> ▾ | | |
| <input type="button" value="OK"/> | | <input type="button" value="Cancel"/> | |
| <input type="button" value="Notes"/> | | <input type="button" value="Copy to..."/> | |
| <input type="button" value="Steam Tables..."/> | | | |

Figure 3

To the boiler model base cases I wrote the control for drum energy balance to use furnace exit gas temperature to balance the drum. An example of this is in Figure 4.

W1gyp04cm1.MDL, Control: 1, Set: 1

Required Data Optional Data Gain Values (Optional) Shutoff (Optional)

CONTROL INPUT DATA

Description: CONTROL TO DRUM ENERGY BALANCE

Goal value, Y VALYC = 1.0

Goal convergence criterion YCNVRG = 100000.0

Goal variable Y definition (Press F1 for help, equation 15-1)

| | Variable Name | Variable ID | Multiplier C(i) (optional, default=1.0) |
|----------------|---------------|-------------|--|
| Y(1), required | BBEIBC | 30 | 0.0 |
| Y(2), optional | | 0 | 0.0 |
| Y(3), optional | | 0 | 0.0 |
| Y(4), optional | | 0 | 0.0 |
| Y(5), optional | | 0 | 0.0 |

Control variable name, X CXVAR = TEXTF

Control variable ID NXUIDC = 10

Optional

Initial value of control variable XINVAL = 0.0

OK Cancel Notes Copy to... Steam Tables...

Figure 4

For the PEPSE® cases sending process steam out to the customer I used a control to balance the drum by using feedwater flow. This is because in these cases I have the fuel flow fixed at the base cases amount and this turned out to be one of the better options for insuring the model converged. Figure 5 is what this control looked like.

W1gyp04cm9.MDL, Control: 19, Set: 1

Required Data Optional Data Gain Values (Optional) Shutoff (Optional)

CONTROL INPUT DATA

Description:

Goal value, Y VALYC =

Goal convergence criterion YCNVRG =

Goal variable Y definition (Press F1 for help, equation 15-1)

| | Variable Name | Variable ID | Multiplier C(i) (optional, default=1.0) |
|----------------|---------------|-------------|--|
| Y(1), required | BBEIBC | 30 | 0.0 |
| Y(2), optional | | 0 | 0.0 |
| Y(3), optional | | 0 | 0.0 |
| Y(4), optional | | 0 | 0.0 |
| Y(5), optional | | 0 | 0.0 |

Control variable name, X CXVAR =

Control variable ID NXUIDC =

Optional

Initial value of control variable XINVAL =

OK Cancel Notes Copy to... Steam Tables...

Figure 5

The two models were linked using special option 11. Note that the boiler is moving feedwater flow to balance the drum energy. To insure that this feedwater flow is transferred back to the turbine model from the boiler model you do not apply the negative sign in front of the steam flow component receiving flow from the boiler model (figure 7). In this case the component receiving the feedwater flow is component number 10. The next two figures (6 and 7) illustrate how to link the two models.




Figure 6




Figure 7

The Appendix has the PEPSE® schematics for the boiler and the turbine models along with some schematics with results on them for full load without and with the process steam.

Results

The results of this study are that the hot reheat temperature will improve along with smaller improvements in superheat temperature. This will happen throughout the loading range and since the process steam requirement is for a fixed amount of heat, the improvements are greater at the lower loads. This is very helpful since both superheat and reheat temperatures “fall off” in these lower load ranges. The gain in reheat temperature is between 17 °F and 32 °F; the superheat temperature gain is between 4 °F and 6 °F. The modeling results are in the tables below.

Overall Results – Table 1

| Case | | 1A | 1B | 2A | 2B | 3A | 3B | 4A | 4B |
|-----------------|--------|---------|---------|---------|---------|---------|---------|---------|---------|
| Fuel Flow | Lbs/hr | 206,142 | 206,142 | 194,194 | 194,194 | 164,917 | 164,917 | 129,228 | 129,228 |
| Process Flow | Lbs/hr | 0 | 113,567 | 0 | 114,015 | 0 | 117,488 | 0 | 117,296 |
| Output | MWg | 319.0 | 308.1 | 299.8 | 288.9 | 249.9 | 239.3 | 190.0 | 179.6 |
| Superheat Temp. | °F | 1,006.9 | 1,012.6 | 1,003.7 | 1,008.8 | 944.8 | 949.3 | 931.9 | 936.2 |
| Reheat Temp. | °F | 978.2 | 996.3 | 955.4 | 973.2 | 931.4 | 958.1 | 852.1 | 883.6 |

Conclusions

Projects arise that use knowledge obtained from previous experience and older PEPSE models. As in this case, the modeling uses newly developed boiler models running them with modified turbine models that have the steam side information. In this case we are able to show that we can improve the operating temperatures of the unit by sending this steam to the process. We can also see the impacts over the expected operating range of the unit.


References

The following references were used during the course of the analysis and in preparation of this paper.

- 1 - PEPSE computer code, Scientech Inc, PO box 50736, Idaho Falls, Idaho, Version 62H
- 2 - PEPSE manual: volumes I, II, III, IV, Scientech Inc, PO box 50736, Idaho Falls, Idaho, Version 62H


Appendix

Winyah Unit 1 VWO MW w/ 0 Btu to process




**Winyah Unit 1 VWO MW w/ 0
Btu to process**


320.8 MW
7626.8
2100000#



**Winyah Unit 1 VVO MW w/
113,750,000 Btu to
process**

308.1 MW
7910.2
2076709#





W1 1,486,523/ 100,000 process

03/27/06

Roof Tubes

Screen Wall

Primary SH Upper

Reheat Upper

Division Walls

Rear WW - Convection

Side WW - Convection

Reheat - Middle

Primary SH - Middle

Side Walls - Convection


SuperHeat - Rear Wall

Reheat - Lower

Primary SH - Lower


Economizer

202411#
150.0#
3129.4#



Winyah Unit 1 300 MW w/ 0 Btu to process


299.8 MW
7673.4
1976854#



| Special Output | | |
|---------------------------|----------|-----------|
| Gross MW | 299.81 | MW |
| Net heat rate | 7673.4 | BTU/KW-HR |
| Throttle pressure | 2422.8 | PSIA |
| Throttle temperature | 1003.7 | DEG-F |
| Throttle flow | 197685.4 | LBM/HR |
| hot reheat pressure | 530.03 | PSIA |
| hot reheat temperature | 955.42 | DEG-F |
| condenser pressure | -2 | -IN-HG |
| Process Steam Flow | 0.0 | LBM/HR |
| Process Steam press | 126.63 | PSIA |
| Process Steam temp | 611.27 | DEG-F |
| Process Steam return temp | 11.27 | DEG-F |
| Cold Reheat press. | 580.72 | PSIA |
| 1st Stage Press | 1905.2 | PSIA |

Winyah Unit 1 300 MW w/ 113,750,000 Btu to process


288.9 MW
7571B/kWh
1956070#




| Special Output | | |
|---------------------------|---------|-----------|
| Gross MW | 288.94 | MW |
| Net heat rate | 7964.6 | BTU/KW-HR |
| Throttle pressure | 2425.4 | PSIA |
| Throttle temperature | 1008.8 | DEG-F |
| Throttle flow | 1956070 | LBM/HR |
| hot reheat pressure | 495.85 | PSIA |
| hot reheat temperature | 973.16 | DEG-F |
| condenser pressure | -2 | -IN-HG |
| Process Steam Flow | 0.0 | LBM/HR |
| Process Steam press | 118.45 | PSIA |
| Process Steam temp | 625.03 | DEG-F |
| Process Steam return temp | 38.61 | DEG-F |
| Cold Reheat press. | 542.91 | PSIA |
| 1st Stage Press | 1889.4 | PSIA |
| Heat rate | 7064.6 | Net-Spec |

Winyah Unit 1 250 MW w/ 0 Btu to process

249.9 MW
7857.2
1676398#





| Special Output | | |
|---------------------------|---------|-----------|
| Gross MW | 249.91 | MW |
| Net heat rate | 7857.2 | BTU/KW-HR |
| Throttle pressure | 2464.5 | PSIA |
| Throttle temperature | 944.84 | DEG-F |
| Throttle flow | 1676398 | LBM/HR |
| hot reheat pressure | 446.99 | PSIA |
| hot reheat temperature | 931.38 | DEG-F |
| condenser pressure | -2 | -IN-HG |
| Process Steam Flow | 0.0 | LBM/HR |
| Process Steam press | 107.32 | PSIA |
| Process Steam temp | 591.96 | DEG-F |
| Process Steam return temp | 691.96 | DEG-F |
| Cold Reheat press. | 488.81 | PSIA |
| 1st Stage Press | 1535.5 | PSIA |
| Heat rate | 7857.2 | Not-Speed |



**Winyah Unit 1 250 MW w/
113,750,000 Btu to
process**

239.3 MW
8207.0
1658780#






05/16/05


Winyah Unit 1 190 MW w/ 0 Btu to process

190.0 MW
8164.3
1324258#




| Special Output | | |
|---------------------------|----------|-----------|
| Gross MW | 189.96 | MW |
| Net heat rate | 8164.3 | BTU/KW-HR |
| Throttle pressure | 2498.0 | PSIA |
| Throttle temperature | 931.86 | DEG-F |
| Throttle flow | 13242.58 | LBM/HR |
| hot reheat pressure | 345.49 | PSIA |
| hot reheat temperature | 852.12 | DEG-F |
| condenser pressure | -2 | -IN-HG |
| Process Steam Flow | 0.0 | LBM/HR |
| Process Steam press | 83.31 | PSIA |
| Process Steam temp | 530.85 | DEG-F |
| Process Steam return temp | 80.85 | DEG-F |
| Cold Reheat press. | 378.17 | PSIA |
| 1st Stage Press. | 1188.8 | PSIA |
| Heat rate | 8164.3 | Not-Speed |

W1 1,486,523/ 100,000 process



**Winyah Unit 1 190 MW w/
1.1375E6 Btus to
process**

179.6 MW
8636.2
1309381#



| Special Output | | |
|---------------------------|---------|-----------|
| Gross MW | 179.64 | MW |
| Net heat rate | 8636.2 | BTU/KW-HR |
| Throttle pressure | 2499.0 | PSIA |
| Throttle temperature | 936.27 | DEG |
| Throttle flow | 1309381 | LBM/HR |
| hot reheat pressure | 313.35 | PSIA |
| hot reheat temperature | 883.58 | DEG |
| condenser pressure | -2 | IN |
| Process Steam Flow | 0.0 | LBM/HR |
| Process Steam press | 75.50 | PSIA |
| Process Steam temp | 554.60 | DEG |
| Process Steam return temp | 106.31 | DEG |
| Cold Reheat press. | 342.69 | PSIA |
| 1st Stage Press | 1180.3 | PSIA |
| Heat rate | 8636.2 | OPVB |

