

**The Development of a Design Mode
Fluidized Bed Plant Model Using the
PEPSE® Heat Balance Code**

Al Hall

Montana-Dakota Utilities Co.

Gene L. Minner

HALLIBURTON NUS Environmental Corporation

THE DEVELOPMENT OF A DESIGN MODE
FLUIDIZED BED PLANT MODEL USING
THE PEPSE® HEAT BALANCE CODE

Al Hall
Montana-Dakota Utilities Co.

Gene L. Minner
HALLIBURTON NUS Environmental Corporation

ABSTRACT

The use of a fluidized bed combustor in an electric utility power plant offers several potential benefits. This paper discusses the benefits that were the motivating factors to the choice of such a system for the lignite fueled Heskett Station of Montana-Dakota Utilities. In brief there are advantages relating to atmospheric pollution control, combustion-zone heat transfer, and capabilities to combust poor-grade fuels.

In the Heskett Station, the fluidized bed combustor replaced a more conventional boiler furnace for the production of superheated steam to a steam turbine generator cycle. Early operation of the new system revealed shortcomings in attaining the needed main steam set point temperature. This paper discusses the development of a PEPSE analysis model of the new Heskett Station to aid in the understanding of the problem and to calculate performance behavior of considered improvements to the system.

INTRODUCTION

Coal combustion in a fluidized bed for steam generation to a steam turbine generator cycle is a relatively recent application. As such, the analysis, diagnosis, and remediation of troublesome operation is in a state of development.

The staffs of Montana-Dakota Utilities and of the HALLIBURTON NUS Environmental Corporation have collaborated to enhance the PEPSE® heat balance computer program for analyses of fluidized bed steam generators. These enhancements have added two new components to PEPSE's existing library. These are the fluidized bed combustor and the in-bed heat exchanger components. The added computations for these components include performance and/or design mode capabilities and embody such effects as bed depth and chemical reactions of limestone for flue gas pollution control.

With the new components in place, it is now possible to analyze the performance of a complete power generation system that employs the fluidized bed for fuel combustion. Such a complete system analysis was necessary in order to investigate scenarios for remedying a shortfall of superheat temperature for the MDU Heskett Power Station.

A PEPSE model has been developed, making extensive use of design mode capabilities for the heat source and the turbine cycle for this station. Discussed here are the background, the highlights of the model development, and conclusions from the work. Also mentioned, in passing, are some observations from experiences of using the 386 machine version on a 486 PC.

Montana-Dakota Utilities

Montana-Dakota Utilities is a relatively small Electric and Natural gas utility. "MDU COUNTRY", as it is called, occupies eastern Montana, most of North Dakota, north western South Dakota, and north central Wyoming. That is 168,100 square miles, or 5 1/4% of the continental United States. The actual peak obligation in 1990 was about 450 mW.

Generation capabilities include the Heskett Station in Mandan, North Dakota, Lewis and Clark Station in Sidney, Montana, Coyote Station in Beulah, North Dakota, Big Stone Plant in Milbank, South Dakota, and 4 gas turbines located in Miles City, Montana, Glendive, Montana, and Wiliston, North Dakota.

The system obviously spans extensive territory.

Fluidized Bed Combustion

The Electric Utility industry has for many years had to address many environmental problems. Currently these include acid rain and global warming from the "greenhouse effect". Both of these are a result of increased emissions of nitrous oxides, and sulfur dioxide. In addition, carbon dioxide is a major contributor to the "greenhouse effect". Utility boilers burning hydrocarbons, such as coal, are a major contributor to these emissions.

Atmospheric Fluidized Bed Combustion continues to be proven as a viable method for burning coal with reduced emissions of NO_x and SO_2 . In AFBC, air for combustion is forced upward through a mixture of limestone (or other material) and fuel (normally coal) at a velocity great enough to suspend, or fluidize the material. The presence of the limestone introduces chemical reactions that reduce the emissions of SO_2 . NO_x is reduced due to lower combustion temperatures.

The fluidization phenomenon is achieved by blowing a gas (air) up through the particulate from the bottom of the bed. The gas velocity at which fluidization first occurs is referred to as "the minimum fluidization velocity" (see Figure 1). At this velocity, the particles are just suspended in the gas stream, with no relative motion observed. As the gas velocity is increased, bubbles, or pockets, of air begin to form in the dense phase of the bed and the particles begin to move about. This is known as a bubbling bed.

As the gas velocity is increased further, the bubbling action becomes more violent, and the bed enters a turbulent mode. In this mode, more of the bed particles are carried out of the




Figure 1
Modes of fluidization of fine particles [1]

bed by the gas stream. These particles are then captured and returned to the bed. This mode is referred to as a Circulating Fluidized Bed.

In a fluidized bed, a portion of the fuel is burned within the dense phase and the rest is burned in the "freeboard" region above the dense region. The heat is removed through immersed heat exchange surfaces within the dense phase of the bed. The agitated movement of material in the bed results in a uniform temperature throughout the bed.

MDU Heskett Station

Montana-Dakota Utilities Heskett Station, Unit 1 (see Figure 2) uses a Riley Spreader Stoker boiler to burn lignite fuel for steam generation. It is a small unit at 25 mW. Since its construction in 1953, it has proved to be a very dependable unit. Unit 1 has been so dependable, in fact, that in 1963, when Unit 2 was built, the same basic design was used, on a larger scale. It was to be rated at 66 mW.

Using the same lignite fuel as Unit 1, Unit 2 (see Figure 3) did not operate nearly as well. Even after major convection pass surface changes, the boiler had severe fouling and slagging problems in the convection pass. It was not uncommon to totally foul the boiler in a period of only 2 months.

The decision to convert the boiler to fluidized bed combustion was made in 1986. This conversion offered many advantages for the future such as: reduced temperatures leaving the furnace, reduced sootblowing, reduced NO_x and SO₂, and generation increased up to 80 mW.

The conversion project proceeded very quickly (see Figure 4). Demolition in the existing boiler proceeded in December of 1986, and first fire was achieved in May of 1987.

Operation to date has not been without problems. However, the availability of the unit for 1990 was greater than 90% (see Figure 5). The major problem has been deficient superheat




FIGURE 2

MONTANA-DAKOTA UTILITIES
HESKETT STATION UNIT 1




FIGURE 3

MONTANA-DAKOTA UTILITIES
HESKETT STATION UNIT 2




Figure 4
Heskett Unit Side View

1990 Unit Availability Heskett #2




FIGURE 5

HESKETT STATION UNIT 2
1990 AVAILABILITY

leaving the bed. Presently, additional superheat surface is being installed in the convection pass of the original boiler. This should solve the problem. But will it? An analysis should provide an answer to this question.

PEPSE Design Mode Plant Model

To best evaluate this problem, it was felt that a full plant model would be needed. Such a model includes a complete turbine and design mode condenser and feedwater heaters, and a complete design mode fluidized bed boiler. The design mode components were necessary so that each section would properly float and reflect the impacts of the changes that occur with the new surface addition.

The entire model schematic was initially drawn and input to the PEPSE Graphics/Database program of the PC Version 56. Figure 6 shows this system schematic. The initial component descriptions were specified in performance mode. This model was based on sketchy heat balances from the original 650,000 lb/hr turbine information, new fluidized bed boiler design information, and operational data. Therefore, there was much information that was missing and thus needed to be determined. The performance mode model was then tuned and some of the unknowns were determined.

The design mode components were each built using submodels (see Figure 7). The HEI condenser and each of the feedwater heaters were quite easy to model. These components were then installed one by one in the plant model. This process occurred smoothly without significant problems.

Next, the boiler portion of the model was developed (see Figure 8). The submodel was relatively more complex than the earlier design mode feedwater heaters because several components were needed in combination including a Type 71 fluidized bed component and the two enclosed in-bed heat exchangers. Unlike the normal Type 70 combustor, the Type 71 Fluidized Bed Combustor can intermingle the performance and design modes for the resident heat exchanger components. This capability made the submodeling of each of these






FIGURE 6
HESKETT STATION UNIT 2
PLANT MODEL



DEAREATING HEATER




FEEDWATER HEATER

CONDENSER

FIGURE 7

HESKETT STATION UNIT 2
PLANT MODEL
SUB-MODEL EXAMPLES



F
L
U
I
D
I
Z
E
D
B
E
D
C
O
N
B
U
S
T
O
R

FIGURE 8

HESKETT STATION UNIT 2
PLANT MODEL
FLUIDIZED BED SUB-MODEL

two much easier. After these were properly tuned, they were inserted into the plant model and tested.

The design walls were then developed in a submodel. This component was a little awkward because the Type 28 heat exchanger was not designed to model a wall arrangement. The Type 28 had to be customized to emulate the walls even though the input geometry looks nothing like a wall description. This took many tries to find one that yielded the desired performance simulation. The result of this effort was then inserted into the full model.

The rest of the boiler sections were then modeled individually, and inserted, one at a time, into the plant model. The model was ready to go after a minor amount of tuning.

The input data set for the full design model is included as Attachment 1. It was very pleasing that the model construction was preceding so quickly, and without major problems. At this point the running of the model had gone from about 34 iterations, to 128 iterations. This compared favorably with past experiences with complete plant models.

Next the added surface was included in the convection pass superheat component. The number of iterations for the calculation did not change, but the final steam temperature was too high now (as it should have been). Now the attemperator needed to be activated in order to reduce the steam temperature.

The attemperator modeling included a single control on the flow from the feedwater splitter to obtain a desired superheat outlet temperature. When this was activated, the number of iterations jumped to about 375 for convergence of 1.0×10^{-3} . On the 486-33 this run took only about 45 minutes.

The next obvious step, was to reduce the run time. A considerable amount of time was spent changing iteration initiations, interval of applications, relaxation factors and other parameters to finally reduce the iterations to 139 (or about 15 minutes). The study was

completed, indicating that YES the surface addition was adequate to raise the superheat to 955 degrees Fahrenheit.

Conclusions

Some of the key points in successfully building a plant model are:

1. It helps to begin with a simplified model, with components initially represented in performance mode. Design components are often easily developed in submodels.
2. Install a steam flow stabilizer in the main steam line after the last boiler superheat stage, and before the throttle valve.
3. Use only one envelope. The use of more envelopes caused no improvement in run time.
4. Good initial construction of the performance mode plant model. Make it as complete and refined as you can initially.
5. Patience - as shown by this work, such a complex model can be made to converge.

PEPSE-386 Operation Using a 486 Machine

The PEPSE 386 Version 56 operated extremely well and quickly on the 486 machine, and it offers many advantages over the mainframe version:

1. Speed. A model run on the PC runs about 10 times faster than on the PRIME mainframe.
2. Ability to observe the convergence criteria change from iterate to iterate. This allows the user to interrupt the run at any time when he feels that the run is diverging.

3. Ability to interrupt the run at any time and check to see values throughout the model, and then resume the run.

ATTACHMENT 1

**PEPSE Data Set
and Output Results**

LISTING OF INPUT DATA FOR CASE 1

```
010001    80    * 80 column output
*
*      PEPSE USER : ADMIN
*      DATE : 05/10/91
*      TIME : 12:17
*      MODEL FILE ID : H2P
*      JOB FILE ID : \EASEPLUS\DEMO\H2P.JOB
*      RESULTS FILE ID : \EASEPLUS\DEMO\H2P.OUT
*
*= Heskett Unit 2 Plant Model
*
* This is a plant model of Heskett Unit 2 Fluidized Bed Boiler and
* its corresponding turbine cycle. This will be used for the NUS
* Performance Software Users Group meeting in New York.
* Now it is all Design Mode.
*
*
*****  
*      GENERIC INPUT DATA  
*****  

*  
*      UNITS FLAGS  
010000  ENGLISH  ENGLISH  

*  
*      CYCLE FLAGS  
010200  2      3      1      1      0      0      NDEBUG  

*  
*      GENERATOR #1 FLAGS AND DATA  
011010  1      2      1      1      3600   88235.  0.85   30.    30.    0.  
011011  0.     0.     0.  

*  
*      CYCLE CONVERGENCE DATA  
012000  500    0.     0.     0.     0.     0      0  

*  
*      NONCONVERGED CASE CONTINUATION CARD  
030000  1  

*  
*      SPECIAL FEATURES INITIATION DATA  
012001  0      0      0      0      0  

*  
*      SPECIAL FEATURES CALCULATIONAL ORDER DATA  
012002  0      0      0  

*  
*      PEPSE OUTPUT SUPPRESSION CARDS  
021000  2 4 5 6 7 8 11 12 13 14 15 16 19 21 22 23 24 25 26 28  

*
```

*

* GEOMETRY CARDS

*

500010	1	U	650	I
500020	2	U	4	I
500030	2	E	102	S
500040	4	U	6	I
500050	4	E	550	IA
500060	6	U	8	I
500070	6	E	540	IA
500080	8	U	10	I
500090	8	E	680	I
500100	10	U	12	I
500110	10	E	530	IA
500120	12	U	100	S
501000	100	T	370	I
501030	100	D	420	I
501020	102	T	220	T
501050	102	D	104	D
501040	104	T	102	T
501060	104	D	106	D
501090	106	D	450	I
501080	108	T	106	FW
501110	108	D	110	D
501100	110	T	520	IA
501120	110	D	440	I
502000	200	T	210	T
502100	210	T	430	I
502120	210	D	100	D
502200	220	T	750	FW
502220	220	D	295	T
502300	230	T	570	IB
502400	240	T	570	IC
502420	240	D	500	IA
502500	250	T	570	IA
502520	250	D	270	S
502600	260	T	510	IA
502620	260	D	240	S
502700	270	T	280	T
502720	270	D	260	S
502800	280	T	300	I
502900	290	T	295	S
502920	290	D	530	IB
502950	295	T	410	I
502970	295	D	700	IA
503000	300	U	399	I
503100	310	U	100	T
503200	320	U	600	I
503300	330	U	700	IS
503400	340	U	700	IF
503990	399	U	640	I
504000	400	U	290	T

504100	410	U	380	I
504200	420	U	200	T
504300	430	U	110	T
504400	440	U	520	IB
504500	450	U	620	I
505000	500	U	220	S
505100	510	U	270	T
505200	520	U	108	T
505300	530	U	110	S
505400	540	U	106	S
505500	550	U	104	S
505600	560	U	210	S
505700	570	U	750	RI
506000	600	U	610	I
506010	600	B	400	I
506100	610	U	350	I
506110	610	B	500	IB
506200	620	U	104	T
506210	620	B	510	IB
506300	630	U	250	T
506310	630	B	460	I
504600	460	U	230	T
506320	630	C	240	T
506400	640	U	1	I
506410	640	B	660	I
506500	650	U	2	I
506510	650	B	670	I
506600	660	U	550	IB
506610	660	B	560	IA
506700	670	U	560	IB
506710	670	B	540	IB
506800	680	U	108	S
506810	680	B	290	S
507000	700	U	250	S
507010	700	B	360	I
507500	750	ST	260	T
507510	750	DC	630	I

*

*

* SPECIAL STREAM SPECIFICATIONS

*

***** STREAM TYPES 1 - 6

*

* Initialization flow for Bed Outlet Gasse

607000 6 1 1 3100. 14.7 948098.

607001 AIRB -0.013

*

```

*
***** COMPONENT DATA *****
*
***** TURBINES
*
* Governing Stage
700010 4 1 2 1 2 1
700011 8 0 32.849998
700012 0. 0. 0. 0.
* HP Turbine Stage
700020 7 0 1 1 1 1 0.03
700021 804. 1424.0 640600. 376.299988 44800. 0.
700022 0. 0. 0. 0. 0.
700023 0 0. 0.
* HIP Turbine Section
700040 7 1 1 1 1 1 0.03
700041 355.700012 1354. 595800. 188.199997 42500. 0.
700042 0. 0. 0. 0. 0.
700043 0 0. 0.
* IP Turbine Stage
700060 7 1 1 1 1 1 0.03
700061 188.199997 1289. 553300. 72.5 17700. 0.
700062 0. 0. 0. 0. 0.
700063 0 0. 0.
* LIP Turbine Stage
700080 7 1 1 1 1 1 0.03
700081 72.5 1211. 535600. 30.299999 40100. 0.
700082 0. 0. 0. 0. 0.
700083 0 0. 0.
* LP Turbine Section
700100 7 1 1 1 1 2 0.03
700101 30.299999 1152. 495500. 10.4 41500. 0.
700102 0. 0. 0. 0. 0.
700103 0 0. 0.
* Final LP Stage group
700120 7 1 3 0 1 2 0.
700121 10.4 1088. 454000. -1.5 0. 26.200001
700122 0. 0. 0. 0. 0.
700123 0 0. 0.
*
***** CONDENSERS AND FEEDWATER HEATERS
*
* Main Condenser
701000 10 1 5 0. -1.5
701005 1 .777 .875 312. 5870. 2 -.85 * HEI Mode condenser
* HP Feedwater Heater
701020 18 0 2 -4 0. 0.0 0.0
701021 0.495 0.625 384.8 326. 17. 1.5 10.0 10.0 6.0 4.0 * Cond.
701023 0.0 0.0 0.0 -0.8 * Mult. for HTC.
701024 71.2 35.0 6.0 0.0 0.0 0.0 0.0 0.0 -0.8 * Desuperheat
701026 48.0 6.0 4.0 * Subcooling Section
* HIP Feedwater Heater

```

701040 18 1 4 -4 0. 0.0 0.0
 701041 0.495 0.625 348. 317. 17. 1.5 10. 10. 8. 6. * Cond.
 701043 0. 0. 0. -0.8 * Mult. on HTC.
 701044 38.0 50.0 2.0 0.0 0.0 0.0 0.0 0.0 -0.8 * Desuperheat
 701046 75.0 10.0 6.0 * Subcooling Section
 * LIP Feedwater Heater
 701080 16 0 8 -4 0.
 701081 .527 .625 181. 367. 64. 1.5 8.0 8.0 12. 4. * Cond.
 701083 0. 0. 0. -1.0
 701086 35. 10. 3. 0.0 0.0 0.0 0.0 0.0 -1.0 * Subcool
 * LP Feedwater Heater
 701100 14 1 10 -4 0.
 701101 0.527 0.625 337. 226. 64. 1.5 8.0 8.0 20.0 6.0 * Cond.
 701103 0.0 0.0 0.0 -0.8
 * Deareating Heater (IP)
 701060 15 1 6 0. 0.
 701061 0. 0. 0. 0. 0. 0
 701062 0. 0. 0. 0. 0 0. 0.
 *
 ***** HEAT EXCHANGERS
 *
 * Boiler Walls
 702500 28 1 700000. 1400. -0.049
 702504 3 1 1 400. 200. 66. 1. 300. 1. 2.1 2.5
 702505 3.0 3.0 0.0 66.0 0.95 27.0 0.0 0.0 0.0
 702506 5.0 25000.0 * HTC and Area
 * Gland Steam Condenser
 702100 20 0.
 702101 0. 0. 0. 0. 0. 0. 14.2
 * Economizer
 702200 28 1 700000. 1785. 433.
 702204 3 0 2 39.333333 14.25 38.666667 24.0
 702205 36. 24. 1.6 2. 6. 3. 1713. 1719.5
 702206 0.95 27.
 * Convection Pass Boiling Surface
 702400 28 1 700000. 1400. -0.049
 702404 3 0 2 30.75 39.229 40.75 18.0 96.0
 702405 1.0 2.1 2.5 5.5 6.0 1707.0 1742.0
 702406 0.95 27.0
 * Convection Pass Primary Superheat
 702600 28 1 700000. 1400. 1.
 702604 3 0 2 25.0 39.0 18.0 16.0 93.0 16.0 2.1 2.5
 702605 9.0 5.0 0.0 0.0 0.80 20.0
 * Convection Pass Secondary Superheater
 702700 28 1 700000. 1355. 650.
 702704 3 0 2 18.0 39.0 17.0 8.0 46.0 8.0 2.1 2.5
 702705 9.0 10.0 0.0 0.0 0.80 20.0
 * Air Pre-heater
 702900 20 0.
 702901 0. 0. 0. 0. 0. 0. 0.
 * Air Heater
 702950 20
 702955 2 1.8 2.0 4.0 4.0 340.0 16430.0 1.0 2.0 20.0 1.0
 702956 20.0 0.0 0.0 0.0 -0.8

* H₂ and Lube Oil Cooler
 702000 26 3 1.
 702001 0. 0. 0. 0.
 * In-Bed Boiling Surface
 702300 24 1 700
 702304 0.2 39.0 200.0 5.0 1.7 2.5 20.0 0.95 0.75 0.55
 702305 2.0 1.0 6.0
 * In-Bed Superheater
 702800 24 1 700
 702804 955.0 39.0 150.0 2.0 1.65 2.25 20.0 0.85 0.55 0.45
 702805 2.0 1.0 6.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
 * 702806 0.0 0.0 0.0 0.0 2500.0 * Area
 *
 ***** SOURCES, SINKS, AND VALVES
 *
 * Flow Stabilizers
 703000 31 950. 1300. 700000. 0. 0.
 703002 1 1
 * Circulating Water Source
 703100 31 50. 20. 1.52E+7 0. 0.
 * Ambient Air Source
 703200 33 90. 14.7 1500000. 0. 0.
 703203 AIR, -0.013
 * Sorbent Source
 703300 31 100. 14.7 5060. 0. 0.
 703303 CO₂, 0., H₂O, 0., SO₂, 0., O₂, 0.
 703304 N₂, 0., CO, 0., H₂, 0., C, 0.
 703305 S, 0., ASH, 1.
 * Fuel Source
 703400 31 50. 14.7 137149. 0. 0.
 703403 FUEL, 6680., SSVL, 0., CO₂, 0., H₂O, 0.374
 703404 SO₂, 0., O₂, 0.112, N₂, 0.006, CO, 0.
 703405 H₂, 0.028, C, 0.396, S, 0.009, ASH, 0.075
 * Sink for Unused Combustion Air
 703500 30
 * Sink for Bed Ash
 703600 30
 * Sink for Circulating Water
 703700 30
 * Stack (Outlet Component)
 703800 32
 * Throttle Valve
 703990 35 -2. -2. -2. 0.250081 1265. 1468. 700000.
 *
 ***** PUMPS, COMPRESSORS, AND FANS
 *
 * Condensate Pump
 704200 41 40. 0. 0. 0.
 704201 0. 0. 0. 0. 0. 0.
 * Condensate Booster Pump
 704300 41 80. 0. 0. 0.
 704301 0. 0. 0. 0. 0. 0.
 * LP heater Drain Pump
 704400 41 80. 0. 0. 0.

704401 0. 0. 0. 0. 0. 0.
 * Boiler Feed Pump
 704500 41 1800. 0. 0. 0.
 704501 0. 0. 0. 0. 0. 0.
 * Boiler Circ. Pumps
 704600 41 1800. 0. 0. 0. 0. 0. 75.0 * Pressure Rise
 * Forced Draft Fan
 704000 43 17.6 0. 0. 0.
 704001 0. 0. 0.
 * Induced Draft Fan
 704100 43 14.7 0. 0. 0.
 704101 0. 0. 0.
 *
 ***** MIXERS
 *
 * Mixer to accept infiltration Air
 705000 51 1 0.
 * Mixer for Attemperator water
 705100 50 1 0.
 * Mixer for Gov.Stg. Leakage to IP
 705400 51 3 0.
 * Mixer for Throttle Valve Leakage to HIP
 705500 51 3 0.
 * Leakage Mixer Prior to Gland Steam Conde
 705600 51 4 0.
 * LP Heater drain pump Mixer
 705200 50 0 0.
 * Mixer for Air Preheater Condensate to LP
 705300 51 4 0.
 * Mixer Prior to Drum, after circulation
 705700 54 0 0.
 *
 ***** SPLITTERS
 *
 * Splitter for Air Infiltration
 706100 61 0. 100000.0
 * Combustion Air Demand Splitter
 706000 60 0. 814434. 0. 0 0.
 * Splitter for Attemporater
 706200 61 0. 0.
 * Throttle Valve Total Leakage Splitter
 706400 68 0. 0. 0.
 * Shaft Packing Total Leakage Splitter
 706500 64 260.888763 0. 0.
 *
 706600 68 0. 0. 0.
 * Final Shaft Packing Leakage Splitter
 706700 64 245.0 0. 0.
 * Spltr. for Air Preheater
 706800 61 0. 0.
 * Drum Downcommer Triple Spliter
 706300 63 0. 0.45
 706301 1 0. 0.3
 *

***** CLASS 7 COMPONENTS

*

* Fluid Bed Combustor

707000 71 600 150. 0.059 0.15 0.8
707001 980. 0. 0. 1. 0. 0.
707002 0.008 0. 0.04 0. 0.4 0.
707003 2.9 0.
707009 1500.0 1 1.0
* Boiler Drum ID

707500 73 0 340 1400. 0. 0. 0.
707509 10 3 1.0 100000. 150000.

*

***** CONTROLS

* ATEMPERATOR

706200 61 0. 10000.0 * Guess the attemperator flow
*** CARD ABOVE IS A REPLACEMENT CARD. ***

* 840108 DELETE

840100 WWFIXB 620 955.0 0.001 1.0 TT 280 * Attemperator
840105 2 * Interval of application
840106 10 * 1st time on Itt.#
840107 0.90 * Relaxation Fact.
840109 0.0 50000.0 * Limits on control

* DRUM

* 840200 WWVSC 340 0.0 1.0E3 1.0 BBEIBC 750

* 840205 10

* 840206 10

* 840207 1.0

* 840209 80000.0 150000.0

* CONTROL BLOCK

* 845100 1 2

* 845106 10

***** OPERATIONS

* HEAT RATE DEFINITION

873000 1000.0

880010 WW 340 MUL FUEL 340 OPVB 1

880020 OPVB 1 DIV BKGR0 1 OPVB 1

880030 OPVB 1 DIV OPVB 300 OPVB 1

890010 'Gross Plant Heat Rate, BTU/KWH'

890011 OPVB 1

.

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 1

CONTROLS INPUT
(CALCULATIONS BEGIN AT ITRCON = 10)

CONT SET	VALUE OF GOAL(Y) VARIABLE	FRACT. CONV. CRIT.	GOAL(Y) VARIABLE COMBINATION	CONTROL(X) VARIABLE	CONT LIMITS XCLO/ XCHI	INIT./ INTRVL/ RELAX
1	9.55000E+02	1.0E-03	(1.00E+00)*TT	(280) WWFIXB(620)	0.00E+00 5.00E+04 0.9000	10 2

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 2

DEFINITIONS OF SPECIAL OPERATIONS SPECIFIED
(CALCULATIONS BEGIN AT ITROPS = 2)

SET	FIRST VARIABLE (ID)	OPERATION	SECOND VARIABLE (ID)	=	RESULT VARIABLE(ID)	INTERVAL/SPCL INIT*
1	WW (340)	MUL	FUEL (340)	=	OPVB (1)	1/NO
2	OPVB (1)	DIV	BKGRO (1)	=	OPVB (1)	1/NO
3	OPVB (1)	DIV	OPVB (300)	=	OPVB (1)	1/NO

* SPCL INITIATION (YES) - PRIOR TO FIRST ITERATE AT USER OPTION

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 3

OPERATION SET VALUES CALCULATED
AT THE START OF ITERATION 139

SET	VARIABLE (ID) VALUE	OPERATION	VARIABLE (ID) VALUE	=	VARIABLE (ID) VALUE
1	WW (340) 1.38802E+05	MUL	FUEL (340) 6.68000E+03	=	OPVB (1) 9.27198E+08
2	OPVB (1) 9.27198E+08	DIV	BKGRO (1) 6.75778E+01	=	OPVB (1) 1.37205E+07
3	OPVB (1) 1.37205E+07	DIV	OPVB (300) 1.00000E+03	=	OPVB (1) 1.37205E+04

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 4

CONTROLLED VARIABLE VALUES CALCULATED

CONTROL SET	Y VARIABLE/ VALUE FROM ITERATE 139	FRAC(ABS) DEVIATION FROM GOAL	Y VARIABLE GOAL	X VARIABLE/ VALUE USED AT ITERATE 139	CONVG	LAST ITN X LIMTD
1	1.0E+00 * TT (280) 9.55526E+02	-5.5E-04	9.55000E+02	WWFIXB(620) 3.10687E+04	YES	

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 5

TABLE OF NON-ZERO OPERATIONAL VARIABLES
(PRESENTATION IS: ID, VALUE; ID,)

1, 1.37205E+04; 300, 1.00000E+03

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 6

FLAG SETTINGS AND DATA FOR SYSTEM

NTGCYC = 2, FOSSIL TURBINE GENERATOR CYCLE CALCULATION

NTIMES = 139, NUMBER OF SYSTEM ITERATIONS
(ITRMAX = 500, ITRMIN = 5)

NCMP = 60, NUMBER OF COMPONENTS USED IN THIS CASE
(MXCMP = 250, MAXIMUM NUMBER ALLOWED)

NSTR = 86, NUMBER OF STREAMS USED IN THIS CASE
(MXSTR = 360, MAXIMUM NUMBER ALLOWED)

NRHEAT = 0, NON-REHEAT TURBINE PLANT DESIGN

CONVERGENCE DATA:

EXTERR = 1.00000E+00 LBM/HR, EXTRACTION FLOW CONVERGENCE
CIRERR = 1.00000E+00 LBM/HR, TOTAL SYSTEM MASS FLOW CONVERGENCE
TERROR = 5.00000E-06 - , COMPONENT CONVERGENCE
PERROR = 1.00000E-03 - , STREAM CONVERGENCE
GENERR = 1.00000E+00 KW, GENERATOR CONVERGENCE
ENEROR = 1.00000E+03 BTU/HR, ENERGY CONVERGENCE

REFERENCE DATA:

TTDEAD = 50.00 DEG F, DEAD STATE TEMPERATURE
PPDEAD = 14.70 PSIA, DEAD STATE PRESSURE
ZZDEAD = 0.00 FT, DEAD STATE ELEVATION
TTAIR = 50.00 DEG F, AMBIENT TEMPERATURE

STEAM TURBINE DATA:

NTURB = 1, GENERAL ELECTRIC TURBINES
NGEPRO = 3, TURBINES SOLVED, G.E. FOSSIL PROCEDURE GER-2007C
TFREQ = 0.940254, EQUIVALENT THROTTLE FLOW RATIO
TFR1ST = 0.250081, FIRST ADMISSION THROTTLE FLOW RATIO

GENERATOR DATA:

NGNTYP = 2, CONDUCTOR COOLED GENERATOR
NGENER = 1, GENERAL ELECTRIC GENERATOR
NGNCOL = 1, LOSSES ARE PARTIALLY RECOVERABLE THROUGH

COOLERS

ISPEED = 3600 RPM, GENERATOR SPEED
BKGRAT = 88235 KVA, RATED GENERATOR CAPACITY
POWFAC = 0.850, GENERATOR POWER FACTOR
PPGNH2 = 30.00 PSIA, ACTUAL HYDROGEN GENERATOR PRESSURE
PPGNHR = 30.00 PSIA, RATED HYDROGEN GENERATOR PRESSURE

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
 VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
 Heskett Unit 2 Plant Model

PAGE 7

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY (-)	ENTH (B/LB)	ENTRPY (B/LB-F)	SPEC. VOLUME (FT3/LBM)	
1	TFGS	640/I 1/U	0 0	698077. 698077.	952.4 858.9	1291.94 880.48	1.483 1.345	1468.6 1429.5	1.60076 1.61160	6.07E-01 8.38E-01
2	TFLP	650/I 2/U 3/E	0 0 0	689619. 641357. 48262.	858.9 673.1 671.7	880.48 406.43 394.24	1.345 1.184 1.183	1429.5 1348.3 1348.3	1.61160 1.62572 1.62891	8.38E-01 1.58E+00 1.63E+00
4	TFLP	2/I 4/U 5/E	0 0 0	641357. 600355. 41002.	673.1 529.6 528.5	406.43 205.11 198.96	1.184 1.102 1.102	1348.3 1284.8 1284.8	1.62572 1.63769 1.64091	1.58E+00 2.75E+00 2.84E+00
6	TFLP	4/I 6/U 7/E	0 0 0	600355. 573536. 26819.	529.6 355.2 354.3	205.11 77.90 75.56	1.102 1.027 1.027	1284.8 1207.2 1207.2	1.63769 1.65407 1.65730	2.75E+00 6.01E+00 6.19E+00
8	TFLP	6/I 8/U 9/E	0 0 0	573536. 539839. 33698.	355.2 256.1 254.3	77.90 33.13 32.14	1.027 0.982 0.982	1207.2 1149.3 1149.3	1.65407 1.66817 1.67138	6.01E+00 1.23E+01 1.27E+01
10	TFLP	8/I 10/U 11/E	0 0 0	539839. 495250. 44589.	256.1 199.4 197.9	33.13 11.38 11.04	0.982 0.938 0.939	1149.3 1085.8 1085.8	1.66817 1.68646 1.68957	1.23E+01 3.19E+01 3.29E+01
12	TFLP	10/I 12/U	0 0	495250. 495250.	199.4 94.7	11.38 0.81	0.938 0.880	1085.8 978.0	1.68646 1.77119	3.19E+01 3.59E+02
100	COND	12/S 310/T 212/D 103/D 100/T	0 0 0 0 0	495250. 15200000. 869. 496119. 15200000.	94.7 50.0 210.3 94.7 79.9	0.81 20.00 14.20 0.81 20.00	0.880 -0.185 0.000 0.000 -0.154	978.0 18.1 178.5 62.7 48.0	1.77119 0.03604 0.30946 0.11999 0.09291	3.59E+02 1.60E-02 1.67E-02 1.61E-02 1.61E-02
102	FWH	104/T 3/S 102/T 105/D	0 0 0 0	668931. 48262. 668931. 48262.	376.2 671.7 442.4 391.0	1792.93 394.24 1785.62 384.66	-0.585 1.183 -0.442 -0.069	351.8 1348.3 422.7 365.7	0.53279 1.62891 0.61435 0.55483	1.82E-02 1.63E+00 1.91E-02 1.85E-02
104	FWH	620/T 550/S 105/D 104/T 106/D	0 0 0 0 0	668931. 42572. 48262. 668931. 90833.	310.5 541.1 391.0 376.2 327.0	1800.00 198.96 384.66 1792.93 193.01	-0.724 1.110 -0.069 -0.585 -0.064	283.7 1291.5 365.7 351.8 297.9	0.44795 1.64773 0.61435 0.53279 0.47290	1.74E-02 2.88E+00 1.85E-02 1.82E-02 1.77E-02

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
 VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
 Heskett Unit 2 Plant Model

PAGE 8

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY (-)	ENTH (B/LB)	ENTRPY (B/LB-F)	SPEC. VOLUME (FT3/LBM)
106 D-A	108/FW	0	574406.	247.0	74.00	-0.067	215.7	0.36329	1.70E-02
	540/S	0	34761.	452.7	75.56	1.084	1258.0	1.71624	7.04E+00
	106/D	0	90833.	327.0	193.01	-0.064	297.9	0.47290	1.77E-02
	109/D	0	700000.	308.1	75.56	0.000	278.1	0.44795	1.75E-02
108 FWH	520/T	0	574406.	190.3	75.88	-0.132	158.5	0.27896	1.66E-02
	680/S	0	33698.	254.3	32.14	0.982	1149.3	1.67138	1.27E+01
	108/T	0	574406.	247.0	74.00	-0.067	215.7	0.36329	1.70E-02
	111/D	0	33697.	206.2	31.67	-0.050	174.3	0.30323	1.67E-02
110 FWH	430/T	0	496119.	105.9	80.00	-0.231	74.1	0.13983	1.61E-02
	530/S	0	44589.	197.9	11.04	0.939	1085.8	1.68957	3.29E+01
	111/D	0	33697.	206.2	31.67	-0.050	174.3	0.30323	1.67E-02
	110/T	0	496119.	189.2	75.23	-0.133	157.4	0.27720	1.66E-02
	112/D	0	78286.	197.4	10.92	0.000	165.5	0.29001	1.80E-02
200 HXGC	420/T	0	496119.	94.7	40.00	-0.185	62.8	0.12001	1.61E-02
	200/T	0	496119.	103.6	40.00	-0.176	71.7	0.13590	1.61E-02
210 HXGN	200/T	0	496119.	103.6	40.00	-0.176	71.7	0.13590	1.61E-02
	560/S	0	869.	886.8	880.48	1.368	1445.4	1.62357	8.60E-01
	210/T	0	496119.	105.8	40.00	-0.173	73.9	0.13983	1.61E-02
	212/D	0	869.	210.3	14.20	0.000	178.5	0.30946	1.67E-02
220 HCNV	102/T	0	668931.	442.4	1785.62	-0.442	422.7	0.61435	1.91E-02
	500/S	8	1054686.	636.8	14.68	N.A.	362.7	1.77820	2.80E+01
	220/T	0	668931.	472.1	1748.99	-0.363	455.7	0.65039	1.96E-02
	222/D	8	1054686.	561.3	14.66	N.A.	341.8	1.75856	2.61E+01
230 HXFB	460/T	0	1505095.	566.8	1475.00	-0.067	570.5	0.76861	2.22E-02
	230/T	0	1505095.	588.2	1411.80	0.211	721.6	0.91339	8.13E-02
240 HCNV	632/T	0	1003397.	566.4	1400.00	-0.049	570.2	0.76861	2.22E-02
	262/S	7	954686.	1065.7	14.69	N.A.	496.1	1.86617	3.89E+01
	240/T	0	1003397.	586.5	1394.13	0.134	675.6	0.86959	6.06E-02
	242/D	7	954686.	687.1	14.68	N.A.	385.4	1.78286	2.93E+01
250 HCNV	630/T	0	836164.	566.4	1400.00	-0.049	570.2	0.76861	2.22E-02
	700/S	7	954686.	2009.2	14.70	N.A.	792.0	2.01677	6.29E+01
	250/T	0	836164.	586.3	1392.15	0.258	747.0	0.93798	9.55E-02
	252/D	7	954686.	1522.3	14.70	N.A.	637.1	1.94693	5.05E+01

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
 VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
 Heskett Unit 2 Plant Model

PAGE 9

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY (-)	ENTH (B/LB)	ENTRPY (B/LB-F)	SPEC. VOLUME (FT3/LBM)
260	HCNV	750/T	0	668931.	587.1	1400.00	1.000	1175.3	1.34736 3.02E-01
		272/S	7	954686.	1382.9	14.70	N.A.	593.3	1.92403 4.70E+01
		260/T	0	668931.	721.6	1388.95	1.238	1314.1	1.47362 4.25E-01
		262/D	7	954686.	1065.7	14.69	N.A.	496.1	1.86617 3.89E+01
270	HCVN	510/T	0	700000.	666.7	1388.95	1.159	1268.3	1.43396 3.85E-01
		252/S	7	954686.	1522.3	14.70	N.A.	637.1	1.94693 5.05E+01
		270/T	0	700000.	737.8	1362.20	1.258	1328.1	1.48720 4.46E-01
		272/D	7	954686.	1382.9	14.70	N.A.	593.3	1.92403 4.70E+01
280	HXFB	270/T	0	700000.	737.8	1362.20	1.258	1328.1	1.48720 4.46E-01
		280/T	0	700000.	955.5	1345.77	1.495	1468.6	1.59657 5.82E-01
290	HXGN	400/T	3	820106.	118.8	17.60	N.A.	153.0	1.65314 1.23E+01
		681/S	0	0.	254.3	32.14	0.982	1149.3	1.67138 1.27E+01
		290/T	3	820106.	118.8	17.60	N.A.	153.0	1.65314 1.23E+01
		292/D	0	0.	254.3	32.14	0.982	1149.3	1.67138 1.27E+01
295	HXGN	222/T	8	1054686.	561.3	14.66	N.A.	341.8	1.75856 2.61E+01
		290/S	3	820106.	118.8	17.60	N.A.	153.0	1.65314 1.23E+01
		295/T	8	1054686.	297.7	14.66	N.A.	271.1	1.67853 1.94E+01
		297/D	3	820106.	488.4	17.60	N.A.	243.9	1.77445 2.02E+01
300	SRCE	280/I	0	700000.	955.5	1345.77	1.495	1468.6	1.59657 5.82E-01
		300/U	0	700000.	955.5	1345.77	1.495	1468.6	1.59657 5.82E-01
310	SRCE	310/U	0	15200000.	50.0	20.00	-0.185	18.1	0.03604 1.60E-02
320	INPUT	320/U	3	1500000.	90.0	14.70	N.A.	145.9	1.65314 1.40E+01
330	SRCE	330/U	4	5060.	100.0	14.70	N.A.	4.6	0.00839 N.A.
340	SRCE	340/U	5	138802.	50.0	14.70	N.A.	70.5	0.68771 N.A.
350	SINK	610/I	3	579894.	90.0	14.70	N.A.	145.9	1.65314 1.40E+01
360	SINK	701/I	6	9282.	1511.1	14.70	N.A.	291.4	0.27433 5.02E+01
370	SINK	100/I	0	15200000.	79.9	20.00	-0.154	48.0	0.09291 1.61E-02

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
 VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
 Heskett Unit 2 Plant Model

PAGE 10

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY (-)	ENTH (B/LB)	ENTRPY (B/LB-F)	SPEC. VOLUME (FT3/LBM)
380	OPUT	410/I	8	1054686.	298.3	14.70	N.A.	271.2	1.67853 1.93E+01
399	VTHR	300/I	0	700000.	955.5	1345.77	1.495	1468.6	1.59657 5.82E-01
		399/U	0	700000.	952.4	1291.94	1.483	1468.6	1.60076 6.07E-01
400	PMGC	601/I	3	820106.	90.0	14.70	N.A.	145.9	1.65314 1.40E+01
		400/U	3	820106.	118.8	17.60	N.A.	153.0	1.65314 1.23E+01
410	PMGC	295/I	8	1054686.	297.7	14.66	N.A.	271.1	1.67853 1.94E+01
		410/U	8	1054686.	298.3	14.70	N.A.	271.2	1.67853 1.93E+01
420	PMEL	103/I	0	496119.	94.7	0.81	0.000	62.7	0.11999 1.61E-02
		420/U	0	496119.	94.7	40.00	-0.185	62.8	0.12001 1.61E-02
430	PMEL	210/I	0	496119.	105.8	40.00	-0.173	73.9	0.13983 1.61E-02
		430/U	0	496119.	105.9	80.00	-0.231	74.1	0.13983 1.61E-02
440	PMEL	112/I	0	78286.	197.4	10.92	0.000	165.5	0.29001 1.80E-02
		440/U	0	78286.	197.5	80.00	-0.129	165.8	0.29003 1.66E-02
450	PMEL	109/I	0	700000.	308.1	75.56	0.000	278.1	0.44795 1.75E-02
		450/U	0	700000.	310.5	1800.00	-0.724	283.7	0.44795 1.74E-02
460	PMEL	631/I	0	1505095.	566.4	1400.00	-0.049	570.2	0.76861 2.22E-02
		460/U	0	1505095.	566.8	1475.00	-0.067	570.5	0.76861 2.22E-02
500	MX51	242/IA	7	954686.	687.1	14.68	N.A.	385.4	1.78286 2.93E+01
		611/IB	3	100000.	90.0	14.70	N.A.	145.9	1.65314 1.40E+01
		500/U	8	1054686.	636.8	14.68	N.A.	362.7	1.77820 2.80E+01
510	MIXR	260/IA	0	668931.	721.6	1388.95	1.238	1314.1	1.47362 4.25E-01
		621/IB	0	31069.	310.5	1800.00	-0.724	283.7	0.44795 1.74E-02
		510/U	0	700000.	666.7	1388.95	1.159	1268.3	1.43396 3.85E-01
520	MIXR	110/IA	0	496119.	189.2	75.23	-0.133	157.4	0.27720 1.66E-02
		440/IB	0	78286.	197.5	80.00	-0.129	165.8	0.29003 1.66E-02
		520/U	0	574406.	190.3	75.88	-0.132	158.5	0.27896 1.66E-02
530	MX51	11/IA	0	44589.	197.9	11.04	0.939	1085.8	1.68957 3.29E+01
		292/IB	0	0.	254.3	32.14	0.982	1149.3	1.67138 1.27E+01
		530/U	0	44589.	197.9	11.04	0.939	1085.8	1.68957 3.29E+01

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
 VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
 Heskett Unit 2 Plant Model

PAGE 11

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY (-)	ENTH (B/LB)	ENTRPY (B/LB-F)	SPEC. VOLUME (FT3/LBM)
540 MX51	7/IA	0	26819.	354.3	75.56	1.027	1207.2	1.65730	6.19E+00
	671/IB	0	7943.	858.9	880.48	1.345	1429.5	1.61160	8.38E-01
	540/U	0	34761.	452.7	75.56	1.084	1258.0	1.71624	7.04E+00
550 MX51	5/IA	0	41002.	528.5	198.96	1.102	1284.8	1.64091	2.84E+00
	660/IB	0	1569.	952.4	1291.94	1.483	1468.6	1.60076	6.07E-01
	550/U	0	42572.	541.1	198.96	1.110	1291.5	1.64773	2.88E+00
560 MX51	661/IA	0	354.	952.4	1291.94	1.483	1468.6	1.60076	6.07E-01
	670/IB	0	515.	858.9	880.48	1.345	1429.5	1.61160	8.38E-01
	560/U	0	869.	886.8	880.48	1.368	1445.4	1.62357	8.60E-01
570 M3WA	250/IA	0	836164.	586.3	1392.15	0.258	747.0	0.93798	9.55E-02
	230/IB	0	1505095.	588.2	1411.80	0.211	721.6	0.91339	8.13E-02
	240/IC	0	1003397.	586.5	1394.13	0.134	675.6	0.86959	6.06E-02
	570/U	0	3344656.	587.2	1401.74	0.199	714.1	0.90640	7.86E-02
600 SDEM	320/I	3	1500000.	90.0	14.70	N.A.	145.9	1.65314	1.40E+01
	600/U	3	679894.	90.0	14.70	N.A.	145.9	1.65314	1.40E+01
	601/B	3	820106.	90.0	14.70	N.A.	145.9	1.65314	1.40E+01
610 SFIX	600/I	3	679894.	90.0	14.70	N.A.	145.9	1.65314	1.40E+01
	610/U	3	579894.	90.0	14.70	N.A.	145.9	1.65314	1.40E+01
	611/B	3	100000.	90.0	14.70	N.A.	145.9	1.65314	1.40E+01
620 SFIX	450/I	0	700000.	310.5	1800.00	-0.724	283.7	0.44795	1.74E-02
	620/U	0	668931.	310.5	1800.00	-0.724	283.7	0.44795	1.74E-02
	621/B	0	31069.	310.5	1800.00	-0.724	283.7	0.44795	1.74E-02
630 SPCT	751/I	0	3344656.	566.4	1400.00	-0.049	570.2	0.76861	2.22E-02
	630/U	0	836164.	566.4	1400.00	-0.049	570.2	0.76861	2.22E-02
	631/B	0	1505095.	566.4	1400.00	-0.049	570.2	0.76861	2.22E-02
	632/C	0	1003397.	566.4	1400.00	-0.049	570.2	0.76861	2.22E-02
640 SVSL	399/I	0	700000.	952.4	1291.94	1.483	1468.6	1.60076	6.07E-01
	640/U	0	698077.	952.4	1291.94	1.483	1468.6	1.60076	6.07E-01
	641/B	0	1923.	952.4	1291.94	1.483	1468.6	1.60076	6.07E-01
650 SSPL	1/I	0	698077.	858.9	880.48	1.345	1429.5	1.61160	8.38E-01
	650/U	0	689619.	858.9	880.48	1.345	1429.5	1.61160	8.38E-01
	651/B	0	8458.	858.9	880.48	1.345	1429.5	1.61160	8.38E-01

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
 VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
 Heskett Unit 2 Plant Model

PAGE 12

COMPONENT PROPERTIES

COMP	STREAM /PORT	FLU ID	MASS FLOW (LBM/HR)	TEMP (F)	PRESS (PSIA)	QUALITY (-)	ENTH (B/LB)	ENTRPY (B/LB-F)	VOLUME (FT3/LBM)	SPEC.
660 SVSL	641/I	0	1923.	952.4	1291.94	1.483	1468.6	1.60076	6.07E-01	
	660/U	0	1569.	952.4	1291.94	1.483	1468.6	1.60076	6.07E-01	
	661/B	0	354.	952.4	1291.94	1.483	1468.6	1.60076	6.07E-01	
670 SSPL	651/I	0	8458.	858.9	880.48	1.345	1429.5	1.61160	8.38E-01	
	670/U	0	515.	858.9	880.48	1.345	1429.5	1.61160	8.38E-01	
	671/B	0	7943.	858.9	880.48	1.345	1429.5	1.61160	8.38E-01	
680 SFIX	9/I	0	33698.	254.3	32.14	0.982	1149.3	1.67138	1.27E+01	
	680/U	0	33698.	254.3	32.14	0.982	1149.3	1.67138	1.27E+01	
	681/B	0	0.	254.3	32.14	0.982	1149.3	1.67138	1.27E+01	
700 FBED	297/IA	3	820106.	488.4	17.60	N.A.	243.9	1.77445	2.02E+01	
	340/IF	5	138802.	50.0	14.70	N.A.	70.5	0.68771	N.A.	
	330/IS	4	5060.	100.0	14.70	N.A.	4.6	0.00839	N.A.	
	700/U	7	954686.	2009.2	14.70	N.A.	792.0	2.01677	6.29E+01	
	701/B	6	9282.	1511.1	14.70	N.A.	291.4	0.27433	5.02E+01	
750 DRUM	220/FW	0	668931.	472.1	1748.99	-0.363	455.7	0.65039	1.96E-02	
	570/RI	0	3344656.	587.2	1401.74	0.199	714.1	0.90640	7.86E-02	
	750/ST	0	668931.	587.1	1400.00	1.000	1175.3	1.34736	3.02E-01	
	751/DC	0	3344656.	566.4	1400.00	-0.049	570.2	0.76861	2.22E-02	

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 13

DETAILED FEEDWATER HEATER PERFORMANCE OUTPUT - TABLE A
(EXTRACTION FLOW UPDATING BEGINS AT ITERATION 2)

HTR	COMP	COMPONENT	HEAT TRANSFER/DEG*	HEAT#	TERM	DRAIN	FW OR	UPD	INT/
NO.	NO.	DESCRIPTION	CONDENSING SUBCOOL/MX SECTION	EX SECTION	PERF	TEMP DIFF	COOL DIFF	PRESS	(RELAXN)
					INDEX	(TTD)	(DCA)	DROP	DEMAND
			(B T U / H R - F)		(-)	(F)	(F)	(PSIA)	(-)
1	102	FW. W/DESUP+COOL	3.53E+05	8.05E+04	0.98	0.80	14.8	7.3	1(1.00)
2	2	104 FW. W/DESUP+COOL	3.85E+05	1.65E+05	0.97	5.13	16.5	7.1	1(1.00)
4	3	106 CONTACT HEATER	N.A.	N.A.	0.82	0.00	N.A.	-1.6	1(1.00)
6	4	108 FWHT. BACK-DRAIN	1.25E+06	4.84E+04	0.98	7.27	15.9	1.9	1(1.00)
8	5	110 STD. FW. HEATER	1.17E+06	3.24E+03	0.85	8.78	N.A.	4.8	1(1.00) 10
A	100	STD. CONDENSER	1.67E+07	2.25E+03	9.53	N.A.	N.A.	0.0	N.A.

* HEAT TRANSFER/DEG IS SIMILAR TO UA. SEE VOL 1 OUTPUT DESCRIPTION.

PERFORMANCE INDEX IS SIMILAR TO EFFECTIVENESS. SEE VOL 1 OUTPUT DESCRIPTION.

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
 VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
 Heskett Unit 2 Plant Model

PAGE 14

DETAILED FEEDWATER HEATER PERFORMANCE OUTPUT - TABLE B

HTR	COMP	COMPONENT	HEAT XFER TO FW OR CIRC.H2O	ENTHALPY RISE FW.OR CIRC.	MASS FLOWS		
NO.	NO.	DESCRIPTION	(BTU/HR)	DROP EXT STEAM (BTU/LBM)	TO HEATER SHELL	RATE HEATER DRAIN IN (L B M / H R)	RATE THRU TUBES
1	102	FW. W/DESUP+COOL	4.74E+07	70.9 982.6	48262.	0.	668931.
2	104	FW. W/DESUP+COOL	4.56E+07	68.1 993.6	42572.	48262.	668931.
3	106	CONTACT HEATER	3.59E+07	62.4 979.9	34761.	90833.	574406.
4	108	FWHT. BACK-DRAIN	3.29E+07	57.2 975.0	33698.	0.	574406.
5	110	STD. FW. HEATER	4.13E+07	83.3 920.3	44589.	33697.	496119.
A	100	STD. CONDENSER	4.53E+08	29.8 915.3	495250.	869.	15200000.

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 15

DETAILED HEAT EXCHANGER DESIGN OUTPUT

COMPONENT NUMBER	COMPONENT DESCRIPTION	HEAT TRANS. COEFFICIENT (BTU/HR-FT ² -F)	EFFECTIVE HEAT TRANS. AREA (FT ²)
220	CONVECTIVE STAGE	9.005	17492.39
230	FLUID BED HT.EX.	47.716	5105.09
240	CONVECTIVE STAGE	8.616	46087.17
250	CONVECTIVE STAGE	5.000	25000.00
260	CONVECTIVE STAGE	9.378	17530.09
270	CONVECTIVE STAGE	13.566	4094.54
280	FLUID BED HT.EX.	43.370	3445.93

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 16

DETAILED COMBUSTOR PERFORMANCE OUTPUT

COMP NO.	FUEL RATE (LBM/HR)	FRACT. AIR (-)	AD. (F)	FLAME TEMP. (F)	EXIT TEMP. (F)	IN-AIR/ IN-FUEL	E N E R G Y (B T U / H R) OUT-REFUSE/ OUT-FLU GAS	LOST TO ENVIR.	RESIDENT HX'S	
700	1.388E+05	0.1500	0.0	2009.2	8.293E+07	2.690E+06	7.418E+06	3.258E+08	8.346E+08	5.445E+08

FIRST LAW OF THERMODYNAMICS PERFORMANCE - SYSTEM

HEAT SUPPLIED (ALL UNITS ARE BTU/HR) -		
BOILER HEAT TO WORKING FLUID	\$	-5.54931E+07
1ST BOILER REHEAT (IN, TYPE 25 COMPONENT)		0.00000E+00
2ND BOILER REHEAT (IN, TYPE 25 COMPONENT)		0.00000E+00
UNSPECIFIED HEAT EXCHANGERS (HEAT IN)		0.00000E+00
GROSS HEAT SUPPLIED	\$	-5.54931E+07
MAKEUP HEAT (BY FLOW IN)		-1.52752E+10
LETDOWN HEAT (BY FLOW OUT)		-1.56518E+10
CIRC WATER LOAD CREDIT (HEAT IN)		4.53416E+08
COMPONENT VESSEL LOSSES		0.00000E+00
PIPE HEAT AND ELEVATION LOSSES		0.00000E+00
PUMP/COMP/FAN INEFFICIENCY LOSSES		0.00000E+00
PUMP GLANDS AND SEALS LOSSES		0.00000E+00
GENERATOR HYD AND OIL COOLER (HEAT IN)		4.40673E+06
NET HEAT SUPPLIED		7.78975E+08
HEAT IN AS ELECTRIC PUMP/COMP/FAN POWER		1.04309E+07
NET POWER SUPPLIED		7.89406E+08

POWER OUT (ALL UNITS ARE MWE) -		
NET TURBINE WHEEL POWER TO GENERATORS		69.013
GENERATOR MECHANICAL LOSSES		0.327
GENERATOR ELECTRICAL LOSSES		1.109
GROSS GENERATOR POWER		67.578
ELECTRIC POWER USED FOR PUMP/COMP/FAN		3.057
HOUSE LOAD POWER, EXCLUDING ELEC PUMP/COMP/FAN		0.000
NET GENERATOR POWER		64.521

SYSTEM PERFORMANCE	THERMAL EFF.	HEAT RATE (BTU/KW-HR)
GROSS ACTUAL TURBINE CYCLE (GROSS HEAT SUPPLIED / GROSS GENERATOR POWER)	-4.15520	\$ -821.
NET ACTUAL TURBINE CYCLE (MOD NET POWER SUPPLIED / NET GENERATOR POWER)	0.27889	12235.
TURBINE CYCLE STEAM RATE, LBM/KW-HR		22.1966

NOTE: MOD NET POWER SUPPLIED = NET POWER SUPPLIED + COMPONENT VESSEL LOSSES + PIPE HEAT AND ELEVATION LOSSES + PUMP INEFFICIENCY LOSSES + PUMP GLANDS AND SEALS LOSSES

\$ -- CAUTION INTERPRETING BOILER HEAT AND GROSS HEAT RATE AND EFFICIENCY, RE INPUT/OUTPUT MASS DIFFERENCE. SEE VOLUME 1, SECTION 24. ADVISE USER DEFINE HEAT RATE AND EFFICIENCY.

PEPSE CODE BY NUS CORPORATION, IDAHO FALLS, ID.
VERSION 56D CREATED 22 JAN 91 DATE 05/24/91.
Heskett Unit 2 Plant Model

PAGE 18

SPECIAL OUTPUT TABLE OF SPECIFIED VARIABLES

INDEX	DESCRIPTION	VARIABLE(ID)	VALUE
1	Gross Plant Heat Rate, BTU/KWH	OPVB (1)	1.372046E+04